




Figure I-23: South Kearny Pump Station Service Area

I.3.8 Rainfall Derived Infiltration and Inflow (RDII)

The model uses the RTK unit hydrograph (UH) to estimate RDII into the separate area sewer systems. As shown in **Figure I-24**, a RTK UH set contains up to three hydrographs (Muleta & Boulos, 2008): one for a short-term response (UH1), one for an intermediate-term response (UH2), and one for a long-term response (UH3). UH1 represents the most rapidly responding inflow component and has a short T value, UH2 includes both inflow and infiltration and has a longer T value, and UH3 includes infiltration that may continue long after the storm event has ended and has the longest T value. The unit hydrograph is defined by the following three parameters:

- R: the fraction of rainfall volume that enters the sewer system and equals to the volume under the hydrograph,
- T: the time from the onset of rainfall event to the peak of the unit hydrograph in hours, and
- K: the ratio of time to recession of the unit hydrograph to the time to peak.

The same set of RDII parameters were applied in the same metershed because of the availability of the flow hydrograph for model calibration. The initial values of RTK were estimated based on previous modeling document. The RTK values are calibration parameters to be refined during model calibration.



Source: M.K. Muleta and P.F. Boulous, Analysis and Calibration of RDII and Design of Sewer Collection Systems, ASCE Conference Proceedings 316, 642 (2008)

Figure I-24: RTK Unit Hydrograph

I.3.9 Dry Weather Flow

Dry Weather flow shown in **Figure E-4** was assigned to subcatchments in proportion to the service area in the same metershed. Same weekday and weekend dry weather flow diurnal patterns (example **Figure E-5**) developed from flow metering data were assigned to the subcatchments in the same metershed. Concentration of Pollutant PL1 was assumed to be 100 for all dry weather input, this allows users to differentiate wet weather flow quantity from the dry weather flow quantity.

I.3.10 Real Time Control (RTC)



RTC for Gate Operation of Regulators along PVSC Interceptor

Real time controls for gate operation of regulators along PVSC interceptor were developed based on the PVSC Primary Clarifier Auto Fill System Operating Procedure (SOP, October 27, 2016). The SOP includes sequenced procedures to be performed during wet weather conditions. These procedures were incorporated into the PVSC model through real time controls. Schematics in **Figure I-25** illustrate the following wet weather operating procedures in the model:



- (a) When the WRRF flow (including flows from the Hudson County Force Main) is less than 350 MGD, all regulator gates are kept open
- (b) When the WRRF flow increases above 350 MGD, close regulator gates on Verona Ave. (N_002A), Herbert Pl. (N_004A/005A), 4th Ave. (N_008A), Saybrook Pl. (N_014A), City Dock (N_015A), Jackson St. (N_016A), Polk St. (N_017A), and Freeman St. (N_018A).

During 10/7/2015 to 7/7/2016 (model calibration events were in this period), these regulator gate were put in use at plant flow 400 MGD.



- (c) When the WRRF flow further increases to above 400 MGD, start primary clarifier (PC) filling at flow rate 50 MGD
- (d) When the PC storage is full, stop PC filling and close regulator gate at Clay St.
- (e) When the WRRF flow recede to 350 MGD post storm event, open all regulator gates and start dewatering PC storage





(a) Keep regulator gate open when WRRF flow is less than ~~400~~350 MGD




(b) Close regulator gates (except Clay Street) when WRRF flow is greater than 350 MGD



(c) Start filling PC Storage when flow is greater than 400 MGD



(d) Close Clay Street regulator gate when the PC Storage is full



(e) Open regulator gate and dewater PS Storage when WRRF flow recedes to 350 MGD

Figure I-25: PVSC Wet Weather Operating Procedure

RTC for Gate Operation of Regulators in City of Bayonne

All real time controls for City Bayonne regulators are inherited from its original model, with update of unit conversion detailed in **Table I-4**.


I.4 MODEL CONSTRUCTION SUMMARY

The PVSC CSO LTCP model was developed from the integration of four existing CSO community models in InfoWorks ICM 9.0 based on PVSC datum. The model was then further expanded to include all separate sewer service areas. The model has the following features:

- 1121 subcatchments, including all 48 served communities (both combined and separate)
- 4216 nodes, including 4081 manholes, 123 CSO outfalls, and 12 storage for pump station wet well and primary clarifier serving as a storage facility. Real time control rules were set up for filling the primary clarifiers served as storage facility based on the wet weather Standard Operating Procedure (SOP) of PVSC WRRF.
- 4413 links, including 4039 conduits, 42 orifice, 120 weirs, 101 flap valves, 95 sluice gates, and 16 pumps. 34 of the 95 gates are with variable gate openings to be regulated during wet weather conditions. Real time control rules were set up for the variable gate based on wet weather SOP.
- Hudson County Force Main was extended to the PVSC WRRF based on drawings to convey flows from the Hudson County to the WRRF. Force main from Bayonne was extended to the tie-in point to the Hudson County Force Main. Force Main from North Bergen was extended to the Jersey City sewer system.
- South Kearny pump station and force main are also added and tied into the Hudson County Force Main. The force main receive flows from Kearny Meadowlands District and South Kearny District, both areas are with separate sewer.
- Dry weather flow based on 2016 flow monitoring data.
- Wet weather flow simulated as runoff from the combined areas and RDII from the separate areas.
- Real time control based on the current PVSC WRRF wet weather SOP.

Model network of the integrated PVSC model is shown in **Figure I-26**. Quantities of subcatchments, nodes and links are also shown on the map. Two permanent meters (Jersey City West Pump Station and Jersey City East Pump Station) shown on the map are the meters used for flow verification. Calibration/validation of Jersey City model is not part of the efforts of this study because Jersey City is in charge of its model and the received model has been calibrated. Therefore the characteristics of Jersey City model remains unchanged in the integrated PVSC model.

THIS PAGE INTENTIONALLY LEFT BLANK






Figure I-26: Snapshot of Entire PVSC H&H Model Network

1.5 H&H MODEL CALIBRATION/VALIDATION

Model credibility is developed through model calibration and validation. Model calibration involves application of the model to known external inputs (e.g., rainfall), evaluation of the model's ability to replicate monitored conditions (e.g., flow and volume), and adjustment of key model parameters as needed until an acceptable level of agreement is reached between simulated and monitored conditions. Model validation generally involves verifying model performance with additional independent storm events. Further model adjustments are often made during model validation process to improve model accuracy. Due to the limited availability of monitoring data, it is common practice for H&H models to undergo a single calibration/validation process. In this approach, model parameters are adjusted to improve model

accuracy across all of the events, and then each event is evaluated independently to verify model performance across a range of conditions. The four storm events identified in Section E.9 were used for the PVSC model calibration/validation.

The collection system H&H Model was calibrated in conjunction with the flow monitoring. The H & H Model was calibrated by running the model with rainfall data collected from selected storms and then comparing the calculated results to the actual flow monitoring data collected. The model parameters were adjusted and the process repeated until the calculated results approximated the actual flow monitor measurements. Goals for the model calibration included:

- To match visually the shape of the curve between model and flow monitor.
- To match model runoff volumes (volume under curve) to actual runoff volumes.
- To match model runoff peak flow rates to actual runoff peak flow rates.

I.5.1 Dry Weather Flow Calibration/Validation

Dry weather flow (DWF) analysis was based on the rainfall and flow monitoring results. DWF distribution in the collection system was based on land use data. Weekday, weekend and monthly diurnal factors from the DWF analysis were applied for each flow meter service area. Upstream meters in the system were calibrated first, then flows through the system to the pumps stations and to the WRRF were balanced. **Figure E-4** shows the arrangement of the meters in the system and meter identification.

The DWF calibration goals are included below based on the “Code of Practice for the Hydraulic Modeling of Sewer Systems” by the Wastewater Planning Users Group (WPUG):

- The simulated hydrograph should match the general observed hydrograph shape,
- The simulated time of peaks and troughs will be within 1 hour of the observed,
- The simulated peak flow will be within 10% of the observed flow, and
- The simulated flow volume over 24 hours will be within 10% of observed flow.

After the dry weather calibration was considered to be satisfactory, the model was calibrated for wet weather periods as described below.

I.5.2 Wet Weather Calibration/Validation

Wet weather flow (WWF) includes surface runoff from the combined area and RDII from the combined and separate sewered areas. Surface runoff parameters for the combined area and RDII parameters for the separate area were adjusted to calibrate the system response to the wet weather conditions.

The WWF calibration goals are also based on the “Code of Practice for the Hydraulic Modeling of Sewer Systems” by WPUG:

:

- The simulated hydrograph should match the general observed hydrograph shape,
- The simulated time of peaks and troughs will be similar,

- The simulated peak flow for significant peaks will be within the range of -15% to +25%,
- The simulated flow volume will be within the range of -10% to +20%,

Storm events were analyzed based on precipitation data from the Newark Liberty International Airport. Four storm events selected for calibration/validation of the collection system model met all the desired storm characteristics as describe in **Section E** of this Report. The July 25, 2016 storm was a 1.81-inch storm with a duration of approximately 3 hours and a maximum intensity of 1.68 in/hr. The May 29, 2016 storm was a 1.60-inch storm with a duration of 5.75 hours and a maximum intensity of 1.09 inches/hour. The July 25, 2016 storm was a 1.84 inch storm with a duration of 3 hours and a maximum intensity of 1.68 in/hr. The July 29, 2016 storm was a 0.87 inch storm with a duration of 8.5 hours and a maximum intensity of 0.43 in/hr. The July 30, 2016 rain event was a 1.07-inch storm with a duration of 32.75 hours and a maximum intensity of 0.49 in/hr. Detailed storm characterizations can be found in **Table E-5** for all eight rain gauges. Precipitation data collected by the eight rain gauges throughout the PVSC service area were applied to modeling subcatchments based on Thiessen Polygons for model calibration. Examples of model calibration/validation results are shown in the following figures for the observed and simulated flow, the one-to-one plots for modeled versus observed volumes, and the one-to-one plots for modeled versus observed peak flows. A well calibrated model will result in plotted values that are close to a one-to-one relationship. Deviations from this one-to-one relationship can be result from a variety of factors including error inherent with monitoring data, special variations in rainfall, and model limitations. When a modeled versus observed point is well outside of the calibration goal range, a note is provided to explain the likely cause of the discrepancy. Examples of model calibration results are shown in **Figure I-27** to **Figure I-52** for flow meters in different locations of the collection systems. **Appendix D** shows calibration plots for all meters.

- **Figure I-27** to **Figure I-34** for flow meters in along the PVSC Interceptor;
- **Figure I-35** to **Figure I-42** for flow meters in the separate sewer area,
- **Figure I-43** to **Figure I-50** for flow meters in the combined sewer area, and
- **Figure I-51** to **Figure I-54** for flow meters in the CSO overflow lines.

Obtaining accurate flow monitoring in an outfall pipe is often challenging. Most of the time the meter is recording no flow but when the overflow begins the flow rate can increase rapidly. This can result in instabilities in the recorded flows and difficulties in matching modeled and monitored timing for individual overflow meters. Another way to consider how the outfall meters are performing overall is to consider the total predicted vs. monitored overflow volumes for each event across all of the overflow meter locations. **Figure I-55** shows that the model underpredicts the total overflow volume for Event 4, but shows a very good fit for the remaining 3 events. Overall the predicted overflow volume at these metered locations is consistent with the monitored data.




Figure I-27: Calibration Plot for Interceptor_Paterson Main Line_I




Figure I-28: Calibration Plot for Interceptor_Paterson Main Line_II




Figure I-29: Calibration Plot for Interceptor_Passaic Chamber_I




Figure I-30: Calibration Plot for Interceptor_Passaic Chamber_II




Figure I-31: Calibration Plot for Interceptor_Second River Crossing_I




Figure I-32: Calibration Plot for Interceptor_Second River Crossing_II




Figure I-33: Calibration Plot for PVSC WRRF_I




Figure I-34: Calibration Plot for PVSC WRRF_II




Figure I-35: Calibration Plot for Separate Area_Totowa PS_I




Figure I-36: Calibration Plot for Separate Area_Totowa PS_II




Figure I-37: Calibration Plot for Separate Area_Hope Ave_I




Figure I-38: Calibration Plot for Separate Area_Hope Ave_II




Figure I-39: Calibration Plot for Separate Area_Nutley Golf Club_I




Figure I-40: Calibration Plot for Separate Area_Nutley Golf Club_II




Figure I-41: Calibration Plot for Separate Area_Union Outlet_I




Figure I-42: Calibration Plot for Separate Area_Union Outlet_II




Figure I-43: Calibration Plot for Combined Area_Paterson 6A Influent_I




Figure I-44: Calibration Plot for Combined Area_Paterson 6A Influent_II

Note: The simulated volume and peak flow for the May 29, 2016 event exceeded the monitored values beyond the targeted calibration ranges. Adjusting the model parameters to provide a better fit for this event would have resulted in under simulation of the larger events.




Figure I-45: Calibration Plot for Combined Area_Hamilton St._I




Figure I-46: Calibration Plot for Combined Area_ Hamilton St._II

Note:

1. Monitored data was not available for an extended portion of the May 29th, 2016 event. Therefore, this event was not considered during model calibration.
2. The monitored data for the July 29th, 2016 and July 30th, 2016 events also has some missing or periods of zero flow. The calibration effort for this site focused on matching peak flows and the hydrograph pattern.




Figure I-47: Calibration Plot for Combined Area_South 4th St_I




Figure I-48: Calibration Plot for Combined Area_ South 4th St_ II

Note:

1. Accurate monitoring data was not available for the May 29th, 2016 event. Therefore, this event was not considered during model calibration and is not shown on the one-to-one plots.
2. Monitored data for Event July 25, 2016 has significant fluctuations and was therefore not considered during model calibration.




Figure I-49: Calibration Plot for Combined Area_ NB Central Pump Station I




Figure I-50: Calibration Plot for Combined Area_ NB Central Pump Station_II

Note:

1. Monitored data was not available for the May 29th, 2016 and July 25, 2016 events. Therefore, these events were not considered during model calibration and are not shown on the one-to-one plots.




Figure I-51: Calibration Plot for CSO Overflow_NE_15A_I




Figure I-52: Calibration Plot for CSO Overflow_NE_15A_II

Note:

1. Calibration efforts were focused on the July 25, 2016 event because it had the most reasonable wet weather response to rainfall pattern and as the largest event has the most significant impact on overflows. The model is producing overflows during smaller precipitation increments which are not reflected in the monitoring data.




Figure I-53: Calibration Plot for CSO Overflow_KE_07A_I




Figure I-54: Calibration Plot for CSO Overflow_KE_07A_II

Note:

1. The calibration was performed to have a balanced calibration on both overflow volume and peak (both on conservative side).




Figure I-55: System-Wide Overflow Volume Calibration

I.5.3 Model Calibration/Validation Result Statistics

The coefficient of determination, R^2 , is used to evaluate the goodness-of-fit of modeled peak flow and event volume vs. the observed values. The calculation of R^2 is based on the most general definition detailed below.

- Assuming the observed data (event peak or event volume) is represented by a data set with n values marked x_1, \dots, x_n , each associated with a modeled value y_1, \dots, y_n .
- Define the *residuals* as $e_i = x_i - y_i$
- Define the mean of the observed data

$$x_0 = \frac{1}{n} \sum_{i=1}^n x_i$$

- The total sum of squares (proportional to the variance of the data) is:

$$SS_{tot} = \sum_{i=1}^n (x_i - x_0)^2$$

- The sum of squares of residuals (i.e. residual sum of squares) is

$$SS_{res} = \sum_{i=1}^n (x_i - y_i)^2 = \sum_{i=1}^n e_i^2$$

- The definition of R^2 is

$$R^2 = 1 - \frac{SS_{res}}{SS_{tot}}$$

The R^2 defined above is also known as the Nash-Sutcliffe Efficiency (NSE). It is an appropriate statistical measure of the goodness-of-fit for model calibration/validation. It has been widely applied in hydrologic models (Moriassi et al., 2007) and thus can be used to assess the event predictions of the hydrologic component of the model. Although interpretation of NSE values may be subjective, model calibration is generally considered satisfactory for values greater than 0.5, with values greater than 0.75 being considered very good (Moriassi et al., 2007).

Figure I-56 shows modeled vs. observed event peak of all calibrated flow meters for individual events. The R^2 values were calculated for individual event and shown on the figure, they are 0.945, 0.885, 0.947, and 0.879 for Event 1, Event 2, Event 3, and Event 4 respectively.

Figure I-57 shows modeled vs. observed event volume of all calibrated flow meters for individual events. The R^2 values are 0.996, 0.994, 0.992, and 0.995 for Event 1, Event 2, Event 3, and Event 4 respectively.

Figure I-58 shows modeled vs. observed event volume (and peak) of all calibrated flow meters for all four events. The overall R^2 values are 0.909 for event peak and 0.994 for event volume. This is consistent with individual event R^2 .

The R^2 of the event volume is closer to 1 than the R^2 of the event peak for both individual event statistics and entire event statistics, indicating that the model has a more satisfied prediction of the wet weather event volume than the event peak flow. All the R^2 values are greater than 0.85, which means the calibrated model can predict wet weather flows in a great agreement with the metered data for the PVSC sewer collection system.




Figure I-56: Modeled vs. Observed Flow Peak for Individual Events




Figure I-57: Modeled vs. Observed Flow Volume for Individual Events




Figure I-58: Modeled vs. Observed Flow Peak and Volume for All Four Events

1.6 H&H MODEL RESULTS


The calibrated model was run using 2004 rainfall and tides to evaluate collection system performance under existing conditions.

Five-minute precipitation data was developed from 1-minute NOAA ASOS (Automated Surface Observing System, National Centers for Environmental Information) for Newark. Minor gaps in the 5-minute data were filled using corresponding hourly and daily data for the airport. The same precipitation data was applied uniformly system wide.

Model results were extracted for all CSO overflow points and for WRRF and other community effluent flows at 5-minute intervals. The data were converted to 15-minute intervals for overflow event statistics analysis. A 24-hour inter-event-time was used for overflow event definition.

The following figures present a partitioning of the simulated volumes in the typical year. Jersey City flows and runoff have been included in the typical year statistics.

- Figure I-59 Figure I-62 presents the total collection system inflows. Approximately 429% of the total influent volume is attributed to rainfall runoff and RDII, with the remainder coming from sanitary and baseflow.
- Figure I-60 Figure I-63 presents the runoff and losses in the combined sewer areas. Approximately 3227% of the precipitation volume over the combined sewer portions of the model reaches the collection system as runoff. The remainder is lost to hydrologic process such as evaporation and infiltration.
- Figure I-61 Figure I-64 presents the total outflow from the model. Approximately 956% of the flow reaches the plant, with 54% discharging through CSOs.







Figure I-59: Typical Year Collection System Inflows







Figure I-60: Typical Year Runoff and Losses






Figure I-61: Typical Year Total Outflows

I.6.1 Characterization of System Performance

There are 97 rainfall events in the typical year (IET 12 hours), including events with a total rainfall depth less than 0.1 inch. Overflows at each CSO outfall were analyzed for event overflow volume for each rainfall event. Community overflow volume was then estimated by summing CSO event volumes from all CSOs located within the same community. For example, Paterson's total overflow volume is 63 million gallons (from all 23 CSO outfalls in Paterson) for the 3.68-in storm event on Sep 28, 2004. The effects of the same size storm event on different communities are different, this is reasonable because each community has different regulator configurations, system storage capacities, and wet weather operation rules. However, most of the PVSC combined communities start to experience CSO overflow occurrences in a rainfall depth range of 0.2 to 0.3 inches.

- Correlations between community CSO volume and rainfall depth are shown in **Figure I-62** for Paterson and Newark. A rainfall depth of 0.2 inch will trigger overflows in Paterson and Newark.
- Correlations between community CSO volume and rainfall depth are shown in **Figure I-63** for Kearny and Harrison. A rainfall depth of 0.15 inch will trigger overflows in Kearny and a rainfall depth of 0.2 inch will trigger overflows in Harrison.
- Correlations between community CSO volume and rainfall depth are shown in **Figure I-64** for East Newark. A rainfall depth of 0.3 inch will trigger overflows in East Newark.
- Correlations between community CSO volume and rainfall depth are shown in **Figure I-65** for Bayonne and North Bergen. A rainfall depth of 0.15 inch will trigger overflows in Bayonne and a rainfall depth of 0.2 inch will trigger overflows in North Bergen.




Figure I-62: Correlation between Rainfall Depth and CSO Volume (Paterson, Newark)




Figure I-63: Correlation between Rainfall Depth and CSO Volume (Kearny, Harrison)




Figure I-64: Correlation between Rainfall Depth and CSO Volume (East Newark)




Figure I-65: Correlation between Rainfall Depth and CSO Volume (North Bergen, Bayonne)

I.6.2 Overflow Statistics

Typical year CSO volume, frequency and duration is summarized in **Table I-11** for CSO outfalls in Paterson, East Newark, Harrison, Kearny, Newark, North Bergen, and Bayonne. Jersey City was not included in the table. Inter-event time of 24 hours was used to identify overflow events, i.e., multiple periods of overflow from one or more outfalls are considered one overflow event if the time between periods of overflow is no more than 24 hours without a discharge from any outfall. Overflow duration in the table is the total overflow hours at the corresponding CSO outfall in the typical year.

The PVSC system (excluding Jersey City) overflows 59-60 times in the typical year of 2004, with a total overflow volume of 3078-3000 MG and overflow duration of 532-414 hours. Newark has the highest annual overflow volume (1,288+81 MG), followed by Bayonne (791-712 MG), Paterson (541834 MG), North Bergen (251-255 MG), Kearny (247-251 MG), Harrison (57-59 MG), and East Newark (17 MG).


The following figures are provided for visual comparisons of CSO outfalls.


- **Figure I-66** shows overflow volume, frequency and duration for CSOs in Paterson.
- **Figure I-67** shows overflow volume, frequency and duration for CSOs in East Newark, Harrison, Kearny, and Newark. And
- **Figure I-68** shows overflow volume, frequency and duration for CSOs in North Bergen and Bayonne.

Table I-11: Typical Year CSO Overflow Volume, Frequency, and Duration

| CSO ID | Overflow | | | CSO ID | Overflow | | | CSO ID | Overflow | | |
|--------|-------------|------------|-----------------|--------|-------------|------------|-----------------|--------|-------------|------------|-----------------|
| | Volume (MG) | # per Year | Duration (Hour) | | Volume (MG) | # per Year | Duration (Hour) | | Volume (MG) | # per Year | Duration (Hour) |
| PT001 | 14.5 | 2835 | 116162 | EN001 | 17.016.8 | 3434 | 10199 | NB003 | 143.4141.4 | 4342 | 260254 |
| PT003 | 1.41.5 | 1519 | 1721 | | | | | NB005 | 24.424.1 | 4747 | 230227 |
| PT005 | 3.44.2 | 2225 | 4354 | HR001 | 1.61.4 | 2727 | 4439 | NB006 | 0.020.02 | 14 | 14 |
| PT006 | 54.866.0 | 3134 | 135151 | HR002 | 3.02.9 | 2929 | 5350 | NB007 | 13.212.9 | 3030 | 140137 |
| PT007 | 35.744.1 | 3133 | 147162 | HR003 | 13.813.7 | 2929 | 6261 | NB008 | 20.920.5 | 3029 | 116113 |
| PT010 | 4.24.9 | 1520 | 1830 | HR004 | 0.40.4 | 1413 | 108 | NB009 | 25.425.0 | 3535 | 163159 |
| PT013 | 7.19.3 | 2727 | 5468 | HR005 | 19.518.9 | 3232 | 136133 | NB010 | 1.21.0 | 2323 | 3737 |
| PT014 | 0.20.1 | 55 | 23 | HR006 | 7.46.8 | 2828 | 5549 | NB011 | 19.419.2 | 3434 | 132132 |
| PT015 | 0.30.5 | 1118 | 511 | HR007 | 13.513.3 | 4242 | 133133 | NB014 | 6.46.3 | 2727 | 9492 |
| PT016 | 7.812.0 | 2527 | 4251 | | | | | | | | |
| PT017 | 6.17.6 | 2728 | 8392 | KE001 | 3.93.9 | 2929 | 5454 | BA001 | 362.2373.9 | 5659 | 388532 |
| PT021 | 7.38.1 | 3032 | 150160 | KE004 | 12.312.3 | 4949 | 177177 | BA002 | 8.08.7 | 99 | 1314 |
| PT022 | 23.425.2 | 3133 | 164174 | KE006 | 120.6119.3 | 5453 | 251247 | BA003 | 6.040.9 | 2731 | 71108 |
| PT023 | 7.89.3 | 2225 | 6773 | KE007 | 88.186.0 | 3232 | 170165 | BA004 | 0.00.0 | 23 | 14 |
| PT024 | 13.115.9 | 2728 | 7885 | KE010 | 26.326.0 | 4747 | 146144 | BA006 | 11.716.0 | 2833 | 94138 |
| PT025 | 79.7103.2 | 4248 | 153159 | | | | | BA007 | 53.472.1 | 2932 | 97425 |
| PT026 | 0.40.7 | 1216 | 69 | NE002 | 95.591.4 | 4242 | 299266 | BA008 | 2.510.1 | 1630 | 1388 |
| PT027 | 30.260.2 | 2939 | 119130 | NE003 | 00 | 00 | 00 | BA009 | 2.74.2 | 2629 | 3658 |
| PT028 | 2.910.0 | 1626 | 1948 | NE004 | 1.51.4 | 2322 | 3229 | BA010 | 10.117.4 | 3749 | 107179 |
| PT029 | 75.189.9 | 3241 | 139161 | NE005 | 23.721.1 | 3939 | 281246 | BA011 | 5.05.9 | 2930 | 5771 |
| PT030 | 3.04.5 | 34 | 23 | NE008 | 97.693.1 | 4645 | 356323 | BA012 | 11.514.0 | 4149 | 108142 |
| PT031 | 19.69.5 | 2724 | 8539 | NE009 | 187.2162.4 | 3636 | 234207 | BA013 | 0.60.8 | 2429 | 2735 |
| PT032 | 18.022.3 | 2728 | 93101 | NE010 | 187.2162.4 | 3636 | 234207 | BA014 | 13.312.7 | 3737 | 129127 |
| | 0.4 | 10 | 8.5 | NE014 | 191.0179.7 | 4645 | 414384 | BA015 | 45.446.6 | 4447 | 212231 |
| | 0.4 | 12 | 13.3 | NE015 | 81.574.3 | 4039 | 278244 | BA016 | 5.86.5 | 4343 | 119130 |
| | 1.8 | 11 | 11.0 | NE016 | 56.854.2 | 4444 | 272248 | BA017 | 52.054.2 | 5254 | 330350 |
| | | | | NE017 | 112.4107.1 | 4544 | 304277 | BA018 | 13.714.6 | 4650 | 200232 |
| | | | | NE018 | 79.175.4 | 4746 | 357320 | BA019 | 35.638.8 | 3031 | 103112 |
| | | | | NE022 | 46.245.7 | 6059 | 262262 | BA020 | 9.710.1 | 2929 | 6065 |
| | | | | NE023 | 18.316.8 | 3030 | 111108 | BA021 | 52.462.9 | 4447 | 170212 |
| | | | | NE025 | 63.858.2 | 1716 | 3730 | BA022 | 00 | 00 | 00 |
| | | | | NE026 | 21.516.6 | 1917 | 3525 | BA024 | 0.10.1 | 33 | 22 |
| | | | | NE027 | 13.611.3 | 1717 | 4538 | BA026 | 1.31.3 | 99 | 44 |
| | | | | NE030 | 10.810.3 | 1919 | 2221 | BA028 | 00 | 00 | 00 |
| | | | | | | | | BA029 | 6.86.8 | 2323 | 4141 |
| | | | | | | | | BA030 | 1.51.5 | 1616 | 1010 |
| | | | | | | | | BA034 | 0.20.1 | 77 | 64 |
| | | | | | | | | BA037 | 1.11.0 | 98 | 98 |

Note: Overflow statistics were not included in the table for Jersey City.










Figure I-66: Typical Year CSO Overflow Volume and Frequency Paterson










Figure I-67: Typical Year CSO Overflow Volume and Frequency East Newark, Harrison, Kearny and Newark








Figure I-68: Typical Year CSO Overflow Volume and Frequency North Bergen and Bayonne

I.6.3 Percent Capture

Wet weather percent capture was calculated for the PVSC Interceptor communities, North Bergen, and Bayonne. The wet weather volume was estimated based on durations from the time when the accumulated precipitation depth is over 0.1 inch to 12 hours after the storm event.

Table I-12: Typical Year % Capture

| | PVSC Interceptor Communities | North Bergen | Bayonne |
|---|------------------------------|---------------------|------------------------|
| Total WWF Volume (MG) | 12,529 68 | 780 64 | 1,486 04 |
| Total CSO Volume (MG) | 2,033 7 | 254 4 | 773 94 |
| % Capture | 83.8% | 67.4 2 % | 52.143 -6 % |
| Additional Capture Volume (MG) for 85% Capture | 154 2 | 137 6 | 49058 4 |

SECTION J - REFERENCES

- Greeley and Hansen. (2017). *Headworks Design Memorandum*. Report prepared for Passaic Valley Sewerage Commission (PVSC).
- Greeley and Hansen. (2017). *Typical Hydrologic Year Report*. Report prepared for Passaic Valley Sewerage Commission (PVSC).
- Greeley and Hansen. (2018). *Identification of Sensitive Areas Report*. Report prepared for Passaic Valley Sewerage Commission (PVSC).
- Hatch Mott MacDonald. (2003). *Bayonne Municipal Utilities Authority Combined Sewer Overflow Characterization Study and Work Plan*.
- Hatch Mott MacDonald. (2005). *Bayonne Municipal Utilities Authority Combined Sewer Overflow Discharge Characterization Study*.
- Hatch Mott MacDonald. (2007). *Bayonne Municipal Utilities Authority Combined Sewer Overflow LTCP*.
- Iannuzzi, T. J., & Ludwig, D. F. (n.d.). Historical and Current Ecology. *Urban Habitats*, 2(1), pp. 147-173.
- Interstate Environmental Commission. (2018, April 2). *IEC Regulations*. Retrieved from Interstate Environmental Commission: <http://www.iec-nynjct.org/wq.regulations.htm>
- Meadowlands Environmental Research Institute. (2018, April 5). *Sites: Waterbodies and Other Wetlands: The Hackensack River*. Retrieved from Meadowlands Environmental Site Investigation Compilation: <http://meri.njmeadowlands.gov/mesic/sites/waterbodies-and-other-wetlands/hackensack-river-2/>
- New Jersey Department of Environmental Protection. (2017). *2014 New Jersey Integrated Water Quality Assessment Report: Appendix B: Final 303(d) List of Water Quality Limited Waters with Sublist 5 Subpart and Priority Ranking for TMDL Development*. Division of Water Monitoring and Standards, Bureau of Environmental Analysis, Restoration and Standards.
- New Jersey Future. (2018, February 22). *Ripple Effects*. Retrieved from New Jersey Future: <http://www.njfuture.org/wp-content/uploads/2014/06/Water-and-Sewer-System-Ownership-and-Management-in-NJ-CSO-Municipalities-including-Collection-Systems-and-Treatment-Plants.pdf>
- North Bergen Municipal Utilities Authority. (2018, February 22). *Our Mission*. Retrieved from North Bergen Municipal Utilities Authority: <http://www.nbmua.com/mission/>
- Pecchioli, J. A. (2006). *The New Jersey Toxics Reduction Workplan for New York – New Jersey Harbor: Study I-E- Hydrodynamic Studies in the Newark Bay Complex*. Research Project Summary, Division of Science, Research and Technology, N.J. Department of Environmental Protection.
- Pence, A. M. (2004). *Dominant Forces in an Estuarine Complex with Multiple Tributaries and Free connections to the Open Ocean with Application to Sediment Transport*. PhD Thesis, Stevens Institute of Technology.
- State of New Jersey. (2014). *2014 Hazard Mitigation Plan: Appendix P. Watersheds of New Jersey*.
- State of New Jersey. (2018, February 22). *What We Do*. Retrieved from Passaic Valley Sewerage Commission: <http://www.nj.gov/pvsc/what/>
- State of New Jersey Department of Environmental Protection. (2017). *New Jersey Water Supply Plan 2017-2022: Appendix G: Water Regions, Watershed Management Areas, and HUCS11S in New Jersey*.
- Tierra Solutions Inc. (2003). *Executive Summary: Passaic River Study Area: Preliminary Findings*.

SECTION K - ABBREVIATIONS

CSO: Combined Sewer Overflow
CSS: Combined Sewer System
CWA: Clean Water Act
DWF: Dry Weather Flow
EPA: United States Environmental Protection Agency
ESI: Environmental Sensitivity Index
GIS: Geographic Information System
H&H: Hydrologic and Hydraulic
LTCP: Long Term Control Plan
MGD: million gallons per day
NJPDES New Jersey Pollutant Discharge Elimination System
PCBs: polychlorinated biphenyls
QAPP: Quality Assurance Project Plan
SSS: Separate Sewer System
USEPA: United States Environmental Protection Agency
WRRF: Water Resources Recovery Facility

APPENDIX A

Combined Sewer Overflow and Stormwater Sampling Results





APPENDIX A





Sampling Schedule and Dates





A summary of the sampling dates with corresponding locations and sample station identification numbers are shown in the table below. The Sampling Identification is noted at the top of each page in Appendix A.





| CSO Sampling | | |
|--------------|-----------|---|
| Date | Locations | CSO Sample Identification |
| 8/21/2016 | 1 | PAT-06A |
| 11/29/2016 | 5 | HAR-06A, HAR-07A, KEA-07A, NWK-25A, NWK-45A |
| 4/4/2017 | 4 | HAR-06A, HAR-07A, KEA-07A, NWK-91A |
| 4/6/2017 | 4 | NWK-14A, NWK-45A, PAT-06A, PAT-27A |
| 6/19/2017 | 4 | BAY-08A, BAY-10A, PAT-25A, PAT-27A |
| 7/23/2017 | 2 | BAY-08A, BAY-10A |
| 10/24/2017 | 4 | NWK-14A, NWK-25A, NWK-45A, NWK-91A |
| Total | 13 | Unique CSO Locations |
| Total | 27 | CSO Location-Events |





| Stormwater Sampling | | |
|---------------------|-----------|------------------------------------|
| Date | Locations | Stormwater Sample Identification |
| 7/29/2016 | 2 | OAK-LR4, PAT-LR1 |
| 9/19/2016 | 2 | NWK-CI2, PAT-LR1 |
| 9/30/2016 | 2 | NWK-CI2, OAK-LR4 |
| 10/21/2016 | 1 | NWK-HR1 |
| 11/15/2016 | 4 | NWK-CI2, NWK-HR1, OAK-LR4, PAT-LR1 |
| 12/6/2016 | 1 | NWK-HR1 |
| 1/17/2017 | 2 | NWK-HR2, NWK-LR2 |
| 5/5/2017 | 4 | HAW-LR3, NWK-HR2, NWK-LR2, PAT-CI1 |
| 5/22/2017 | 2 | NWK-HR2, NWK-LR2 |
| 5/25/2017 | 2 | HAW-LR3, PAT-CI1 |
| 7/7/2017 | 2 | HAW-LR3, PAT-CI1 |
| Total | 8 | Unique Stormwater Locations |
| Total | 24 | Stormwater Location-Events |















































































































































































































































APPENDIX B

MEG-Model Evaluation Group (MEG) Group Meeting
Summary with comments, MEG -Memorandum, and
Presentations for the following sessions: and Comments:

MEG Meeting 1- February 5, 2016

MEG Meeting 2 – March 17, 2017

MEG Meeting 3 – September 15, 2017

MEG Meeting 4 – December 5, 2018

March 7, 2016 Meeting Summary
PVSC Model Evaluation Group (MEG)
Session 1 Notes

Memorandum

To: PVSC Long Term Control Plan Team

From: PVSC Model Evaluation Group: Alan Blumberg, Steve Chapra, Wayne Huber

Date: March 7, 2016

Subject: Model Evaluation Group – Session 1 Summary

The PVSC Model Evaluation Group held an initial meeting at the offices of PVSC on February 5, 2016. CDM Smith, Greeley and Hansen, and HDR presented an overview of monitoring and modeling that will be implemented for the PVSC Long-Term Control Plan project. The MEG submits the following comments based on discussion at the meeting and our review of the monitoring and modeling QAPPs.

Responses to MEG comments from the project team are shown in italics following each comment.

Monitoring

General

1. We endorse use of data collected by NYC DEP and other reputable groups even though they do not use NJ-approved QAPPs. These data should be compared with data collected in this project to ensure consistency.

Agreed.

2. Storm event monitoring is the most critical element of the program. How will we be assured that the program will obtain wet weather data? Timing sampling to capture events is often difficult.

The sampling QAPP indicates that three wet weather events will be measured at each intensive wet weather sampling station. The team has planned for up to six sampling events to capture the three wet weather events. A project scientist will monitor the weather so that appropriate resources are ready to sample when needed.

3. All collected data should be analyzed and presented as soon as possible.

Collected data and its analysis will be presented to the MEG at the next meeting subsequent to a sampling event or as soon as practical thereafter.

4. The data should be made available to the public so that others have the chance to use it and possibly discover problems.

PVSC Long Term Control Plan Team
March 7, 2016
Page 2

We will discuss this issue with PVSC.

5. The role of historical data collected over the last two decades was not adequately discussed. If land use and system configuration haven't changed much, then these data remain valuable for landside modeling. Conversely, deepening of channels in the Kills and other bathymetric changes affect receiving water dynamics.

Agreed.

6. The MEG inquired whether conservative tracers (e.g. select inorganic ions) that could help characterize sewage loads would be monitored and modeled, but the question was not answered.

We will not monitor or model inorganic ions.

Landside

7. We understand that there will be continuous water level monitoring at several stations along the main interceptor and at key CSO locations. This will be important for hydrologic/hydraulic model calibration and verification. Water levels alone are very useful when hydraulics are modeled dynamically.

Agreed.

8. It might be useful to sample sediment in the interceptor if it has sedimentation issues. This would help address the issue of possible first-flush effects. There seemed to be a variety of opinions offered about the first-flush concept at the meeting.

We will not sample sediment quality in sewers, but will measure sediment depths at flow metering sites.

9. Sampling within the collection system was not discussed. How clean is the upstream collection system? Additionally, interceptor geometry is critical for hydraulic grade line determination.

Sediment conditions in the community sewer systems likely vary widely. They have been incorporated to some extent into the existing collection system models. Newark and Bayonne (as well as Jersey City, which is conducting its own collection system study) already have reasonably detailed local collection system models; detail will be added for other communities as needed for assessing CSO. The existing local models and the PVSC interceptor model represent geometry adequately in all major pipes. The integrated PVSC model will incorporate good representation of the geometry of all pipes downgradient of CSO regulators.

10. Infiltration/inflow (I/I) was discussed, but monitoring of sanitary sewers was not adequately described. Will I/I just get merged with downstream sanitary sewage for estimating bacteria concentrations?

PVSC Long Term Control Plan Team
March 7, 2016
Page 3

PVSC already monitors incoming flows from each of its communities. The modeling can thus discretely represent sanitary flow and I/I. Bacteria concentrations will be separately assigned to each flow component and tracked through the collection system model.

Receiving Water

- 11.** Water quality sampling at predetermined intervals along with a few storm events in detail will provide a start for bacteria calibration, but see comments 15 and 16 below concerning modeling dry-weather bacteria concentrations.
- 12.** Lateral sampling is important; more is needed, especially for bacteria. Stations should be added near the Statue of Liberty, Governors Island, and on the eastern side of Staten Island, perhaps near 455 Front Street, Staten Island.

See Item 12 discussion below.

Summary: The monitoring program will serve the needs of the study with the caveat that the sampling should be designed to characterize the predominant loads. The proposed metering for sewer system hydraulics should be adequate.

Modeling

- 13.** The charge to the MEG (QAPP page 10) should mention review of the model grid prior to running simulations, and should include assessing the validity of calibration and sensitivity simulations.

Agreed.

- 14.** The MEG should be given the chance to evaluate plans for the projection cases and the outcomes.

Agreed.

- 15.** Bacteria are notoriously difficult to quantify from both a precision and accuracy standpoint; an order of magnitude agreement between measurements and the models will be an accomplishment.

We believe that statistical comparisons still have general merit. We will seek further guidance from the MEG, statistical experts, and scientific literature as to what values best represent “central tendency” and “variance” when comparing bacteria concentrations.

- 16.** It is unclear how bacteria loadings will be generated for the model. Probably the most significant contribution will be from sanitary sewage. If most loading is from sanitary sewers, the most useful data will be both influent and effluent strength at the treatment plant, with influent strength used for estimating concentration in CSO during wet weather. Is bacteria concentration at the WWTP monitored regularly?

PVSC Long Term Control Plan Team
March 7, 2016
Page 4

Bacteria concentration is not monitored at the WWTP. We expect to rely on dry weather sewer system sampling included in the planned field program and prior system characterization.

- 17.** The stormwater contribution will need to be calibrated, as we are unaware of consistent loading rates (e.g., MPN/acre) for stormwater. However, it could turn out that during an overflow, the dominant bacteria load is due to the sanitary contribution even though stormwater quantity might be greater. Both sewage and stormwater mass flux (flowrate times concentration) magnitudes will be important.

Bacteria loads for the calibration will be generated by the following methodology:

CSO flows will be based on permittee/NYC DEP InfoWorks or SWMM model. Concentrations will be assigned based on the mass balance approach in which InfoWorks determines the fraction of sanitary and stormwater flow. Sanitary flow concentrations will be based on system-specific data collected during the monitoring program. Stormwater concentrations will be based on literature-derived concentrations based on land use supplemented by site-specific stormwater sampling. A constant concentration, based on geometric mean of the data, will be assigned to the sanitary and stormwater flow components. These concentrations may be spatially variable, depending on the sampling data.

Stormwater flows will be based on a rainfall-runoff model. Stormwater concentrations will be obtained from literature-derived concentrations based on land-use supplemented by site specific stormwater sampling.

Flows from external rivers entering the model domain at the boundary will be based on USGS gauge flow or flow ratios based on gauged and ungauged drainage areas. Flow versus concentration curves will be developed based on sampling data.

Internal rivers will be based on data collected at source sampling stations.

Illicit dry-weather sources will be identified based on dry-weather sampling data. Loads will be estimated via trial and error to match available water quality data. Depending on the required size of the dry weather source, flows may or may not be added to the model, as flow volumes may be trivial.

Ocean boundary conditions are likely to be inconsequential to driving the model solution; they will set to low bacteria concentrations.

The approach to developing projection condition loads may differ from the calibration process. The MEG will participate in the decision process for developing projection conditions. Decisions will need to be made as to whether illicit dry weather loads are part of the projection analysis, and what river and meteorological conditions will be appropriate to use.

PVSC Long Term Control Plan Team
March 7, 2016
Page 5

- 18.** Sensitivity analysis was not adequately discussed. For instance, will receiving water concentrations be most sensitive to load, hydrodynamics (transport processes), or decay rate?

It is likely that the degree of sensitivity will vary within the model domain. Non-tidal freshwater sections will probably be more sensitive to transport processes, while some tidal areas may be more sensitive to the decay rate. Peak concentrations may be more sensitive to the load. In some places, illicit dry weather loads may mask these processes.

The intensive storm event sampling data should inform the spatial bacteria loss rate: transport + decay + other (e.g. settling). The calibrated hydrodynamic model will allow us to estimate the transport component of the loss by executing the water quality model with no decay rate. Previous model experience will allow us to bound expected die-off rates. If additional loss mechanisms are required, the effect of solar radiation and/or settling can be examined. Peak concentrations that are too high or too low will require us to reassess how loads were developed. Since bacteria concentrations range over orders of magnitude, factors that affect concentrations by a factor or two or so may be difficult to assess in terms of how much those factors influence model calibration.

- 19.** What is the frequency of sanitary sewer overflow (SSO) across the system?

No SSO has been reported by the communities.

- 20.** Was it stated that there is not a significant groundwater infiltration contribution to the sewer system, or just that it will not be dynamically modeled? How leaky are the regional sewers?

Base flow in regional streams typically varies from 1.5 cfs per square mile (cfs/m) in spring to less than 0.5 cfs/m in fall; regional sewers can be expected to exhibit similar variation in groundwater-driven infiltration flows. For areas where such seasonality has not already been incorporated into the collection system models, monthly infiltration factors will likely be developed to represent this flow variation based on long-term flow data already collected by PVSC. We will compile long-term flow data for the wastewater treatment plant and key permanent monitoring locations to establish seasonal infiltration factors. (While not directly pertinent to the issue of infiltration in sewers, it is noteworthy that flow in the Hackensack River does not conform to the regional norm. It is strongly regulated by in-line reservoirs and water supply withdrawals; base flow near its mouth averages 0.2 cfs/m.)

- 21.** Good coordination with the municipalities will be important if they want to use the landside model for internal analysis of their systems.

Agreed.

PVSC Long Term Control Plan Team
March 7, 2016
Page 6

Item 12 Discussion

DEP (Marco Alebus): Although the model encompasses the core area of NY/NJ Harbor, the focus of the model calibration/validation should be on New Jersey waters. In addition, given the uncertainty in quantifying the loadings from NYC, detailed calibration of the model in open waters is not a primary objective of this effort. Thus, event sampling at these stations, although useful for the overall model, may not be critical to demonstrating model fitness in most NJ waters. For the purpose of establishing a baseline condition, does NYC sample at or near these locations? Station B28 is located along the shipping channel. Given that this is also an event sampling station, please explain how the sampling location will not jeopardize obtaining the required number of samples during an event sampling.

SJL (Sheldon Lipke Environmental Consultants): Please further explain the MEG's rationale for the additional sampling sites. It would be useful to know why the MEG chose the Governors Island and Statue of Liberty sites, which are relatively close to each other, and the B21 site, which is on the same confined waterbody (the Narrows) as B21A and B21B.

NYC sampling locations are not close to the additional stations suggested by the MEG. We don't see shipping interfering with sampling as an issue; we can move out of the way if a ship is coming by. We only need to be on station for 10 to 15 minutes to collect samples and make measurements.

Background information questions from MEG

Timothy J. Groninger from HDR is identified as Project Manager, but was not at the meeting, while Bill Leo, also from HDR, is not mentioned in the QAPP but participated in the meeting. Please clarify.

The project's consultant team consists of Greeley and Hansen, CDM Smith, and HDR. Greeley and Hansen is the contractual lead and responsible for landside analysis. CDM Smith is the program manager and coordinates modeling efforts. HDR is responsible for water quality sampling and receiving water analysis. Tim Groninger is HDR's project manager; Bill Leo is a senior vice president at HDR with extensive knowledge of the firm's previous work.

Why are pathogens in the receiving waters the emphasis of the study? We understand it is for an NPDES permit, but for what water quality standard? Fishable-swimmable or water contact locally (harbor areas)? Water contact at distant beaches? Shellfish? Is there a TMDL or other standard to be met?

Pathogens have been defined by NJ DEP as the water quality constituent of concern for the LTCP. There is no approved pathogen TMDL. Pathogen water quality standards will be existing NJ DEP standards. In the area of interest, the majority of the waters are secondary contact waters, but the region does contain primary contact waters in areas away from the CSOs. Beaches and shellfish areas also exist within the Harbor but they are in Raritan Bay and are far from any NJ CSOs.

PVSC Long Term Control Plan Team
March 7, 2016
Page 7

In SSCWP QAPP PART 1.pdf, pp. 57-58, there is a memo from HDR “Modeled CSOs vs. Rainfall.” The figures are examples of common rainfall frequency analyses in which it is demonstrated that small storms (by depth) occur much more frequently and contribute more to total annual rainfall depth than do big storms. How was a storm event defined? Event definition is typically done by specifying a minimum inter-event time (MIT, hours) between “independent” events. MIT can be determined probabilistically, although it seldom is. Instead, a number like 6 hours is often used. MIT definition influences the plots and thus the conclusions drawn from the plots. How was an event defined?

The minimum inter-event time was defined as 4 hours in the analyses noted. However, for the purpose of the LTCP, analyses will be continuous simulations using 15 minute to one hour time steps (yet to be determined). In continuous simulation modeling, MIT does not have to be defined.



Long Term Control Plan



MEG Meeting
February 5, 2016 9:00 A.M. - 3:00 P.M.
PVSC WWTP, OEM Main Conference Room

| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|---|-----------------------|--|----------------|--|
| 1 | Bridget McKenna | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 817-5976 | bmckenna@pvsc.nj.gov |
| 2 | Marques Eley | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 466-2969 | meley@pvsc.nj.gov |
| 3 | Michael Witt | Chasan Leyner & Lamparello 300 Harmon Meadow Blvd. Secaucus, NJ 07094 | (201) 809-6039 | mwitt@chasanlwy.com |
| 4 | Sheldon Lipke | SJL Environmental Con. 32 Tanglewood Drive Livingston, NJ 07039 | (201) 532-1715 | slipke@SJLConsultants.com |
| 5 | Michael Hope | Greeley and Hansen 1700 Market Street Philadelphia, PA 19103 | (215) 553-7917 | mhcope@greeley-hansen.com |
| 6 | Timothy Dupuis | CDM Smith 111 Founders Plaza East Hartford, CT 06108 | (860) 808-2269 | dupuis@cdmsmith.com |
| 7 | Stephen Ertman | HDR 4 International Blvd Suite 100 Mahwah, NJ 07430 | (201) 335-9359 | stephen.ertman@hdrinc.com |
| 8 | William Du Jardin | HDR 4 International Blvd Suite 1000 Mahwah, NJ 07430 | 201.335.9301 | wdujardin@hdrinc.com |

Charlie Dupardin

GLEC

dupardin@aol.com

PASSAIC VALLEY SEWERAGE COMMISSION

June 2018 (Revised 03/28/19)
Page 321 of 796

| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|----|---|--|--------------|---------------------------------|
| 9 | <i>Michael Heinen</i> Signature MICHAEL HEINERAW Print | CDM SMITH 75 STATE STREET BOSTON MA 02109 | 617 452 6359 | HEINERAWMC@ CDMSMITH.COM |
| 10 | <i>Steve Chapra</i> Signature STEVE CHAPRA Print | TUFTS UNIV Medford, MA | 617 627 3654 | steven.chapra @tufts.edu |
| 11 | <i>Wayne Huber</i> Signature Wayne Huber Print | 2972 NW 132 AVE Portland, OR 97229 OR ST - FORTUNE | 503 716 8330 | Wayne.Huber @orst.edu |
| 12 | <i>Alan Blumberg</i> Signature ALAN BLUMBERG Print | Stevens Inst of Tech Castle Pt on Hudson Hoboken, NJ 07030 | 201-216-5289 | ablumberg@ stevens.edu |
| 13 | <i>Sheldon Lipka</i> Signature Sheldon Lipka Print | SFL Consultants | 21 532 1715 | slipka@slconsulting .com |
| 14 | <i>Francisco Brillante</i> Signature Francisco Brillante Print | HDR Mahwah NJ | 201 335 9339 | f.brillan@HDRINC.COM |
| 15 | <i>Richard Isleib</i> Signature Richard Isleib Print | HDR Mahwah NJ | 201-335-9878 | richard.isleib@ hdrinc.com |
| 16 | <i>Nicholas Kim</i> Signature NICHOLAS KIM Print | HDR Mahwah NJ | 201-335-9300 | Nicholas.Kim@hdrinc. com |
| 17 | <i>Marco Alebus</i> Signature Marco Alebus Print | NJ DEP | 609 292-1930 | MARCO.ALEBUS@dep.nj.gov |
| 18 | <i>Chang Wu</i> Signature Chang Wu Print | NJ DEP | 609 777 4297 | Chang.Wu@dep.nj.gov |
| 19 | <i>Susan Rosawinkel</i> Signature Susan Rosawinkel Print | NJ DEP | 609 292 4860 | susan.rosawinkel@ dep.nj.gov |

Meeting Summary

PVSC Model Evaluation Group (MEG)

Session 2

March 17, 2017

Stevens Institute of Technology

Attendees: See Sign-In Sheet

Introduction

The PVSC Long Term Control Plan (LTCP) Model Evaluation Group (MEG) held their second meeting at Stevens Institute of Technology on March 17, 2017. Greeley and Hansen, CDM Smith, and HDR presented status updates on the progress of the monitoring and modeling programs being performed for the PVSC Long-Term Control Plan project. The following is a summary of the meeting topics and discussions.

Opening Remarks

- Dr. Alan Blumberg welcomed the members of the MEG, PVSC, NJDEP, the engineering consultants, and other observers to Stevens Institute of Technology.
- The meeting attendees introduced themselves and their affiliation with the project
- Mike Hope provided an overview of the program status:
 - All the NJPDES QAPPS have been submitted to NJDEP and approved by NJDEP
 - The 12-week temporary flow monitoring program is complete
 - The water quality sampling programs are approximately 90% complete
 - The wet-weather sampling program is slightly behind schedule due to the lack of rainfall in 2016.

Flow Monitoring Program – Presented by Yuan Fang

- Yuan Fang provided an overview of the temporary flow monitoring program:
 - 21 temporary flow meters were in place from April 2016 through August 2016
 - 13 of the meters are monitoring flow in an outfall
 - 7 of the meters are monitoring flow in a regulator influent
 - 1 of the meters is monitoring flow on the interceptor (Paterson)

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- The flow monitoring data was analyzed to determine the period when close to all of the meters appear to be functioning properly so that model calibration events can be identified. The period between May 15th and August 5th.
- Yuan Fang provided an overview of the PVSC permanent flow meter locations.
- Yuan Fang provided an overview of available precipitation records for the proposed model calibration periods:
 - Sub-hourly data is available from Newark Airport, but there is a deficit in the total volume recorded in June 2017 as compared with the hourly and daily data.
 - Bridget McKenna stated that PVSC has a rain gage that might be able to supplement the missing airport information.
 - Tim Dupuis stated that we can also supplement the data by disaggregating the hourly data from the airport.

Water Quality Monitoring Program – Presented by Tim Groninger

- Tim Groninger provided an overview of the sampling programs:
 - The Routine Sampling program is 95% complete and is on schedule.
 - The Intensive Sampling program is 72% complete and is on schedule. One more boat intensive survey remains.
 - The System Characterization Stormwater Sampling program is 79% complete and is nearly on schedule.
 - The System Characterization CSO Sampling program is 12% complete and is behind schedule due to a lack of precipitation in 2016.
- Marco Alebus asked the MEG whether they felt it was critical to complete the CSO sampling program, since they aren't going to be used directly by the models. The models will be applying concentrations based upon the relative mix of stormwater and sanitary flow in the overflow, as predicted by the model.
 - Dr. Wayne Huber responded that the CSO sampling is important since the CSO load will be the largest bacterial source to the receiving waters.
- Tim Groninger presented a summary of the sample data quality, based on the number of laboratory qualified and estimated values:
 - Tim Groninger explained that the laboratory reports estimated values if the bacterial plate count is outside of the range of 20-60 colonies. The laboratory did provide the actual plate count with the sample data if the value was estimated due to being outside of this range.
 - Marco Alebus asked how the estimated values will be used:
 - Tim Groninger responded that we plan to utilize the qualified data for the model calibration, and note the qualifications.
 - Tim Dupuis stated that this is an area where we would like to receive input from the MEG.
 - Dr. Steven Chapra stated that he doesn't have concerns with utilizing the qualified data.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- Biswarup Guha requested additional information on the upper quantification limit. He suggested that the upper quantification limit be included when reporting the data.
- Marco Alebus asked whether a site-specific correlation can be established between the bacteria indicators, and if it could be used to help evaluate the estimated values.
 - Tim Groninger replied that it is something that would be looked at.

Typical Year – Presented by Mike Hope

- Mike Hope presented the selection criteria utilized for identifying a “typical year”.
 - The method is a statistical approach based on multiple rainfall (Newark Airport) and river flow (Passaic River) criteria
 - This method has been used and accepted elsewhere by USEPA
 - Based on the applied ranking methodology, 2004 was ranked #1
 - 2008, the NYC typical year, was ranked as #8
 - New York City utilizes the rain gage at JFK Airport
 - The model was simulated for 20 years to evaluate the relative annual overflow volumes and number of events:
 - 2004 is approximately 1.5% over the average overflow volume, and 6.7% over the average number of overflow events.
 - Selecting a year other than 2008 will require additional coordination with NYC, but this additional coordination has been discussed with NYC and NYC seems to be willing to provide the required model outputs. In turn, PVSC will provide the required model outputs for 2008 to facilitate NYC’s LTCP program.
- Biswarup Guha asked whether New York City utilized a similar method for selecting their typical year:
 - Tim Groninger responded that the New York City analysis utilized the same methodology that was previously used to select the JFK 1988 typical year. This included five unweighted statistics at JFK Airport, Newark Airport, LaGuardia Airport, and Central Park.
 - Dr. Steve Chapra suggested that the JFK data be run through the PVSC typical year selection criteria weight to see how 2008 ranks.
- Marco Alebus stated that the perception at NJDEP may be that 2008 is less stringent than the prior typical year (JFK 1988).
- Marco Alebus stated that USEPA may want to utilize 2008 anyway to be consistent with the shared waters.
- Biswarup Guha stated that intensity is critical for selecting critical year:
 - Biswarup Guha requested that a chart or figure be developed showing intensities for each year.
 - Biswarup Guha requested that temporal plots of the actual rainfall be developed for records from Newark Airport and other gages, including JFK Airport.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- Tim Dupuis stated that the number of back to back rainfall events is one of the critical parameters, and that 2008 was well above the annual average in the number of back to back events. The number of back to back events will impact the effectiveness of green infrastructure in reducing CSO impacts since the capacity will not have time to recover between storms.
 - Biswarup Guha requested a graphical representation on the number of back to back events
- Biswarup Guha stated that updated standards that introduce a Statistical Threshold Value (STV) are being developed for SE1 waters.
 - EPA is also pushing to upgrade the downgraded waters as well.
 - This won't happen before the LTCP plan is done
 - New York City has updated their LTCPs based on the new standards, and upgraded some of the shared waters to primary contact.
- Susan Rosenwinkel suggested that an official approval of the typical year report would be useful.
 - Mike Hope agreed, and asked whether the comparison of 2004 and 2008 should be included.
 - Dr. Steve Chapra stated that the analysis should be done for a range of years, but the comparison of 2004 and 2008 shouldn't be presented.
 - Susan Rosenwinkel suggested that a narrative be included on why the New York City typical year wasn't used by default.
 - Tim Dupuis stated that the planned approach was to submit a document to NJDEP for approval.
- Biswarup Guha requested that a comparison between the PVSC rain gage and the Newark Airport rain gage be performed.
- Nicholas Kim suggested that the Lodi/Saddle River streamflow gage may be more appropriate to look at in comparison to rainfall instead of the Passaic River.
- Marco Alebus requested that timeseries plots of river flow be developed for 2004 and 2008.
- Marques Eley stated that the September 8, 2008 storm was Hurricane Hannah, which was nearly 8". The National Weather Service said that 2008 was one of the driest years on record at that time, prior to that storm.

Regional Drainage Model – Presented by Mitch Heineman

- Mitch Heineman explained that that Regional Drainage Model is needed to simulate continuous flows and loads from the drainage areas not included in the CSO areas.
 - Stream flow records from 7 USGS gages were loaded directly into the model to account for flows from areas upstream of those gages.
 - Rainfall-runoff was simulated in areas downstream of those 7 USGS gages utilizing the SWMM non-linear reservoir method in InfoWorks.
 - Several downstream USGS gages were used for model calibration.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Hydrologic and Hydraulic Model – Presented by Yuan Fang

- Yuan Fang provided an update on the hydrologic and hydraulic model development.
 - The PVSC, Bayonne, and North Bergen models have been combined into a single integrated model.
 - A simplified Jersey City model was developed to convey flows from North Bergen and to account for the Jersey City flows.
 - Tim Dupuis informed the group that another consultant is working on the Jersey City modeling, and that the PVSC consulting team coordinates with them.
 - Regulator settings were checked and updated.
 - Delineations were updated, particularly in Paterson.
 - Susan Rosenwinkel asked whether Paterson Outfall O-28 is included in the model as a CSO. NJDEP recently confirmed that it is a CSO.
 - Yuan Fang replied that it is being modeled as a CSO.
 - Separately sewered areas were added to the model.
 - Wet-weather operating rules were added at the Newark CSO regulators and the primary storage tanks at PVSC.
- Wet weather calibration events have been identified as:
 - 5/29/16-5/30/16
 - 7/25/16
 - 7/29/16-8/1/16 (back to back storm at 7/29/16 and 7/31/16)
- Biswarup Guha asked whether in-pipe sedimentation is being considered.
 - Yuan Fang responded that sedimentation is not being included in the model.
 - Tim Dupuis stated that CDM Smith is inspecting the PVSC lines as part of another contract and that the information will be provided to the LTCP modeling team as it becomes available.

Hydrodynamic Model – Presented by Nicholas Kim

- Nicholas Kim provided an overview of the hydrodynamic receiving water model.
 - The model calibration period is 2009-2016.
 - The model calibration involves: elevation; currents; temperature; salinity
 - Tidal marsh area was added to account for the required storage volume of the large tidal flux.
 - An overview of the modified grid mesh was shown.
- Marco Alebus asked how “Dundee Lake”, the water behind Dundee Dam, was handled in the model.
 - Nicholas Kim responded that the flow recorded at the USGS Little Falls gage is discharged over Dundee Dam.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- Dr. Alan Blumberg asked about bathymetry, and how the dredging program has been accounted for.
 - Nicholas Kim responded that approximately 90% of the dredging program was complete by 2009 and 2010. It was assumed that the dredging project was complete for the calibration period.
- Nicholas Kim presented model calibration timeseries plots of tide data, temperature, and salinity.
 - Dr. Alan Blumberg asked whether the model calibration will be evaluated in any sort of statistical manner.
 - Nicholas Kim stated that will be done and included in the report.
 - Marco Alebus requested that a statistical means for quantifying the error in the calibration be included.
- Biswarup Guha stated that BCUA collected salinity data that might be useful.
 - Bridget McKenna stated that BCUA is a participant on this project and she will request the data from BCUA.

Water Quality Modeling – Presented by Richard Isleib

- Richard Isleib provided a summary of the receiving water quality data collected between April 2016 and early January 2017.
 - The stormwater sampling results for the Hawthorne low density residential and Paterson commercial/industrial sampling locations are unexpectedly high. Additional investigation on these locations may be required.
 - Dr. Wayne Huber asked whether the industrial and commercial stormwater sampling locations are representative of the all industrial and commercial land uses.
 - Marques Eley stated that the Paterson Commercial/Industrial site may be near a slaughter house in Paterson.
- Dr. Steven Chapra suggested that light be included as a modeling parameter.
- Charlie Dujardins suggested that some of the remaining CSO sampling effort be diverted towards additional stormwater sampling.

Closing Remarks

- The group discussed a schedule for the next MEG meeting(s).
 - Dr. Steven Chapra requests that any information on the receiving water quality model be sent in advance of the next MEG meeting so that the MEG has time to review.
 - Tim Dupuis suggested that two more MEG meetings be held; one prior to the receiving water quality model validation and one afterwards.
 - Biswarup Guha requested that materials be shared with NJDEP ahead of the next meeting.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- The group decided that the next meeting will be targeted for August 2017.

Attachments

- Agenda
- Sign-in sheet

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.














Long Term Control Plan

Modeling Evaluation Group - Session 2
March 17, 2017, 9:00 A.M. - 3:00 P.M.
Stevens Institute of Technology, Babbio Center, 5th Floor






| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|---|------------------------|--|----------------|--|
| 1 | Bridget McKenna | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 817-5976 | bmckenna@pvsc.nj.gov |
| 2 | Marques Eley | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 466-2969 | meley@pvsc.nj.gov |
| 3 | Michael Witt | Chasan Leyner & Lamparello 300 Harmon Meadow Blvd, Secaucus, NJ 07094 | (201) 809-6039 | mwitt@chasanlaw.com |
| 4 | Sheldon Lipke | SJL Environmental Con. 32 Tanglewood Drive Livingston, NJ 07039 | (201) 532-1715 | slipke@SJL-Consultants.com |
| 5 | Michael Hope | Greeley and Hansen 1700 Market Street Philadelphia, PA 19103 | (215) 553-7917 | mhope@greeley-hansen.com |
| 6 | Clifford Pomerantz | Greeley and Hansen 111 Broadway New York, NY 10006 | (212) 227-1250 | cpomerantz@greeley-hansen.com |
| 7 | Timothy Dupuis | CDM Smith 111 Founders Plaza East Hartford, CT 06108 | (860) 808-2269 | tdupuis@cdmsmith.com |
| 8 | David Ksnyiak | CDM Smith 110 Fiedcrest Ave; 6th Fl. Edison, NJ 08837 | (732) 590-4686 | dkksnyiak@cdmsmith.com |

June 2018 (Revised 03/28/19)
Page 330 of 796

PASSAIC VALLEY SEWERAGE COMMISSION

| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|----|---|---|--|----------------------------------|
| 9 |  MITCH HEINEMAN | COM SMITH 75 STATE ST BOSTON MA 02109 | Phone 617 452 8357 Fax | HEINEMANM@ COMSMITH.COM |
| 10 |  Corey Aren | NJDEP 401 E. State St. Trenton, NJ | Phone 609 633 7021 Fax | Steven.aren@ dep.nj.gov |
| 11 |  Fitas Saleh | STEVENS 1101 1 Cosmic Point | Phone 912-834-4680 Fax | F.Saleh@stevens. edu |
| 12 |  Cismarup (Arap) Gibbs | NJDEP Trenton | Phone 609 292 1572 Fax | bismarup.gibbs@ dep.nj.gov |
| 13 |  LIN LIANG | Giedeg-Hansen Richmond, VA | Phone 804-977-7256 Fax | liang@giedeg-hansen. com |
| 14 |  Wayne Huber | ORSK - everetts portland OR | Phone 541 231 3944 Fax | Wayne.huber@ orit.edu |
| 15 |  ALAN BLUMBERG | Stevens Inst | Phone 201-216-5259 Fax | alblumberg@ stevens.edu |
| 16 |  NICHOLAS KIM | HDR Inc Morristown NJ | Phone Fax | Nicholas.Kim@HDRINC. com |
| 17 |  STEVE CHAPRA | TUFTS MEDFORD, MA | Phone 617 627 3654 Fax 617 627 3994 | steven.chapra@ tufts.edu |
| 18 |  Susan Rosenwinkol | NJDEP Trenton, NJ | Phone 609 292 4860 Fax | Susan.rosenwinkol@ dep.nj.gov |
| 19 |  Teresa Guloy | NJDEP Trenton NJ | Phone 609 292 4860 Fax | teresa.guloy@ dep.nj.gov |

PASSAIC VALLEY SEWERAGE COMMISSION

| # | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|----|--|--|---------------------|---------------------------------|
| 20 | Signature:  Print: Marco Melaris | Name: NJ DEP Address: Trenton NJ | Phone: 609 292-1935 | MAELARIS, MARCO dep.nj.gov |
| 21 | Signature:  Print: Charles DORANOV | Name: GCISE Address: | Phone: 201-259-7566 | DORANOV @ aol.com |
| 22 | Signature:  Print: Richard Isleib | Name: HDR Address: | Phone: 973-359-9978 | richard.isleib@ hdrinc.com |
| 23 | Signature:  Print: Tim | Name: HDR Address: 711 Woodchester Av White Plains, NY | Phone: 914-993-2098 | Timothy Groinger @hdrinc.com |
| 24 | Signature:  Print: Yifang | Name: Greeley and Hansen Address: Richmond, VA | Phone: 804-204-2412 | yifang@greeley- hansen.com |
| 25 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 26 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 27 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 28 | Signature: Print: | Name: Address: | Phone: Fax: | |

I:\07128 01 PVSC\CPSC General Communications\09-01 Reg Communications\09-01-01 (New) Reg\09-01-01-01 Agency\04-11-2017\003 Sheet 3 of 3 (2017-03) (1) Sign-In Sheet\02\09-01-01-01

Meeting Summary

PVSC Model Evaluation Group (MEG)

Session 3

September 15, 2017

Stevens Institute of Technology

Attendees: See Sign-In Sheet

Introduction

The PVSC Long Term Control Plan (LTCP) Model Evaluation Group (MEG) held their third meeting at Stevens Institute of Technology on September 15, 2017. Greeley and Hansen, CDM Smith, and HDR presented status updates on the progress of the monitoring and modeling programs being performed for the PVSC Long-Term Control Plan project. The following is a summary of the meeting topics and discussions.

Opening Remarks

- The meeting attendees introduced themselves and their affiliation with the project
- Mike Hope provided an overview of the program status:
 - The program is in the System Characterization Phase.
 - The collection system model calibration is almost complete.
 - The water quality sampling program is complete with the exception of the CSO sampling program.

Water Quality Monitoring and Modeling Program Overview – Presented by Richard Isleib

- Surface water quality sampling program:
 - There are 72 surface water monitoring locations.
 - The applicable water quality standards and waterbody classifications were reviewed.
 - There are locations upstream of the CSOs where the sample results approach or exceed the single sample maximum.
 - The Second River shows some of the highest bacteria concentrations.
 - Sheldon Lipke states that prior investigations on the Second River have shown that both dry and wet weather concentrations can be out of compliance.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- The Elizabeth River also shows high bacteria concentrations.
- Dr. Blumberg requests that maps of the sample locations be added to the sample results slides in future presentations.
- Tim Groninger stated that the surface water sample data scatter plots will be distributed to the NJ CSO Group along with a memorandum explaining the sampling program and results.
- Sheldon Lipke asked that Richard Isleib email him the figures shown in the presentation.
- Sheldon Lipke suggested that distinguishing between dry-weather and wet-weather samples on the plots may be useful.
- Richard Isleib asked NJDEP whether the State was considering upgrading any of the waterbodies.
 - Biswarup Guha stated that EPA wants the States to update their standards for primary contact waterbodies.
 - For SE1 and SC waters, NJDEP is going to update the criteria to match the EPA standards
 - For downgraded waters, NJDEP might consider the results of the LTCPs to determine whether to modify the standards.
- Stormwater sampling program:
 - There are 8 stormwater sampling locations.
 - There are 18 CSO sampling locations.
 - The stormwater sampling program is complete.
 - The stormwater sampling results were compared with tributary area land use, but definitive distinctions were not found. Therefore, a single stormwater concentration will be utilized.
 - Richard Isleib explained the mass balance approach for to determine the fraction of sanitary and stormwater flow in the overflow using a tracer, and calculating the overflow concentrations based on the percentage of each in the overflow.
- CSO sampling program:
 - Mike Hope stated that the CSO sampling program is the only portion of the overall sampling program that is not yet complete.
 - To date 18 CSO sampling events have been completed, which is 1/3rd of the CSO Sampling Program. 36 additional sampling events are required.
 - 10 of the 18 sampling stations have been sampled at least once.
 - Weather conditions have been a challenge
 - Continuing the current course of the CSO sampling program will negatively impact of the schedule for completing the System Characterization Report.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- We are considering collecting additional stormwater sample data in lieu of collecting additional CSO sample.
 - Charlie Dujardins asked whether a difference in CSO concentration was found from location to location, or based on tributary area land use.
 - Richard Isleib stated that there is variability between locations, but there is also variability at the same station when it has been sampled multiple times.
 - Dr. Steven Chapra asked whether the CSO sample concentrations have been normalized to something like the size of the tributary area.
 - Richard Isleib responded that the data was no normalized to the area, but that is something that we can look at.
 - Susan Rosenwinkel stated that NJDEP would like to see all of the data before making a decision to allow a change to the sampling program.
 - Richard Isleib that the results of the InfoWorks model would be used to evaluate how well the model is predicting the existing CSO sample dataset, and then a decision can be made about whether additional CSO sampling data would be required.
 - Marco Alebus asked that a comparison of the results predicted by the model against the data collected be sent.
- Dry and Wet Weather Loads to the Receiving Water Model:
 - Richard Isleib explained the proposed Monte-Carlo regression of using dry weather river flow and bacteria concentration.
 - Dr. Steven Chapra suggested that the actual data be used instead of assuming a geometric distribution for sites with many observations.
 - Richard Isleib explained an approach using a linear regression of concentration vs. precipitation for events above 0.2” to determine a concentration to add to the dry weather concentrations.
 - Dr. Steven Chapra suggested that the slope of the regression be tested to determine whether it is statistically significant, or whether a constant wet weather concentration should be used instead.
 - Dr. Wayne Huber agrees that the significance of the regression slope needs to be confirmed.
 - Richard Isleib stated that the load from the upstream Hudson River will be applied just upstream of the area of interest, instead of trying to model the loads from Albany down to the area of interest.
 - The MEG agrees that this approach is reasonable.
 - Richard Isleib explained the pathogen model kinetics.
 - Dr. Chapra suggests that HDR’s knowledge on NYC and available local data be used to determine the loss rate.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- Dr. Chapra also suggests that the settling velocity can be used as a calibration knob.

Collection System Model Calibration Results – Presented by Yuan Fang

- Yuan Fang provided an overview of the collection system model and the individual CSO communities.
- The group discussed the impacts of not having the detailed Jersey City collection system model in the regional InfoWorks model.
 - Yuan Fang explained that the Jersey City collection system is currently represented as a simplified system.
 - Jersey City is performing their own modeling independently.
 - Bridget McKenna stated that PVSC has requested the Jersey City model, but it hasn't been received yet.
 - Mitch Heineman stated that we currently have a reasonably working model to simulate the flows, but not the detailed model.
- Yuan Fang presented timeseries and scatter plots showing how the collection system model flow predictions compare with the monitored flow data.
 - The model performs best on the interceptor and trunk sewer meters.

Final Discussion

- The group discussed holding another MEG meeting prior to final calibration of the receiving water quality model, most likely in the first quarter of 2018.
- The group discussed the overall project schedule.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Long Term Control Plan

Modeling Evaluation Group - Session 3
September 15, 2017, 9:00 A.M. - 3:00 P.M.
Stevens Institute of Technology, Babbio Center, 5th Floor



| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|---|------------------------|--|----------------|--|
| 1 | Bridget McKenna | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 817-5976 | bmckenna@pvsc.nj.gov |
| 2 | Marques Eley | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 466-2969 | meley@pvsc.nj.gov |
| 3 | Michael Witt | Chasan Leyner & Lamparello 300 Harmon Meadow Blvd. Secaucus, NJ 07094 | (201) 809-6039 | mwitt@chasanlaw.com |
| 4 | Sheldon Lipke | SJL Environmental Con, 32 Tanglewood Drive Livingston, NJ 07039 | (201) 532-1715 | slipke@SJLConsultants.com |
| 5 | Michael Hope | Greeley and Hansen 1700 Market Street Philadelphia, PA 19103 | (215) 553-7917 | mhope@greeley-hansen.com |
| 6 | Clifford Pomerantz | Greeley and Hansen 111 Broadway New York, NY 10006 | (212) 227-1250 | cpomerantz@greeley-hansen.com |
| 7 | Timothy Dupuis | CDM Smith 111 Founders Plaza East Hartford, CT 06108 | (860) 808-2269 | tdupuis@cdmsmith.com |
| 8 | David Ksyaniak | CDM Smith 110 Fiedcrest Ave, 6th Fl, Edison, NJ 08837 | (732) 590-4686 | dksyaniak@cdmsmith.com |

June 2018 (Revised 03/28/19)
PASSAIC VALLEY SEWERAGE COMMISSION
 Page 337 of 796

| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|----|--|--|--|----------------------------------|
| 9 | Signature: Print: MITCH WEINTRAUB | Name: CDM SMITH Address: 75 STATE ST. BOSTON MA | Phone: 617 452 6357 Fax: | HEINEMANME@ CDMSMITH.COM |
| 10 | Signature: Print: CHARLES OUZARONS | Name: PLIC Address: | Phone: 201-259-7560 Fax: | OUZARONS@APL.COM |
| 11 | Signature: Print: ALAN F. BLUMBERG | Name: Address: | Phone: Fax: | |
| 12 | Signature: Print: Richard Istaitieh | Name: HDR Address: | Phone: 201-355-9378 Fax: | richard.istaitieh@ hdrinc.com |
| 13 | Signature: Print: Steven Anen | Name: NJ DEP - DWG Address: | Phone: 201 633 7021 Fax: | Steven.anen@ dep.nj.gov |
| 14 | Signature: Print: Susan Rosewinski | Name: NJ DEP - DWG Address: | Phone: 609 292 4860 Fax: | susan.rosewinski@ dep.nj.gov |
| 15 | Signature: Print: Marco Alebus | Name: NJ DEP - DWG Address: | Phone: 609 292 4860 Fax: | marco.alebus@ dep.nj.gov |
| 16 | Signature: Print: STEVE CHAPKA | Name: TUFTS Address: MEDFORD, MA | Phone: 617 627 3654 Fax: 617 627 3994 | steven.chapka@ tufts.edu |
| 17 | Signature: Print: Helen Pang | Name: NJ DEP Address: DWMS | Phone: 609-292-7760 Fax: | helen.pang@ dep.nj.gov |
| 18 | Signature: Print: YUAN FANG | Name: Greeley and House Address: | Phone: 800-206-2412 Fax: | yfang@greeley-house. com |
| 19 | Signature: Print: BISWAJIT GHATA | Name: NJ DEP Address: DWMS | Phone: 609 292 1592 Fax: | biswajit.ghata@ dep.nj.gov |

June 2018 (Revised 03/28/19)
Page 338 of 796

PASSAIC VALLEY SEWERAGE COMMISSION

| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|----|--|--|-----------------------------|--------------------------------|
| 20 | Signature:  Print: Lisa Liang | Name: Corvelog and Hansen Address: Richmond, VA | Phone: 904-204-2433 Fax: | Liang @ corvelog-hansen.com |
| 21 | Signature:  Print: TIM GROVINGER | Name: HDR Address: White Plains, NY | Phone: 914-993-2098 Fax: | timothy.grovinger@ ch2m.com |
| 22 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 23 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 24 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 25 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 26 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 27 | Signature: Print: | Name: Address: | Phone: Fax: | |
| 28 | Signature: Print: | Name: Address: | Phone: Fax: | |

\\pvc\dfs\01_PVSC\1\Tech\General Commission\MS3\01_Mtg Documents\MS3\01_01_Clarifier_Mtg\01_01_01_Agenda\Attachments\15_2017\MS3_2017\15_28\01_01_15_Sign-in Sheet_01_01_15.docx

Meeting Summary

PVSC Model Evaluation Group (MEG)

Session 4

December 5, 2018

Location: CDM Smith Edison, NJ Office

Attendees: See Sign-In Sheet

Introduction

The PVSC Long Term Control Plan (LTCP) Model Evaluation Group (MEG) held its fourth meeting on December 5, 2018. Greeley and Hansen and HDR presented status updates of the monitoring and modeling programs being performed for the PVSC Long-Term Control Plan project. This memorandum summarizes the meeting topics and discussion.

Opening Remarks

- Meeting attendees introduced themselves and their affiliation with the project
- Michael Hope provided an overview of the program status and schedule.
- Mr. Hope requested that the MEG provide a memorandum summarizing their participation in the project and their conclusions.
 - Susan Rosenwinkel agreed that this would be useful. She suggested the memo include an introduction with MEG meeting dates, background on the members, and conclusions.

Hydrologic and Hydraulic Model Overview – Presented by Dr. Yuan Fang

- Dr. Fang provided an overview of the collection system model and the individual CSO communities. She described wet weather operating rules implemented in the model, which include utilizing primary clarifier storage and closing regulator gates when influent flow rate to PVSC from the west exceeds 350 mgd.
 - Marques Eley confirmed that the rules implemented in the model match current standard operating procedures.
- Dr. Fang presented model calibration and validation results
 - Dr. Steven Chapra suggested that the flow monitoring data should be adjusted to eliminate questionable spikes, and then the calibration plots should be updated.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- Dr. Alan Blumberg suggested that performance statistics, such as root mean square error, should be included.
- Dr. Blumberg requested that monitored vs. modeled scatter plots be developed which show all metered events at all locations; the group agreed that these scatter plots would be useful in evaluating the calibration
- Marzooq (Marco) Alebus acknowledged that calibration was performed, but asked whether an independent validation was also performed using separate storm events.
 - Mitch Heineman responded that collection system models typically have limited data from which calibration and validation can be performed, so it is typical to perform a single calibration/validation.
 - Dr. Chapra stated that validation was performed since calibration results from the four events are based on a single set of model input parameters. Each event thus validates the others. Dr. Chapra stated that this is excellent engineering in terms of considering one's available data, and that he has confidence in the methodology; Charles DuJardin agreed with Dr. Chapra.
- NJDEP suggested that the System Characterization Report be retitled "Calibration/Validation", instead of "Calibration and Validation".
- The MEG requested that scatter plots with all the monitored vs. modeled results be developed, color coded by event.
- Susan Rosenwinkel stated that a 45-day extension would be granted for submission of the revised System Characterization Reports so that MEG comments could be addressed and incorporated.

Hydrodynamic Modeling – Presented by Nicholas Kim

- Mr. Kim provided an overview of the hydrodynamic model. He explained the model input parameters and model domain, and presented salinity and temperature calibration results at various monitoring locations within the model domain.
- Dr. Wayne Huber stated that the model results are generally in good agreement with the monitoring data.
- Mr. Alebus requested that all graphs be presented in the final report; Dr. Blumberg suggested that the main report should contain representative plots, with the remainder relegated to an appendix
- Rich Isleib stated that for the purposes of the water quality model, the hydrodynamics perform as required.
- Mr. DuJardin requested that some level of spatial plots be developed to show how salinity varies along the Hudson River, Passaic River, and Hackensack River.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Water Quality Modeling Update – Presented by Rich Isleib

- Mr. Isleib provided an overview of the receiving water quality model, beginning with model kinetics and pathogen sources.
- Mr. Isleib presented the monitored stormwater and sanitary bacteria concentrations obtained from the monitoring programs.
 - The results of the stormwater sampling program did not reveal a statistically significant difference in bacteria concentrations in runoff from different land use types. The variation within a land use type was as wide as the variation among land use types.
 - All the monitoring data was thus combined. Uniform fecal coliform (41,000 cfu/100 ml), enterococci (110,000 cfu/100 ml), and E. coli (38,000 cfu/100 ml) concentrations were applied to runoff regardless of land use type.
- Mr. Isleib explained that CSO loadings were determined based upon the fraction of sanitary and stormwater flows in the hydraulic models, multiplied by respective dry and wet weather concentrations. Calculated CSO concentrations were compared with monitored CSO concentrations and found to be in good agreement.
- Mr. Isleib presented the WWTP influent monitored pathogen concentrations.
 - Dr. Chapra asked about the seasonal pattern in bacteria concentration at the WWTP.
 - Mr. Isleib responded that it may be the result of dilution from I&I
- The group discussed the ratio of E. coli: enterococci in sanitary and stormwater data
- Mr. Isleib presented the methodology for assigning river boundary loads using a Monte Carlo approach for dry weather, and maximum likelihood estimation for wet weather.
 - The water quality monitoring data suggest the presence of additional dry-weather loads from sources other than those initially modeled.
 - To check the reasonability of the additional dry weather loads being input into the model, a “person-equivalent” approach was used assuming an average sanitary flow concentration and 150 gallons per day wastewater per capita.
 - The group discussed the person-equivalent approach.
 - Dr. Chapra suggested that it might be a good discussion for an appendix.
- Mr. Isleib presented WWTP, stormwater, baseflow, and Hudson River boundary loads that were applied to the model.
 - Mr. Alebus asked about using a WWTP effluent enterococci concentration of 100 cfu/100 ml even though WWTPs have limits of 35 cfu/100 ml.
 - Mr. Isleib responded that he didn’t think the WWTP concentration was that sensitive.
 - Ms. Rosenwinkel responded that she doesn’t believe the contributing WWTPs have enterococci limits.
 - Mr. Alebus suggested that an explanation of the 100 cfu/100 ml should be included in the report.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

- Mr. Isleib presented NJ pathogen criteria for primary and secondary contact recreation, followed by model calibration results.
 - Mr. Hope asked if Mr. Isleib's interpretation of evaluating geomean compliance with the model is to use a rolling 30-day geomean.
 - Mr. Isleib responded that this is his interpretation and explained how he performed those calculations.
 - Dr. Chapra asked what model adjustments had to be made for this study as compared to prior studies.
 - Mr. Isleib responds that the base die-off rate for fecal coliform was set to 0.2/day instead of 0.8/day and that temperature adjustments were also made
 - Dr. Chapra stated that in his opinion the model is the best that it can be given the state of knowledge.
 - Mr. DuJardin stated that he would like to see a calculated depth-average solar radiation decay rate in the Hudson River vs. the Passaic River, or other locations.
 - Dr. Huber asked that the report address the sensitivity analysis of all key parameters, not just the die-off coefficient.

Final Discussion

- Dr. Huber suggested that a sensitivity analysis be performed for each model.
- The MEG requested that one additional MEG meeting be held.
- Mr. Hope discussed the next steps
 - Possibly hold another MEG meeting
 - Memo from the MEG
- Dr. Blumberg stated that the System Characterization Report needs a conclusion on the model's performance.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Long Term Control Plan

Dec. Modeling Evaluation Group - Session 4
November 5, 2018, 10:00 A.M. - 3:00 P.M.
CDM Smith, 110 Fieldcrest Avenue, Edison, New Jersey 08837



| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|---|---------------------------------------|--|----------------|--|
| 1 | <i>[Signature]</i> Bridget McKenna | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 817-5976 | bmckenna@pvsc.nj.gov |
| 2 | <i>[Signature]</i> Marques Eley | PVSC 600 Wilson Avenue Newark, NJ 07105 | (973) 466-2989 | meley@pvsc.nj.gov |
| 3 | <i>[Signature]</i> Michael Witt | Chasan Leyner & Lamparello 300 Harmon Meadow Blvd. Secaucus, NJ 07094 | (201) 809-6039 | mwitt@chasanlaw.com |
| 4 | <i>[Signature]</i> Sheldon Lipke | SJL Environmental Con. 32 Tanglewood Drive Livingston, NJ 07039 | (201) 532-1715 | slipke@S.J.L.Consultants.com |
| 5 | <i>[Signature]</i> Michael Hope | Greeley and Hansen 1700 Market Street Philadelphia, PA 19103 | (215) 553-7917 | mhope@greeley-hansen.com |
| 6 | <i>[Signature]</i> Timothy Dupuis | CDM Smith 111 Founders Plaza East Hartford, CT 06108 | (860) 808-2269 | dupuis@cdmsmith.com |
| 7 | <i>[Signature]</i> David Ksyniak | CDM Smith 110 Fieldcrest Ave; 6th Fl. Edison, NJ 08837 | (732) 590-4686 | dksyniak@cdmsmith.com |
| 8 | <i>[Signature]</i> | CDM Smith | | dksyniak@cdmsmith.com |

PASSAIC VALLEY SEWERAGE COMMISSION

June 2018 (Revised 03/28/19)

Page 344 of 796

| | NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|----|---|--|---|-----------------------------|
| 9 | Signature: <i>Wynne Huber</i> Print: Wynne Huber | R.H. Name: 2007 NW 12th Ave Address: Fort Lauderdale, FL 33324 | Phone: 505.716.8330 Mobile: 561.421.8560 Fax: | Wynne.huber@pvc.org |
| 10 | Signature: <i>M. Heine</i> Print: MARY HEINEMAN | COM SMITH Address: BOSTON | Phone: 617.152.6359 Fax: | HEINEMANM@COMSMITH.COM |
| 11 | Signature: <i>L. Lyndon</i> Print: CHARLIE LYNDON | Name: G.L.L.C. Address: WICHUDDAN | Phone: 201-259-2500 Fax: | Quadrifonds@nbc.com |
| 12 | Signature: <i>M. Albus</i> Print: MARGO ALBUS | Name: NJDEP Address: | Phone: 609.292.4860 Fax: | MARZOCCHI.ALBUS@dep.nj.gov |
| 13 | Signature: <i>Susan Rosawinkel</i> Print: Susan Rosawinkel | Name: NJDEP Address: | Phone: 609.292.4860 Fax: | Susan.Rosawinkel@dep.nj.gov |
| 14 | Signature: <i>B. Bisconti</i> Print: BISCONTI BIANCA | Name: NJDEP Address: | Phone: 609.292.1572 Fax: | biscanti@dep.nj.gov |
| 15 | Signature: <i>Alan Blumberg</i> Print: BLUMBERG | Name: Address: | Phone: 201-835-6347 Fax: | alan@blumberggeneral.com |
| 16 | Signature: <i>S. Chapra</i> Print: CHAPRA | Name: Address: | Phone: 617.627.3654 Fax: | steven.chapra@tufts.edu |
| 17 | Signature: <i>Frank Klapinski</i> Print: Frank Klapinski | Name: NJDEP Address: | Phone: Fax: | |
| 18 | Signature: <i>Helen Pang</i> Print: Helen Pang | Name: NJDEP Address: | Phone: Fax: | |
| 19 | Signature: <i>Richard Isleib</i> Print: Richard Isleib | Name: HDR Address: | Phone: 201-335-9378 Fax: | richard.isleib@hdrinc.com |

| NAME | COMPANY/ADDRESS | PHONE/FAX | E-MAIL |
|------|-----------------|-----------|--------|
|------|-----------------|-----------|--------|

PASSAIC VALLEY SEWERAGE COMMISSION June 2018 (Revised 06/28/19)
Page 345 of 796

| | | | | |
|----|---|--|----------------------------|-------------------------------|
| 20 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 21 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 22 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 23 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 24 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 25 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 26 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 27 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |
| 28 | Name: <i>John J. Vico</i> Title: <i>John J. Vico</i> | Name: <i>John J. Vico</i> Address: <i>1700 Market St</i> <i>Paterson, NJ 07651</i> | Phone: <i>973-227-6426</i> | Email: <i>jjvico@pvsc.com</i> |

Passaic Valley Sewerage Commission, 1700 Market Street, Paterson, NJ 07651, 973-227-6426, www.pvsc.com

PVSC LTCP
Model Evaluation Group (MEG)
Memorandum dated February 15, 2019

Memo:

February 15, 2019

To: PVSC Consulting Team

From: PVSC MEG: Steve Chapra, Alan Blumberg, Wayne Huber

Re. Comments re. MEG4 meeting of December 5, 2018 and PVSC Characterization Report, revised as of January 19, 2019

Overall Summary

1. The MEG has enjoyed presentations on the overall approach to modeling and its support data for the PVSC Combined Sewer Overflow mitigation efforts for the past three years. We are in broad general agreement with the approach and techniques used for the development of modeling tools to address pathogen receiving water impacts of PVSC CSO discharges. We feel that the consulting Team's efforts have been well conceived and executed within practical limits of budget and technology. In particular, the H&H modeling is very extensive and well done. The MEG is in accord with the direction of the Team to date in developing tools to address PVSC mitigation strategies. The Team is "on track".

RESPONSE: Acknowledged.

2. The MEG is missing strategies and pathways leading to overall PVSC mitigation efforts, drawn from the modeling to date. We look for H&H modeling conclusions (such as discussed in our Addendum) related to CSO discharges and their impacts. We understand that there will be a sequence of reports dealing with important results such as receiving water impacts of mitigation strategies, e.g., time series and spatial distributions of pathogen concentrations in New Jersey and New York estuaries. We feel that it is incumbent on us to review and comment on results developed in the next phases of this project regarding the effectiveness and use of these strategies to reduce pathogen concentrations. Therefore, we strongly request another opportunity to evaluate these forthcoming efforts.

RESPONSE: Acknowledged.

Addendum: Comments related to detailed review of PVSC System Characterization Report, Revised 1/2/19. Specific report sections addressed are in response to direction from M. Hope and M. Finizio.

Most comments are editorial in nature. More significant comments:

Section E, comments 2, 3, 6.

Section I, comments 7, 8, 9, 10, 14, 15, 16, 19, 22, 23.

Section G, comment 2.

Section E Collection of Precipitation and Sewer Flow Monitoring Data

1. P. 87. Red revisions delete number of meters for each category. Flow meter locations are summarized in Table E.1. Are we losing any information that we need to know by losing the number in each category? Maybe not, in which case disregard this comment.

RESPONSE: The category for each meter is included in Table E-1. No information was lost.

2. A huge amount of data was recorded by hundreds of meters. Does the report highlight or give a sense of the relative percentage (or other metric) of regulator and outflow volume that was covered by flow monitoring relative the total CSO and PVSC discharges at the downstream end of its system during the time the monitors were active? The monitors include temporary ones here in Section E, and permanent ones. For example, can we say X % of regulator inflow (to the main trunk sewer) volume was measured? Or maybe a different perspective-type number would be the percentage of project cities' land area (or population or?) that was monitored for contributing inflows to the PVSC trunk and stormwater discharges?

RESPONSE: Temporary flow meters were installed at eleven (11) outfalls. Based on the results of the typical year model simulation, these 11 outfall locations discharge approximately 30% of the total annual CSO volume. Quantifying the percentage of the monitored regulator influent would be more difficult. However, large CSO drainage basins were targeted for the temporary flow metering.

3. Regarding missing temporary flow meter data (Figure E-2), was there ever a need to infill such data by other than the model that is not indicated in the reports?

RESPONSE: Figure E-2 in intended to show that all but two of the meters had available metering data from 5/20/2016 through 8/5/2016. That was the period that was selected for model calibration/validation. Records from the two meters located on the Newark 009/010 South and North outfalls were partially missing during this period. No infill of flow data was performed during this period.

4. Data and approaches to diurnal variations, peaking factors, screening of data – all seem good to me. A commendable and huge effort.

RESPONSE: Acknowledged.

5. Section E.7 Rainfall Frequency Analysis. In the big picture, precision on the return period of the selected calibration events probably doesn't matter. But we point out that intensity-duration-frequency curves (IDF curves), here represented by depth-duration-frequency curves, are not an appropriate way to estimate a return period for individual events. IDF curves are not based on independent events but from some d-hour duration segment of real storms, which may be much longer than for the data point used to construct the contours. Specifically, they represent conditional probabilities that a certain intensity will occur given a duration. The right way is to perform a conventional frequency analysis on the period of record from the gages that contains the candidate events (Table E-4). This would be performed on the long-term period of record for the various the rain gages, by separating the record into likely-independent events by the minimum interevent time chosen, here 6 hours, a common choice. For example, SWMM5 can perform this analysis; it isn't arduous. It may be that only the Newark Airport has a long enough record here, which is fine. Then the events of 2016 could be identified from this separation with their return period or exceedance frequency.

This all seems to have been done in Section H ! Could not the analysis look ahead to tables such as H-2 and do a better (as in more precise and theoretically justified) job of assigning return periods here?

Having said all this, it is still obvious from Figure E-9 that all the chosen events are of high frequency with low return periods. That is the main point of the discussion, and the data are well presented. This is not a “mission critical” analysis. Perhaps the report could include a brief insertion on p. 99: “Newark Airport rainfall was compared to the NOAA's Precipitation Frequency Table to *provide an approximate estimate of the return frequency of these events (Figure E-9).*”

RESPONSE: The suggested text has been inserted into Section E.7.

6. Re. Section E.7, has the report stated what time steps are used in the simulations? 15-min? We have very good quality (i.e., 5 to 15-min) rainfall data here.

RESPONSE: Precipitation is input at a 5-minute time step. This is first stated in Section I.3.1 of the Report and repeated in Section I.6. The model is run at a 1-minute time step and reported at a 5-minute time step.

7. Re. overall Section E, I believe we all understand the difficulty and expense of monitoring such a huge complex area and finding a group of monitored events that will serve for model calibration. We think the team has done a fine job here.

RESPONSE: Acknowledged.

Section I Hydrologic and Hydraulic Modeling

1. This review will focus on highlights and the H&H modeling presentations.

RESPONSE: Acknowledged.

2. The PVSC Interceptor Model covers a very large area of primarily old, established cities. Hence, assumptions about constant land use over time should be OK, maybe unless some huge new industrial or other development has occurred or will occur.

RESPONSE: Acknowledged.

3. Pp. 165 and nearby: text is understandable, but with some awkward grammar, e.g., “...is corresponded to...”

RESPONSE: The text was modified for grammar.

4. MEG comments and Table I-5 are discussed in a separate section below.

RESPONSE: Acknowledged.

5. Re. Section I.3, H&H Model Components and inputs, the MEG has enjoyed several presentations on this work. The amount of spatial detail is enormous (e.g., Section I.4), with thousands of SWMM subcatchment parameters provided. Having so much impervious area in the study area helps with parameter choices. Rainfall data are taken from the best available options. Newark Airport data are good for the long-term simulations.

RESPONSE: Acknowledged.

6. Hydraulic data for the combined sewers and regulators have been reviewed (P. 186) by the Team. We don't see how any better model representation could be constructed without unreasonable, large extra expense.

RESPONSE: Acknowledged.

7. At the MEG Session 1 (2/5/16, Table I-5) the MEG was assured that interceptor geometry was represented adequately. Does the Characterization Report mention what field surveys were conducted to ensure this? What is the range of dates for PVSC in-situ drawings for pipes and regulators, e.g., paragraph I.3.6?

RESPONSE: Field surveys were not conducted as part of the current project to confirm the interceptor geometry. The interceptor representation in the model was inherited from prior modeling efforts. Regulator configurations were confirmed using drawings dated from 1997 through 2008.

8. P. 189, re. RDII: Roughly what percentage of flow consists of RDII? Since there are three RDII components, just an average or total is all we request. We are just wondering how important is RDII to overall CSO volumes?

RESPONSE: The total typical year influent volume to the PVSC collection system is estimated to be 83,500 MG, of which approximately 600 MG is RDII.

9. Section I.4. The report should list the model time step for event calibration runs (short runs?) and long-term simulations (annual). Are the event calibration runs (Section I.5) run over a longer real time period, e.g., to establish antecedent conditions? Or are they just run over a period of several hours? Or maybe there's one long run for 2016 from which these four event simulations are extracted? Please explain.

RESPONSE: The same time steps were used for the calibration period simulations and the typical year simulations. Precipitation is input at a 5 minute time step. The model is run at a 1 minute time step and reported at a 5 minute time step. The calibration runs were done using two time periods. The simulation for the May 29th calibration event was started on May 27th to establish the antecedent conditions. The simulation for the July 25th through 30th events were started on July 23rd to establish the antecedent conditions.

10. Of course, these reports and all models will be passed along to the PVSC and its consultants for future application. Of more than just geeky interest is information about time steps and run times for individual events (e.g., the calibration events) and annual simulations as well as the computing platforms used. What kind of simulation times are encountered? Did the team or InfoWorks develop post-processors to aid in the analysis? If this information is already included somewhere, please point to it in, say, an appendix. Else, please do include it, at least briefly.

RESPONSE: The typical year model simulation takes approximately 3 hours without water quality tracers included, 8 to 9 hours with the water quality tracers included. Post processing was performed in Excel.

11. P. 197 re. modeling criteria: It is definitely more important to match volumes than peaks, although both matter, because pathogen loads are driven by volume. Hence, it is good to have a more

stringent goal (-10% - +20%) for volumes than for peaks. In terms of overflows to receiving waters, upstream timing at individual locations mostly gets smeared out in the summation. Hence, overflow volume summary figures are very important. I would expect fits of model vs. monitor volumes to be better than flows in any event, because of the flow integration involved. This is reflected in the useful new Nash-Sutcliffe Efficiency (NSE) plots shown in Section I.5.3 (volume matches have higher R2).

Re. the many, predominantly impressive calibration plots comparing hydrograph flows and volumes, Figures I-27 – I-54:

RESPONSE: Acknowledged.

12. Display of the same hydrograph and scatter plots all on one page, with a separate page showing the hydrographs on larger plots, is a good way to present these analyses.

RESPONSE: A prior version of the report did include the four hydrograph and two scatter plots for each calibration location together on a single page. DEP commented that the figures were too small so they were separated into the separate pages for the scatter plots and the hydrographs.

13. Is there some duplication of figures in Figs. I-27 and I-28? The hydrographs and model-monitoring scatter plots look the same.

RESPONSE: The redline version of the document that the MEG reviewed can be confusing when it comes to replacing figures. As described in the response to Comment #12 above, the prior version of the System Characterization Report included the hydrographs and scatter plots on a single page, in this case that would have been Figure I-27 as found on page 200 of the document. Page 200 is being removed (redlined) and replaced with pages 199 and 201. Figure I-27 now contains only the scatter plots and the site location map. Figure I-28 contains only the hydrograph plots.

14. P. 221, Fig. I-42, errant meter data in the top figure have been smoothed out or in-filled in the lower figure. The text might mention this process somewhere.

RESPONSE: The screening and smoothing/filling of meter data is mentioned in Section E.5. The process has been explained in the updated version.

15. But not at all locations: Fig. I-46 retains the missing (we assume) monitor flows on both sets of hydrographs. That would certainly account for overestimation of volumes by the model for this location and events. Likewise Fig. I-51 for NE_15A. Volumes are not comparable for three of the four events.

RESPONSE: The missing monitored flow data for this meter occurred over a long period of time, making it impossible to interpolate between adjacent data points with any confidence in the resultant timeseries.

16. Yet for location NE_15A_II, Fig. I-52, the missing or no-flow monitoring data are believed. Maybe monitors could be identified as more or less reliable?

RESPONSE: For location NE_15A, which is an overflow meter, the recorded flow during this event was zero. The meter appears to have been operating properly. It is possible that the precipitation used in the model for this particular event didn't occur within the contributing area, or that the

model is simulating an overflow event as a response to a rainfall event that didn't trigger an actual overflow event.

17. Re. Section I.5.3 and NSE, NSE values are very high, and, as noted in the report, well above the threshold (~0.5-0.75) heuristically characterized as a "good fit." Unlike the traditional R2, we don't believe there is a significance test for the NSE. We do note slightly higher NSE-R2 for volume than for peaks.

RESPONSE: Acknowledged.

18. Figures I-63 – I-65 graphs re. overflow statistics, it would help to have "frequency" include units of #/year, as in Table I-11.

RESPONSE: The units of #/year have been added to the figures.

19. In the context of comment 11 above, while a few locations/storm events show inferior fits, the large majority of model-monitor fits are good and within the project percentage criteria. But where do/will we see the summary total overflow volume from all outfalls, modeled vs. monitored, shown at the end of the MEG4 H&H modeling presentation (slide 65)? That is an essential figure, needful of inclusion and discussion.

RESPONSE: This referenced figure and a discussion of the figure has been added to Section I.5.2.

20. The overflow statistics and simple Table I-12 at the end are useful.

RESPONSE: Acknowledged.

Section I ends abruptly, with no summary. We understand from discussion with Team staff that future reports will present more pertinent (to the goal of reducing receiving water pathogens) results, such as receiving water analyses.

RESPONSE: Acknowledged. The intent of this report was to characterize the existing collection system. Future reports will address alternatives for reducing combined sewer overflows, pathogens discharged to the receiving waters, and receiving water quality.

A few additional comments:

21. Sanitary sewer overflows, SSOs: This question may have been addressed earlier, but at this point, it isn't found in prior summations. What is the importance of SSOs in modeling and overall pathogen inputs to the receiving waters? They are not mentioned in the Characterization Report.

RESPONSE: There are no known SSOs within the PVSC service area.

22. We are still missing a sensitivity analysis or discussion of key H&H calibration parameters? With thousands of individual H&H variables, i.e., for specific subcatchments and pipes, what were the main variables actually used to calibrate the overall H&H model and subarea models? What are the "key model parameters" mentioned at the beginning of Section I.5, p. 195? A good discussion of the various SWMM modeling parameters is given in Section I.3.2, but there had to be some watershed-wide (or sub-watershed or city-wide) parameter adjustments at some time. What global

parameters were typically adjusted? To what parameters was the SWMM model most sensitive to in this highly urbanized area?

RESPONSE: The routing coefficient (RC) for combined sewersheds was the principal calibration parameter for the PVSC model. This parameter controls directly-connected impervious area, and is the principal factor determining total wet weather runoff into the collection system. Other important calibration parameters were subcatchment width (hydrograph shape), sanitary sewershed infiltration/inflow (I/I) coefficients ("R"), and Manning's N in the PVSC interceptor. However, the routing coefficient was by far the most important parameter adjusted.

The model's hydrology was adjusted differently for sanitary and combined sewersheds.

For sanitary sewersheds, the unit hydrograph parameters (known as the RTK method) were adjusted. Three R parameters control total I/I. Overall average R coefficient was calibrated at 0.5 percent for 62,000 acres (97 mi²) of separate service area (PVSC Model Summary and Update Procedures, April 2018, p. 5). Sanitary collection system I/I typically ranges from 0.1 to 5 percent of rainfall. I/I from sanitary sewersheds affects flow in the PVSC interceptor along the reach between Paterson and Newark, but has minor overall impact on total flow in the collection system, as demonstrated below.

For combined sewersheds, imperviousness (I) was generally computed directly using the National Land Cover Database (System Characterization Report, p. 179), while the routing coefficient was calibrated to match observed runoff rates. Effective imperviousness (EI) can be expressed as $EI = I \times (1-RC)$. As shown in Table I-7 of the report, the combined service area comprises 23,200 acres (36 mi²), averaging 70 percent impervious and a calibrated value of 41 percent effective impervious (corresponding with RC equal to 41 percent).

For 1-month peak rainfall of 0.4 inches per hour, the rational method ($Q = CIA$) may be used to estimate runoff from both the sanitary and combined service areas, with the assumption of a typical one-hour time of concentration in much of the collection system. For the separate service areas, peak runoff is $0.5\% \times 0.4"/h \times 62000 \text{ ac} = 124 \text{ cfs}$ (80 mgd). For the combined service area, peak runoff is $41\% \times 0.4"/h \times 22000 \text{ ac} = 3600 \text{ cfs}$ (2300 mgd). The combined area runoff greatly exceeds the collection system's wet weather capacity of approximately 300 mgd (550 mgd total conveyance/treatment minus 250 mgd dry weather flow). Combined runoff greatly exceeds sanitary runoff, which is thus relatively inconsequential for overall system performance. Even in small storms or non-peak rainfall, combined runoff can exceed total system conveyance/treatment capacity (e.g. 600 mgd at 0.1"/h rainfall).

The calibrated 41 percent effective imperviousness is lower than would be expected based on the range of values suggested by Sutherland (1995) and presented in the EPA SWMM Hydrology Manual (Rossman and Huber, 2015). Sutherland's method suggests that an area with 70 percent total impervious should have between 49 and 60 percent effective imperviousness. The PVSC project team has found that the low end of this range is typical in northeastern US communities. The fact that the PVSC value is below the end of Sutherland's proposed range is not surprising, as it is

common to find that some areas identified as having combined sewers instead drain to open waterways.

The routing coefficient in the combined service area was thus the principal determinant of total system runoff. It is also the key determinant of CSO volume; while parameters such as subcatchment width affect the timing of hydrographs, runoff across the PVSC combined communities has overland flow distances of at most a few hundred feet, and the timing of hydrographs from individual subcatchments cannot vary across a wide enough range to significantly influence the duration over which the collection system is stressed above its conveyance capacity.

References

PVSC LTCP Consultant Team, Memorandum to PVSC CSO Districts, dated April 24, 2018. PVSC Model Summary and Update Procedures.

Rossman, L. and W. Huber. Storm Water Management Model Reference Manual Volume I, Hydrology. US EPA Office of Research and Development, Washington, DC, EPA/600/R-15/162A, 2015.

Sutherland, R.C. (1995). Methodology for Estimating the Effective Impervious Area of Urban Watersheds. *Watershed Protection Techniques* 2(1): 47–51.

Section G.3 Overview of Sewer System Quality Monitoring Program and G.4 Sewer System Quality Results

1. A good CSO and stormwater sampling program, with help that the PVSC Water Resources Recovery Facility (WRRF) has continuous monitoring. Given the enormity of the watershed/sewershed, the monitoring seems adequate for model development and calibration.

RESPONSE: Acknowledged.

2. Two or three representative photographs of monitoring sites, e.g., at/within a CSO location or regulator, would give the reader a sense of the difficulties of CSO monitoring, here or in Section D. The Team provided these on a PPT in one set of responses to MEG comments.

RESPONSE: Acknowledged. Two representative photos are provided below.



Table I.5 and Appendix B re. MEG comments and meeting reviews


1. To the extent of memory and notes, the MEG reviews are adequately characterized. MEG member comments have been addressed other than as noted above. We believe our summary comments have been uniformly positive and supportive of ongoing activities and see no reason why the report might not mention this if desired.





RESPONSE: Acknowledged.

2. Pp. 173-174 re. MEG affiliations, Huber would prefer his affiliation to be “Oregon State University, emeritus.”

RESPONSE: This report has been updated to reflect Dr. Huber’s affiliation.

PVSC LTCP
MEG Meeting 1, 2, 3 and 4 Presentations

| | | |
|--|--|---|
| <h1>PVSC Long Term Control Plan</h1> <h2>Model Evaluation Group – Session 1</h2> | | |
|  | |  |
| <p>INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS</p> | | <p>February 5, 2016</p>    |

| | |
|--|--|
| <h2>Agenda</h2> <ul style="list-style-type: none">■ Introductions■ MEG Mission■ MEG Scope■ Regulatory Drivers■ Site Information/Background■ Long Term Control Plan Process■ Specific Modeling Components■ Discussion/Next Steps | |
| <p>INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS</p>     | |

Introductions

- PVSC
 - Bridget McKenna
 - Marques Eley
 - Sheldon Lipke (SJL Environmental)
 - Charles Dujardin (GLEC)
- MEG
 - Alan Blumberg, Stevens Institute of Technology
 - Steve Chapra, Tufts University
 - Wayne Huber, Oregon State University
- LTCP Consultant Team
 - Greeley & Hansen
 - CDM Smith
 - HDR
- NJDEP
 - Marzooq Alebus
 - Susan Rosenwinkel
 - Chang Wu

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



MEG Mission

“The Model Evaluation Group (MEG) will review all significant technical aspects of the PVSC Long Term Control Plan model development. Model development will consist of three distinct components: Landside, Hydrodynamic, and Water Quality. The goal is to ensure that these model components are technically viable for use by the engineering team in the assessment of engineering alternatives and with withstand regulatory and public scrutiny.

The MEG will provide guidance, where appropriate, to improve or enhance the approaches and methodologies that lead to model development. The MEG will judge, individually and jointly, the technical acceptability of the major model components. If a component is deemed unacceptable, the MEG will outline steps to improve the technical acceptability of the model components. All findings will be summarized in interim progress reports and a final report.”

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Scope of the MEG

- Work Items (separate handout)
 - Review modeling workplans for landside, hydrodynamic and water quality models
 - Review proposed existing data sources
 - Review proposed sampling plans
 - Respond to requests for opinions
 - Provide guidance during sampling, model development and calibration phases
 - Prepare summary report
- Constraints
 - LTCP must stay within NJPDES permit schedule
 - Reasonable balance of new data and cost
 - Models are the “tools” to develop/evaluate CSO control alternatives for the LTCP

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Regulatory Drivers

- CSO Long Term Control Plan
 - Required under NJPDES permits pursuant to Clean Water Act and CSO Policy
 - “Approvable” plan to be developed within 5-year timeframe
 - PVSC developing one coordinated LTCP for PVSC and 8 CSO municipalities
 - Goal is to identify appropriate CSO controls needed to achieve or not preclude attainment of waterbody-specific water quality standards
- NJDEP-Required Submittals
 - Sewer System Characterization – QAPP and Report – July 1, 2018
 - Major components - rainfall, CSS characterization, CSO monitoring, model and sensitive areas
 - Baseline Compliance Monitoring Program – QAPP and Report – July 1, 2018
 - Major components – ambient monitoring, CSO discharge, rainfall
 - Public Participation Report – July 1, 2018
 - Consideration of Sensitive Areas Plan – July 1, 2018
 - Development and Evaluation of Alternatives Report – July 1, 2019
 - Selection and Implementation of Alternatives Report – June 1, 2020

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Sewer Systems

- Passaic Valley Sewerage Commission
 - 48 municipalities in Bergen, Essex, Hudson, Union and Passaic Counties
 - 1.5 million residents
 - 147 mi² service area
 - 22 mile interceptor sewer
 - 330 mgd WWTP
- PVSC combined service area
 - 8 municipalities
 - 0.9 million residents
- NBMUA
 - 2 CSO municipalities



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




PVSC Communities




INTERAGENCY ADVISORY, CONSULTATIVE A UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE CO



Passaic River Watershed



CSOs



INTERAGENCY ADVISORY, CONSULTATIVE AND UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMI

CSO Communities

| Municipality | WWTP | Population | Area (mi ²) | Sewerage (miles) | CSOs |
|--------------|-------|----------------|-------------------------|------------------|------------|
| Bayonne | PVSC | 63,000 | 5.8 | 94 | 30 |
| East Newark | | 2,400 | 0.1 | 2 | 1 |
| Harrison | | 13,600 | 1.3 | 18 | 7 |
| Jersey City | | 247,600 | 14.8 | 230 | 21 |
| Kearny | | 40,700 | 6.5 | 52 | 5 |
| Newark | | 277,100 | 22.3 | 579 | 18 |
| North Bergen | | 52,600 | 4.5 | 59 | 7 |
| Paterson | | 146,200 | 8.7 | 164 | 23 |
| Guttenberg | NBMUA | 11,200 | 0.2 | 5 | 1 |
| North Bergen | | 8,200 | 0.7 | 8 | 1 |
| Total | | 862,600 | 84 | 1,211 | 114 |

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS





Previous Monitoring and 2016 QAPP

| Municipality | WWTP | Previous Study | Internal Flow Meters | | CSO Flow Meters | | CSO WQ Sampling | |
|--------------|-------|----------------|----------------------|----------|-----------------|-----------|-----------------|-----------|
| | | | Previous | QAPP | Previous | QAPP | Previous | QAPP |
| Bayonne | PVSC | 2005 | 5 | 0 | 3 | 2 | 3 | 3 |
| East Newark | | 1997 | 1 | 0 | 1 | 0 | 1 | 0 |
| Harrison | | 1997 | 7 | 1 | 1 | 0 | 1 | 2 |
| Jersey City | | 2005 | 59 | - | 4 | - | 2 | - |
| Kearny | | 1997 | 9 | 0 | 2 | 1 | 2 | 1 |
| Newark | | 2005 | 32 | 2 | 22 | 5 | 8 | 4 |
| North Bergen | | 2005 | 10 | 0 | 3 | 2 | 2 | 2 |
| Paterson | | 1997 | 27 | 1 | 7 | 2 | 7 | 5 |
| Guttenberg | NBMUA | 2005 | 0 | 0 | 0 | 1 | 0 | 0 |
| North Bergen | | 2005 | 1 | 2 | 1 | 0 | 1 | 1 |
| Total | | | 151 | 6 | 44 | 13 | 27 | 18 |

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS





Baseline Compliance Monitoring Program QAPP



| Station | Waterbody | Coordinates | | Baseline | Status |
|---------|----------------|-------------|-----------|------------|--------|
| | | Lat | Lon | | |
| PAS-C | Passaic River | 40.88257 | -74.14000 | PVSC | |
| PDM-A | Passaic River | 40.91462 | -74.27100 | PVSC | |
| PAS-B | Passaic River | 40.89700 | -74.27300 | PVSC | |
| PAS-A | Passaic River | 40.88773 | -74.24700 | PVSC | |
| 1 | Passaic River | 40.90406 | -74.20066 | PVSC | |
| B24 | Passaic River | 40.91521 | -74.33198 | Contractor | |
| 2 | Passaic River | 40.92120 | -74.37550 | Contractor | |
| 3 | Passaic River | 40.94130 | -74.34820 | PVSC | |
| B22 | Passaic River | 40.91816 | -74.33024 | Contractor | |
| 4 | Passaic River | 40.90266 | -74.31500 | PVSC | |
| 5 | Passaic River | 40.87950 | -74.32666 | PVSC | |
| 6 | Saddle River | 40.88900 | -74.08140 | PVSC | |
| 7 | Passaic River | 40.84149 | -74.32275 | PVSC | |
| B7 | Third River | 40.82598 | -74.33306 | | |
| 8 | Passaic River | 40.78616 | -74.34753 | PVSC | |
| 9 | Second River | 40.78350 | -74.36150 | PVSC | |
| 10 | Passaic River | 40.79120 | -74.36530 | PVSC | |
| 11 | Passaic River | 40.71366 | -74.33566 | Contractor | |
| B4 | Franko Creek | 40.74632 | -74.33747 | Contractor | |
| B6 | Passaic River | 40.74148 | -74.33632 | Contractor | |
| 12 | Passaic River | 40.71983 | -74.32183 | PVSC | |
| 13 | Mockwood Brook | 40.69400 | -74.29600 | PVSC | |

OPERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



System Characterization and Landslide Modeling QAPP



PVSC System Characterization and Landslide Modeling, Part 1 and Part 2 QAPP

Part 1:

- East Newark
- Harrison
- Kearny
- Newark
- Paterson

Part 2:

- Bayonne
- North Bergen (portion)

OPERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



East Newark

Baseline Compliance Monitoring Program



NOT SUBJECT TO DISCLOSURE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Harrison

Baseline Compliance Monitoring Program



System Characterization Wastewater Quality Sampling Stations



Kearney

Baseline Compliance Monitoring Program



System Characterization Wastewater Quality Sampling Stations





Newark

Baseline Compliance Monitoring Program



System Characterization Wastewater Quality Sampling Stations





North Bergen (PVSC)

Baseline Compliance Monitoring Program



System Characterization Wastewater Quality Sampling Stations



North Bergen Woodcliff WWTP

- 477 acres serving 368 acres in North Bergen and all of Guttenberg (109 acres)
- 1 permitted CSO to Hudson River
- 3 mgd Woodcliff WWTP
- North Bergen MUA and Guttenberg cooperatively develop a CSO LTCP. Communities have requested PVSC's LTCP Engineer to develop the System Characterization and Landside Modeling Program on behalf of these permittees



North Bergen Woodcliff WWTP Proposed Temporary Flow Meter Locations




25 UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

North Bergen Woodcliff WWTP System Characterization Wastewater Quality Sampling Stations




26 UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

NOAA and USGS Rain Gauges



Landside Modeling



Landside Modeling

- System Review
 - Overview of PVSC Service Area Models
 - North Bergen
 - Bayonne
 - Jersey City
 - PVSC Main Interceptor
 - PVSC Interceptor Model Development History
 - Current and Historical Data Availability
 - Previous Model Status and Ongoing Model Update
 - Potential Model Improvement

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

29



PVSC Service Area

- Service Area : ~100 mi²
 - Combined 13K ac
 - Separated 57K ac
 - 48 municipalities
 - 8 CSO communities
 - 1.5 million population
- Plant Flow
 - 330 mgd permitted & design
 - Average day 210 mgd




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

30



Non-PVSC Models

- North Bergen
 - Najarian Associates
 - PCSWMM
 - LTCP Team has model
 - Converted to EPA SWMM for CSO Alert System



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Non-PVSC Models

- Bayonne
 - HDR
 - InfoWorks
 - LTCP Team has model
 - Used for CSO Alert System



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Non-PVSC Models

- Jersey City
 - ARCADIS
 - XPSWMM
 - LTCP Team does not have model
 - Model results provided by ARCADIS for CSO Alert System



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



PVSC Main Interceptor Model

- Large, Complex System
 - Main interceptor
 - Seven branch interceptors
 - Combined and separate sewers
 - Regulators
 - RTC
 - Pump stations
 - River crossings
 - Treatment plant



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO



Development History

- NJPDES General Permit for Combined Sewer Systems – 2003 Interceptor Modeling and CSO Characterization Study
 - XPSWMM schematic model
 - Main and branch interceptors
 - Regulators in Paterson, East Newark, Kearny and Harrison
 - Temporary flow and rainfall monitoring
 - Model calibration
 - Event mean concentration development for CSO loads

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History

- 2007 Long Term Control Plan
 - Converted From XPSWMM to InfoWorks
 - Still schematic
 - Integrated Newark and PVSC interceptor models
 - Newark XPSWMM model developed in 2005 by LMS Engineers
 - Converted to InfoWorks by LMS in 2006-2007
 - Newark portion of model is geo-referenced
 - Verified model with data used in 2003 study and additional interceptor data from 2005-2006

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History: Domain and Level of Detail

- Interceptors and Branch Interceptors
 - Not all manholes included in model
 - Continuous sewers with same size and slope without inflows are simplified as one link in model
 - Ground elevations from as-built drawings in 1940s
- Paterson, East Newark, Kearny and Harrison
 - Included regulators and one pipe section upstream of regulators
 - Combined sewers not modeled
 - Model subcatchments are regulator based, no sub-delineation of regulator drainage areas
 - Runoff parameters such as imperviousness from reported values

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History: Domain and Level of Detail

- Newark
 - Combined sewers up to 24" are included
 - Drainage areas are subdivided to subcatchments
- Separately Sewered Area
 - Modeled as dry weather point inflows to interceptor
 - No I&I representation except for Union Outlet
 - Groundwater Infiltration not modeled
- Hudson County Force Main Service Areas
 - Not included

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History

- Geographic Layout - Mixed
 - Newark
 - Sewers laid out per relative geographic location (accuracy unknown, i.e. not survey quality)
 - Subcatchments delineated as polygons
 - Other areas schematic in nature , not geo-referenced
- Suitability
 - Planning level flow and interceptor capacity analysis
 - Not enough detail outside Newark for combined sewer capacity analysis and alternative evaluation, surface flooding analysis or GI evaluation
 - Not applicable for asset management

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History: Layout and Level of Detail



Non-Newark



Newark

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History

- Recent Applications
 - Analysis for responses to EPA questions
 - Interceptor plug and release study for REDZONE inspection
 - Interceptor lining capacity analysis
 - PVSC CSO alert system website development

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Development History

- 2015 updates
 - Georeference entire model
 - Calibrate interceptor HGL using data collected May – Oct 2015

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Current and Historic Data Availability

- Permanent In-System Monitoring
- Historic Flow Monitoring and Model Calibrations
- New Level Monitoring Data
- Proposed Flow Metering

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Permanent In-system Monitoring Historically Used For Calibration

- Flow
 - Plant flow & Hudson County force main
 - 3 venturi meters
- Level
 - Two level meters
- Rain
 - At plant




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Historic Flow Monitoring and Calibration

- 1997-1998 Interceptor Monitoring
 - Flow and level
 - Calibration: 4 dry and 4 wet events
- 1999-2001 CSO Monitoring Program
 - Overflow and concentration at major outfalls
 - Calibration: 3 wet events for each group
- Permanent Meters
 - Verification: 5 wet events in 2005-2006




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




Historical Calibration Example

• In-system



• Overflow



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Notes on Previous Calibration

- Changes occurred in system, model has been updated but has not been recalibrated
 - Water conservation and dry weather flow changes
 - Market Street regulator and South Side interceptor gates no longer in operation
 - Regulator reconfiguration, area separation
 - Interceptor relining
- In-system monitoring and overflow monitoring did not occur concurrently for the same events, giving limited view of system-wide flow balance
- HGLs were not focus of previous work; level data collected were very limited

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Ongoing Update


- Geo-referenced main and branch interceptors, regulator and outfall locations
- Refined interceptor and branch interceptor representation by including all manholes
- Updated main and branch interceptor manhole invert and ground elevations with survey data
- Updated from interceptor ground elevations with best available topography
- Development of non-Newark area subcatchment boundaries

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Ongoing Update

- Updated Main Interceptor Profile



UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT



Current Characteristics

- InfoWorks CS 10.5; can be converted to ICM
- 1666 Nodes
 - 75 outfalls
- 1547 Links
 - 7 pumps
 - 71 orifices/slucices
 - 10 Newark gate + plant gate RTCs
- 473 Subcatchments




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Current Characteristics

- Automated Gate Operations
 - Main Plant Gates and Regulator Gates in Newark
 - Use Real Time Controls
 - Time-based RTC rules (operational logs) for events
 - General flow based rules (operational criteria) for continuous simulation



CSO REGULATORS

| OUTLETS | OUT OF SYSTEM | OUT DATE | OUT TIME | COMPUTER | | IN DATE | IN TIME | AUTO | | LINE CREW MANUAL |
|-----------|---------------|----------|----------|------------|------------------|----------|---------|-------|--------|------------------|
| | | | | AUTO OPER. | LINE CREW MANUAL | | | OPER. | MANUAL | |
| CLAY ST. | X | 05/31/15 | 16:35 | X | | 06/02/15 | 9:30 | | | X |
| VERONA | X | 05/31/15 | 16:34 | X | | 06/01/15 | 18:32 | X | | |
| HERBERT | X | 05/31/15 | 16:35 | X | | 06/01/15 | 18:31 | X | | |
| 4TH AVE. | X | 05/31/15 | 16:33 | X | | 06/01/15 | 18:32 | X | | |
| CITY DOCK | X | 05/31/15 | 16:30 | X | | 06/01/15 | 18:30 | | | X |
| JACKSON | x | 05/31/15 | 19:30 | X | | 06/01/15 | 18:30 | X | | |
| POLK | x | 05/31/15 | 19:29 | X | | 06/01/15 | 18:29 | X | | |
| FREEMAN | x | 05/31/15 | 19:30 | X | | 06/01/15 | 18:30 | X | | |
| SAYBROOK | X | 05/31/15 | 16:34 | X | | 06/01/15 | 18:30 | X | | |
| RECTOR | X | 05/31/15 | 16:36 | X | | 06/01/15 | 18:33 | X | | |

INTERAGENCY ADVISORY
UNDER N.J.S.A. 47:1A-1

GREELEY AND HANSEN

CDM Smith



Current Characteristics

- Boundary Condition
 - Upstream of Dundee Dam
 - River elevation
 - Downstream Tidal Area
 - Tidal elevation
 - Internal Overflows
 - Free discharge



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

GREELEY AND HANSEN

CDM Smith HDR



2015 Calibration - Rain

- Gauge Adjusted Radar Rainfall Collected (GARR)
 - Long interceptor system, spatial rainfall differences exists between upstream and downstream drainage areas
 - 2015 radar rainfall
 - 5-min
 - hourly



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. I
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS


2015 Calibration - Metering

- Flow Assessment Level Monitoring
 - 18 level (1 with flow) meters along main interceptor
 - May 8th - Oct 10th, 2015
 - 5-minute data
- PVSC Permanent Meters
 - Flow
 - Level



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIV
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT

2015 Calibration: Flow Assessment Levels




Sample Level Data
 INTERIOR DESIGN CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




2015 Calibration: Events

- Selection of Calibration and Validation Events

| Station | EWR | | | | | TEB | | | | | |
|-----------------|---------------|------------------|---------------|---------------------|---------------------|---------------|------------------|---------------|---------------------|---------------------|--------------|
| | Start time | Durati on (hrs.) | Volum e (in.) | Ave inten (in./hr.) | Max inten (in./hr.) | Start time | Durati on (hrs.) | Volum e (in.) | Ave inten (in./hr.) | Max inten (in./hr.) | Delta (hrs.) |
| Calibration/Val | 5/16/15 19:00 | 6 | 0.67 | 0.11 | 0.45 | 5/16/15 19:00 | 9 | 0.18 | 0.02 | 0.07 | 15 |
| Calibration | 5/31/15 14:00 | 23 | 2.68 | 0.12 | 0.74 | 5/31/15 15:00 | 14 | 1.86 | 0.13 | 0.53 | 98 |
| Validation | 6/14/15 21:00 | 9 | 0.77 | 0.09 | 0.24 | 6/14/15 22:00 | 7 | 0.82 | 0.12 | 0.39 | 146 |
| Calibration | 6/15/15 14:00 | 4 | 0.66 | 0.17 | 0.33 | 6/15/15 14:00 | 4 | 0.38 | 0.1 | 0.26 | 14.5 |
| Validation | 6/27/15 15:00 | 15 | 1.37 | 0.09 | 0.28 | 6/27/15 16:00 | 16 | 1.25 | 0.08 | 0.19 | 150.5 |
| Calibration | 7/1/15 4:00 | 1 | 0.99 | 0.99 | 0.99 | 7/1/15 4:00 | 1 | 0.99 | 0.99 | 0.99 | 76.5 |
| Calibration | 7/30/15 14:00 | 3 | 0.84 | 0.28 | 0.54 | 7/30/15 13:00 | 4 | 0.35 | 0.09 | 0.3 | 294.5 |
| Calibration | 8/11/15 5:00 | 6 | 0.96 | 0.16 | 0.38 | 8/11/15 5:00 | 6 | 0.84 | 0.14 | 0.37 | 172 |
| Validation | 9/10/15 3:00 | 17 | 0.98 | 0.06 | 0.19 | 9/10/15 1:00 | 9 | 0.45 | 0.05 | 0.16 | 717.5 |
| Validation | 9/29/15 23:00 | 11 | 1.31 | 0.12 | 0.77 | 9/29/15 22:00 | 9 | 1.5 | 0.17 | 0.73 | 394 |
| Calibration | 10/2/15 2:00 | 30 | 1.5 | 0.05 | 0.23 | 10/2/15 7:00 | 22 | 1.27 | 0.06 | 0.21 | 22.5 |



2015 Calibration: PVSC Data



Sample Flow Data




INTENT FOR ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

59



2015 Calibration: – Example Results

- Hydrograph Comparison
- Profile Comparison
- Goodness-of-fit Comparison



UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC I



Potential Improvements

- Expand and Build-out
 - Current model does not include detailed combined sewer network in areas outside Newark (Subcatchments at regulators)
 - Data Required
 - Field survey and development of GIS database of major sewer network
 - Development of drainage area maps for subcatchments delineations, along with other data such as: imperviousness, landuse, population, slope, etc.
 - Additional flow monitoring within municipalities
 - Benefits
 - Asset management, municipality level sewer capacity analysis, alternatives evaluation (storage, GI, etc.)


INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Potential Improvements

- Update base flow and include GI and I&I characterization
 - Currently GWI and I&I not modeled, base dry-weather flow distributions based on 1990s data
 - Requirements
 - Updated water usage/billing info for modeled flow distribution and identifying SIU (significant industrial users)
 - Monitored flow from separate sanitary areas for I&I calculation
 - Expanded to include subcatchments from separate areas
 - Benefits
 - Better characterize dry flow vs. wet flow, piped flow vs. infiltration.
 - Quantify I&I from non-CSO communities
 - Conduct infiltration reduction analysis and assess impact of SIUs

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Potential Improvements

- Update Calibration with Built-out Network
 - Recently collected data does not include outfall monitoring
 - Requirement
 - Additional flow and level data in combined system, interceptor and outfalls (Part of CSO Characterization)
 - Benefit:
 - Verify changes made to model
 - Verify modeled flow components (storm runoff, infiltration, plant flow, outfall flow)
 - Verify HGLs for flooding analysis and assessing system capacity
 - Evaluate plan alternatives (rehabilitation, storage, flow control, GI, etc.)

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Hydrodynamic Modeling

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Hydrodynamic Modeling

- History of NY-NJ Models
- Proposed Model Grid
- Model Summary
- Calibration Data
- Challenges

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




Overview of NY-NJ Harbor Models

- Early 1990s – Inner and Outer Harbor CSO Studies for NYCDEP
- Mid 1990s – System Wide Eutrophication Model (SWEM)
- Early 2000s – NY-NJ Pathogen TMDL, CARP (Contamination Assessment and Reduction Project)
- 2005 to Present: Lower Passaic River/ Newark Bay EPA Superfund Studies

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



SWEM/CARP Domain



UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



SWEM/CARP: NY-NJ Harbor Area



INTERAGENCY ADVISORY, CONSULTATIVE AND
UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COM



SWEM/CARP: NJ LTCP Area

- Coarse resolution in:
 - Lower Passaic River (~1-2 km)
 - Hackensack River (~1-2 km)
 - No Meadowlands
 - Newark Bay: single grid (7 grid cells of 2 km size)
 - Arthur Kill & Kill van Kull: single grid cells
 - Hudson River and Upper Bay (~300x1500 m)



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
 UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



2015 Refined Grid

- Improved Resolution
 - Lower Passaic River (200-500 m)
 - Hackensack River (200-500 m)
 - NJ Meadowlands
 - Newark Bay (100x200 m)
 - Arthur Kill & Kill van Kull: 3-5 lateral cells (100x250 m)
 - Hudson River and Upper Bay (200x600 m)
- Expanded Domain
 - Dundee Dam to Little Falls
 - Overpeck Creek (100x300 m)
 - Elizabeth River (40x150 m)



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
 UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



2015 Refined Grid

- Expanded Domain
 - Dundee Dam to Little Falls
 - Overpeck Creek



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



2015 Refined Grid

- Improved Resolution
 - Lower Passaic River
 - Newark Bay
 - Arthur Kill & Kill van Kull
- Expanded Domain
 - Elizabeth River




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




ECOMSED Features

- 3D Hydrodynamic Model
 - Current
 - Temperature
 - Salinity
 - Water Levels
- Turbulence Model



- Sigma (σ) Coordinate System: 10 layers for PVSC model



$$\sigma = \frac{z - h}{H + h}$$

- Horizontal Orthogonal Curvilinear Coordinate System

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Inputs

- Tidal Forcing
 - Mid-Atlantic Bight
- Freshwater
 - Rivers
 - CSOs
 - Stormwater outfalls & direct drainage
 - Wastewater treatment plants
- Thermal Loads
 - Power plants
- Meteorological Forcing
 - Winds
 - Air temperature
 - Barometric pressure
 - Solar radiation

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Available Calibration Data

- NYC DEP Harbor Survey Program: T/S
- NOAA/USGS/Hudson River Environmental Conditions Observing System (HRECOS) monitoring data: tides, T/S
- NJ Harbor Dischargers Group: T/S
- Meadowlands Environmental Research Institute (MERI): T/S
- Rutgers: 2008 – 2009 (ADCP, T/S)
- Tierra Solutions: 2010 – 2011 (ADCP, T/S)
- NJ LTCP WQ Sampling Program: 2016 (T/S)

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Available Calibration Data



Meadowlands Environmental Research Institute Water Quality Monitoring Network

- 2004 – present



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATTER
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INTERFERE



2008 - 2011 ADCP & Temperature/Salinity



- ADCP: Acoustic Doppler Current Profiler
- Note: These data were collected during USACE NY District Harbor Deepening Projects



WATER
INSPECTION



Sampling Location Modifications

- Lateral stations in Hudson River
- Some locations based on field recon
- Additional baseline and event stations in Upper Passaic River
- Additional source stations
 - Frank's Creek
 - Third River
 - Woodbridge Creek
- Additional station in Kill van Kull
- Additional stations at The Narrows



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT

79

Sampling Stations

- 32 Baseline
- 7 Source
- 22 Intensive Event
- Sampling frequency
 - Baseline and Source
 - Jan-Apr: Monthly
 - May-Jun: Bi-weekly
 - Jul-Sept: Weekly
 - Oct-Dec: Monthly
 - Intensive event
 - 3 events
 - 3 days/event
 - Sampled twice a day



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT

80

Calibration Objectives

- Accurate Volume Exchange in the Meadowlands:
 - Total: 8,400 acres (~13 mi²) vs. Wet Areas: 3,500 acres (~5.5 mi²)
 - Needed for proper tidal dynamics (amplitude and phases)
 - Potential importance of groundwater seepage (~100 cfs)
- Correct net fluxes through the Kills (counter-clockwise)
- Correct net fluxes through the East River
- Proportion of fresh and saline areas in the Meadowlands

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




Meadowlands



Photo by Doc Searls



Hackensack River (Looking East)




UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Photo by Doc Searls



Hackensack River in Winter (Looking East)



UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Photo by Doc Searls



Water Quality Modeling

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

85



Water Quality Modeling

- Previous work (Pathogen TMDL)
- Proposed bacteria model
- Inputs
- Calibration
- Projections

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Water Quality Modeling Approach

- Use Pathogen TMDL work as starting point
- Update landside modeling from RAINMAN to InfoWorks for NJ CSO Communities
- Update NYC landside modeling using RAINMAN and IW loads
- Refine water quality model segmentation in key areas
- Recalibrate WQ model using
 - 2016-2017 New Jersey Harbor Dischargers Group (NJHDG) data
 - 2016-2017 Baseline monitoring sampling data
 - 2016-2017 Event-based WQ sampling data

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Pathogen TMDL Modeling

- Work conducted 2005-2007
- Endpoints (attainment)
 - Total coliform
 - Fecal coliform
 - Enterococci
- MEG reviewed original work
- TMDL not finalized



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Basis of Pathogen TMDL Loading

- CSO loadings by RAINMAN
 - Cross-calibrated to SWMM or IW for NJ
 - RAINMAN for NYC
 - Loads based on a mass balance approach
- Stormwater loadings by RAINMAN



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO



Pathogen TMDL Calibration

- WQ Model
- Calibration
 - Periods in 2002 and 2003
 - Total coliform
 - Fecal coliform
 - Enterococci
- No intensive wet-weather data available



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE
UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO



Program Enhancements


- Upgrade from RAINMAN to InfoWorks for NJ-based sources
- Add source sampling locations to provide better accounting of source loads
- Add receiving water sampling stations and wet-weather event sampling to provide additional data for model re-calibration
- Enhance model grid resolution
- Model skill assessment as outlined in draft QAPP

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Bacteria Model

- RCA (Row-Column AESOP)
- State variables
 - Salinity
 - Tracer
 - E. coli
 - Fecal coliform
 - Enterococci



WATER QUALITY MODEL

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




Bacteria Model Kinetics

$$N = N_0 \exp(-K_B t)$$

$$K_B = [0.8 + 0.006(\% \text{seawater})] 1.07^{(T-20)} + \alpha I_0(t) / K_e H [1 - \exp(-K_e H)] + V_s / H$$

(Mancini, 1978)

- N = Bacteria concentration
- K_B = Bacteria loss rate
- T = Temperature (°C)
- α = proportionality constant (~1)
- I_0 = Surface solar radiation
- t = time
- K_e = Extinction coefficient (1/m)
- H = Depth (m)
- V_s = Net settling rate (m/d)



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Required Inputs

- Hydrodynamics
- Loads
 - CSOs
 - Storm drains
 - Direct drainage
 - Dry-weather sources
 - WWTPs
- Boundary Conditions
 - Rivers
 - Ocean
- Constants and Parameters
 - Die-off rates
 - Additional constants or parameters as necessary

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Input Development

- CSO Flows and Volumes
- Generate NJ CSOs with InfoWorks
- Use 2008 Characterization Study models
- Convert SWMM to InfoWorks as necessary
- PVSC InfoWorks Model
 - Paterson, Newark, Kearny, Harrison, East Newark
 - Bayonne, North Bergen to be added
- Other local CSO municipalities (provided by others)
 - Elizabeth, Ridgefield Park, Hackensack, Fort Lee, Guttenberg, Perth Amboy, North Hudson Sewerage Authority, Jersey City

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS




Sources of CSO Flow/Volumes

- | | |
|--------------------------|-------------------|
| ▪ Greeley and Hansen | ▪ CDM Smith |
| ▪ PVSC/NBMUA communities | ▪ Perth Amboy |
| ▪ Paterson | ▪ Hatch Mott |
| ▪ Newark | ▪ Elizabeth |
| ▪ Kearny | ▪ Ridgefield Park |
| ▪ Harrison | ▪ CH2M |
| ▪ East Newark | ▪ North Hudson |
| ▪ Bayonne | ▪ AECOM and H&S |
| ▪ North Bergen | ▪ NYC |
| ▪ Guttenberg | ▪ HDR |
| ▪ Arcadis | ▪ Fort Lee |
| ▪ Hackensack | |
| ▪ Jersey City (PVSC) | |

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Approaches to CSO Loading

- Event Mean Concentration: Constant concentrations
 - Pros: simple, commonly used
 - Cons: does not represent observed variability
-  Mass Balance: Constant sanitary and stormwater concentrations mixed based on IW calculations
 - Pros: simple, consistent, predictive
 - Cons: less variability, IW-dependent
- Monte Carlo: Concentrations from a generated probability distribution based on observed data
 - Pros: reproduces observed magnitude and variability of data
 - Cons: requires site specific data, random, non-predictive
- Hybrid Mass Balance/Monte Carlo: Mass Balance with concentrations generated by Monte Carlo
 - Pros: reproduce observed data while including predictive capabilities

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Proposed CSO Loading Approach – NJ

- Use IW/SWMM flows provided by consultants
- Use 2008 CSO Characterization Study measured data
- Supplement with LTCP 2016 data as necessary
- Bacteria concentrations
- Mass balance (approach used for Pathogen TMDL)




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Proposed CSO Modeling Approach – NYC

- NYCDEP will provide flows and loads using existing InfoWorks
- All areas, with exception of Oakwood Beach (RAINMAN) in InfoWorks
- InfoWorks models to be recalibrated by end of 2017



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Proposed Approach to Stormwater Loads


- Use InfoWorks or gauged flow regression
- Calibrate to gauge data and 2016-2017 measurements
- Bacteria concentrations based on literature values for land uses, supplemented with 2016-2017 stormwater monitoring results
 - Geometric mean concentrations
 - Constant in time
 - Spatially varying depending on literature/sampling data

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Proposed Approach to Upstream Flows

- Use available flow data from USGS gauges
 - Hackensack River
 - Saddle River
 - Elizabeth River
 - Second River
 - Third River
- Develop runoff using InfoWorks or methodologies used for Passaic River Superfund Project for other tributaries




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO



Proposed Approach to Upstream Concentrations

- Develop functional relationships based on 2016-2017 sampling data and historical data
 - NJHDG
 - Third party



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO



Data for Water Quality Calibration/Validation

- Calibration
 - 2016-2017 NJHDG data
 - Weekly (July-September)
 - Every other week (May, June)
 - Monthly (January-April, October-December)
 - 2016-2017 LTCP Baseline Compliance Monitoring data
 - Same frequency as NJHDG
 - 2016-2017 Intensive Sampling Event data
 - Three 3-day events
 - Other: NYCDEP Harbor Survey, Citizens, etc.
- Validation
 - Historical NJHDG, NYCDEP, IEC, Meadowlands Research Institute data

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Calibration Assessment

- Graphical Comparisons
 - Spatial transect plots of model output versus observed
 - Graphical time-series plots of observed and predicted data
 - Comparisons between observed and calculated probability distributions
 - Scatter plots of observed versus predicted values
- Statistical Comparisons (geometric means)
 - Mean error
 - Absolute
 - Relative error

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Projection Simulations

- Baseline
- Gap Analysis (100% CSO Removal)
- Component Analysis
 - NYC sources
 - NJ CSOs
 - NJ non-CSOs
 - Upstream/downstream boundary conditions
- CSO Control Alternatives
 - Permittee-related
 - Area-wide
 - Final selected plan

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Discussion / Next Steps



INTERAGENCY ADVISORY
UNDER N.J.S.A. 47:1A-1 I







**PVSC – Long Term Control Plan
Modeling Evaluation Group – Session 2
*Hydrologic and Hydraulic Model***



**Greeley and Hansen LLC
March 17, 2017**



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS



Outline

- **Hydrologic and Hydraulic (H&H) Model Update**
 - Model Integration
 - Regulator Update
 - Paterson Re-delineation
 - Separated Service Area
 - Wet Weather Operating Rules
- **Next Step**









Model Integration

Bayonne Model

- Bayonne force main Connected to Hudson County Force Main
- 11 RTC rules appended to the integrated model
- Datum updated to PVSC datum

Model Integration

Jersey City Model

- Simplified model network to
 - represent Jersey City flow
 - connect North Bergen and Bayonne models to the PVSC model

Max pump rate based on meter data
 Jersey City East: Peak 54 MGD
 Jersey City West: Peak 48 MGD

Flows in Hudson County Force Main

- Jersey City East: Peak 54 MGD
- Jersey City West: Peak 48 MGD
- Bayonne: Peak 15 MGD
- Total Maximum: 117 MGD

Model Integration

Force Mains

- Hudson County Force Main was extended to the PVSC WPCF based on drawing
- South Kearny PS 30" force main was created and tied into the Hudson County Force Main



South Kearny Pump Station Service Area

- Kearny Meadowlands District
- South Kearny District
- Both Separated

South Kearny Pump Station

- Capacity: 17.5 MGD
- DWF: 1.6 MGD



Source: Mott MacDonald



| Regulator | Overflow Weir | | | | Regulating Sluice Gate / Orifice | | | | | |
|-------------------------------------|---------------|-------|----------------|-------|----------------------------------|---------------|---------------|----------------|-------|--------|
| | Drawing | | Original Model | | Drawing | | | Original Model | | |
| | Crest | Width | Crest | Width | Invert | Width | Height | Invert | Width | Height |
| P_015A (S.U.M. Park) | 152.9 | 2.5 | 152.9 | 2.5 | 151.87 | 1.25 | | 151.87 | 1.25 | |
| P-001A (Curtis Pl.) | 146.9 | 3.83 | 146.9 | 3.83 | 143.94 | 3 | 1 | 143.94 | 2.25 | |
| P-003A (West Broadway) | 139.5 | 4 | 139.5 | 4 | 137.4 | 1.25 | | 137.4 | 1.25 | |
| P-005A (Bridge St.) | 133.4 | 5 | 136.71 | 5 | 131.7 | 0.833 | 1.667 | 131.7 | 1.25 | |
| P-006A (Montgomery St.) | 134.2 | 8.0 | 135.25 | 8 | 129.53 | 2 | | 129.53 | 2 | |
| P-007A (Straight St.) | 133.8 | 6 | 133.8 | 5 | 130.1 | 1.83 | 3 | 130.1 | 1.25 | |
| P-009A (Keen St.) | 135.4 | 4 | 135.4 | 4 | 133.44 | 1.67 | 0.83 | 133.44 | 1.25 | |
| P-010A (Warren St.) | 133.85 | 4 | 135.21 | 3 | | | | | | |
| P-016A (Northwest St., modified) | 138.8 | 8 | 140.94 | 8.5 | 136.25 | 2.5 | | 136.25 | 2.5 | |
| P-017A (Arch St.) | 135.7 | 4.5 | 135.69 | 3.67 | 132.6 | 1 | | 132.6 | 1 | |
| P-032A (Hudson St.) | 135.2 | 4 | 135.2 | 4 | | | | | | |
| P-022A (Short St.) | 132.6 | 4.5 | 132.6 | 4.5 | 130.63 | 2 | | 130.63 | 2 | |
| P-021A (Bergen St.) | 132.7 | 4.5 | 132.7 | 4.5 | 130.75 | 1 | | 130.75 | 1 | |
| P-013A (East Eleventh St.) | 133.4 | 4.83 | 133.4 | 4.83 | 131.7 | 1.67 | 0.83 | 131.7 | 1.25 | |
| P-014A (Fourth Ave.) | 140.9 | 4.5 | 140.9 | 3 | 137.76 | 1.67 | 0.83 | 137.76 | 1.25 | |
| P-023A (Second Ave.) | 129.8 | 5 | 130.56 | 5 | 127.4 | Not available | Not available | 127.4 | 1.25 | |
| P-024A (Third Ave.) | 130.3 | 4.5 | 130.3 | 5 | 128.2 | 1.67 | 0.83 | 128.2 | 1.25 | |
| P-025A (East 33 rd Ave.) | 128.9 | 8.58 | 129.87 | 8.58 | 127.07 | 3 | 1 | 127.07 | 2 | |
| P-026A (East 20 th Ave.) | 129.2 | 5.5 | 128.92 | 5.5 | 126.95 | 1.67 | 0.83 | 126.95 | 1.66 | 0.83 |
| P-027A (Market St.) | 131.1 | 7.11 | 131.1 | 4.0 | 129.6 | 3.5 | 1.167 | 129.6 | 3.5 | 2.0 |
| | | | | | 129.6 | 3.5 | 1.167 | 129.6 | 3.5 | 0.0 |

Regulator Modification


| Regulator | Overflow Weir | | | | Regulating Sluice Gate / Orifice | | | | | |
|-------------------------------------|---------------|-------|----------------|-------|----------------------------------|-------|--------|----------------|-------|--------|
| | Drawing | | Original Model | | Drawing | | | Original Model | | |
| | Crest | Width | Crest | Width | Invert | Width | Height | Invert | Width | Height |
| N-002A (modified, Verona) | 110.43 | 41 | 103 | 6 | 102.65 | 2.5 | 2.5 | 99.33 | 2 | 2 |
| N-004A/005A (modified, Herbert Pl.) | 114.34 | 41 | 105.55 | 6.667 | 107.06 | 2 | 2 | 103.6 | 1.5 | 1.5 |
| N-008A (4th Ave.) | 103.5 | 6 | 103.5 | 6 | 100.7 | 1.5 | 1.5 | 100.7 | 1.5 | 1.5 |
| N-009A (Passaic St.) | 103.24 | 4 | 103.24 | 4 | 102.4 | 1.66 | 0.83 | 102.4 | 1.66 | 0.83 |
| N-010A (Clay St.) | 105.12 | 8.42 | 105.12 | 8.42 | 101.24 | 6 | 3 | 101.24 | 6 | 3 |
| | 105.12 | 8.42 | 105.12 | 8.42 | 101.24 | 6 | 3 | 101.24 | 6 | 3 |
| | 105.12 | 8.42 | 105.12 | 8.42 | | | | | | |
| N-014A (Rector St., modified) | 102.56 | 5.5 | 103.66 | 5.5 | 99.97 | 1.5 | 1.5 | 101.07 | 1.5 | 1.5 |
| N-014A (Saybrook Pl., modified) | 102.33 | 7 | 103.43 | 7 | 99.02 | 2 | 2 | 100.12 | 2 | 2 |
| N-015A (City Dock, modified) | 98.67 | 14 | 98.67 | 14 | 95.67 | 3.5 | 2.5 | 95.67 | 3.5 | 2.5 |
| N-016A (Jackson St.) | 97.62 | 7 | 97.62 | 4.5 | 96 | 1.5 | 1.5 | 96 | 1.33 | 1.33 |
| N-017A (Polk St.) | 97.8 | 8 | 97.8 | 7 | 95.2 | 1.5 | 1.5 | 95.35 | 1.33 | 1.33 |
| N-018A (Freeman St.) | 100.26 | 4 | 100.26 | 4 | 99 | 2 | 2 | 99 | 2 | 2 |
| N-022A (Roanoke Ave.) | 98.93 | 6 | 98.93 | 6 | | | | | | |
| N-027A/029A | 102 | 4.5 | 102 | 4.5 | 96.4 | 4 | 2.33 | 96.4 | 4 | 2.33 |
| N-025A (Peddie St.) | 98.6 | 8 | 98.6 | 8 | 93 | 4 | 2.33 | 93 | 4 | 2.33 |
| | 98.6 | 8 | 98.6 | 8 | | | | | | |
| | 98.6 | 8 | 98.6 | 8 | | | | | | |
| | 98.6 | 8 | 98.6 | 8 | | | | | | |
| N-030A | 102.32 | 10 | 102.32 | 10 | 99.04 | 4 | 3 | 99.04 | 4 | 3 |
| N-023A | 98.54 | 7 | 98.54 | 7 | | | | | | |


CRISLEY'S DAN HARRISON

Regulator Modification

| Regulator | Overflow Weir | | | | Regulating Sluice Gate / Orifice | | | | | |
|------------------------|---------------|-------|----------------|-------|----------------------------------|-------|--------|----------------|-------|--------|
| | Drawing | | Original Model | | Drawing | | | Original Model | | |
| | Crest | Width | Crest | Width | Invert | Width | Height | Invert | Width | Height |
| K-001A (Stewart Ave.) | 120.85 | 4.5 | 120.27 | 1.5 | 119.07 | 1 | | 119 | 1 | |
| K-004A | 107.9 | 1.5 | 108 | 1.5 | 106.9 | 1 | | 107 | 1 | |
| K-006A (Johnston Ave.) | 99.9 | 5 | 100.9 | 10 | 98.7 | 1.5 | | 98.2 | 1.5 | |
| | 99.9 | 5 | | | | | | | | |
| K-007A | 103 | 9 | 103 | 9 | 100.2 | 3 | 1 | 100.2 | 3 | 1 |
| K-010A (Duke St.) | 102.5 | 4 | 102.5 | 4.5 | 98.84 | 1 | 1 | 100.45 | 1 | |
| | | | | | | | | | | |
| E-001A | 101.6 | 4 | 101.6 | 4 | 99.2 | 1.25 | | 99.2 | 1.25 | |
| | | | | | | | | | | |
| H-001A | 101.2 | 4 | 101.2 | 4 | 99.8 | 1.25 | | 99.8 | 1 | |
| H-002A | 102.2 | 4 | 102.2 | 4 | 101 | 1 | | 101.2 | 1 | |
| H-003A | 103.9 | 4 | 103.9 | 4 | 101.4 | 1.25 | | 101.4 | 1.25 | |
| H-004A (Dey St.) | 102.2 | 4 | 102.2 | 3.5 | 100.58 | 1 | | 100.58 | 1 | |
| H-005A | 100.8 | 3.5 | 100.8 | 3.5 | 99.1 | 1 | | 99.1 | 1 | |
| H-006A | 99.9 | 4 | 99.9 | 4 | 97.9 | 1 | | 97.9 | 1 | |
| H-007A | 102.4 | 4.5 | 102.4 | 4.5 | 101.2 | 1 | | 101.2 | 1 | |


CRISLEY'S DAN HARRISON





Paterson Internal Regulator Connectivity



| Regulator # | Normal Flow Connection | Overflow Connection |
|------------------|-------------------------|---------------------|
| A1-1 to A1-9 (8) | P_001A Regulator | P_028A |
| EF-2 to EF-6 (5) | P_006A Regulator | P_029A |
| V2-1 | P_027A Regulator | P_030A |
| V1-1 to V1-9 (9) | P_027A Regulator | P_031A |
| EF-1 | PVSC Interceptor MH 243 | P_033A |



GREELEY AND HANSEN



Separated Service Area



The figure is a slide with a white top section and a large blue bottom section. In the top right corner of the white section is the logo for 'GREELEY AND HANSEN', which consists of a blue square with white vertical lines of varying heights, followed by the company name in a sans-serif font. The blue section contains the text 'Separated Service Area' in a large, white, sans-serif font, centered horizontally.





| Municipality | Type of Agreement | Lease/ Contract Date | Agreed Average Daily Flow (MGD) | Agreed Max Rate of Flow (MGD) | Comments |
|----------------------------------|-----------------------|----------------------|---------------------------------|-------------------------------|---|
| Passaic County | | | | | |
| Township of Little Falls | Lease | 9/29/1986 | 2.2 | | |
| Borough of Woodland Park | Lease | 4/25/1984 | 2 | 2 | |
| Borough of Totowa | Lease | 1/7/1986 | 2.4 | 2.4 | |
| Borough of North Haledon | Lease | 8/13/1980 | 1 | 1.8 | |
| Borough of Hawthorne | Lease | 3/23/1944 | 2 | 3 | |
| Bergen County | | | | | |
| Township of South Hackensack | Lease | 4/5/2010 | 0.05 | 0.1 | |
| Borough of Hasbrouck Heights | Third Party Agreement | | | | Via Lodi |
| City of Garfield | Contract | 1/1/1965 | 16.11 | 16.11 | |
| Borough of Lodi | Contract | 8/8/1960 | 4.5 | 4.5 | |
| City of Hackensack | Third Party Agreement | | | | Via Lodi |
| Township of Saddle Brook | Lease | 11/10/1960 | 2 | 2 | |
| Borough of Elmwood Park | Lease | 10/20/1943 | 1 | 1.5 (max day) | |
| Borough of Wood-Ridge | Lease | 11/15/2006 | 0.25 | | Lodi & Wood Ridge |
| Village of Ridgewood | Third Party Agreement | | | | Via Glen Rock & Hawthorne |
| Borough of Franklin Lakes | Third Party Agreement | | | | Via North Haledon |
| Borough of Fair Lawn | Lease | 1/3/1945 | 2.25 | 2.5 (max day) | |
| Borough of Glen Rock | Lease | 10/23/1944 | 1 | 1.5 (max day) | |
| Essex County | | | | | |
| Township of Cedar Grove | Third Party Agreement | | | | Via Little Falls and Montclair |
| Borough of North Caldwell | Third Party Agreement | | | | Via Little Falls |
| Township of West Orange | Third Party Agreement | | | | Via Orange |
| Township of South Orange Village | Third Party Agreement | | | | Via Orange |
| Hudson County | | | | | |
| City of Bayonne | Contract | 11/25/1986 | 11 | 17.6 | |
| Township of North Bergen | Contract | 3/9/2006 | 10 | 16 | |
| City of Union City | Contract | 9/25/1985 | 1.5 | 2.4 | |
| City of Jersey City | Contract | 9/24/1985 | 50 | 80 | |
| Union County | | | | | |
| City of Elizabeth | Third Party Agreement | | | | Via Airport / Port Newark to South Side Interceptor @ Waverly |
| Township of Hillside | Third Party Agreement | | | | Via Newark South Side Interceptor |












Next Step

Model Calibration/Validation Approach

- **Dry Weather Flow Calibration**
 - DWF distribution based on metershed
 - Weekday/Weekend Diurnal
- **Wet Weather Flow Calibration**
 - 2-3 storm events
 - CSO area runoff
 - Separated area RDII (RTK)
 - Wet weather flow peak and volume








**PVSC – Long Term Control Plan
Modeling Evaluation Group – Session 2
*Flow Metering Data***



**Greeley and Hansen LLC
March 17, 2017**

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

Outline

- **Flow Monitoring Data**
 - Temporary Flow Meter
 - Permanent Meter Data
- **Rainfall Data**
 - Rainfall Stations
 - Rainfall Data Analysis
- **Calibration Event**







Meter Summary Table

| Meter ID | Municipality | Location | Category |
|-------------------------|--------------|--|--------------------|
| Bayonne 008A OF | Bayonne | East 5th and Ingham Ave | Outfall |
| Bayonne 010A OF | Bayonne | W 1st and Avenue C | Outfall |
| Guttenberg 001A | Guttenberg | 70th and JFK Blvd | Outfall |
| Harrison 006 Influent | Harrison | Bergen and Dey | Regulator Influent |
| Kearny 007A | Kearny | King and Ivy Street | Outfall |
| Newark 004/005A | Newark | Herbert Place under elevated Hwy | Outfall |
| Newark 009/010 OF North | Newark | Clay Street - inside facility | Outfall |
| Newark 009/010 OF South | Newark | Clay Street - inside facility | Outfall |
| Newark 015A | Newark | City Dock | Outfall |
| Newark 014A | Newark | Saybrook in pull off | Outfall |
| Newark 025A East | Newark | Peddie - access through parking, near railroad | Regulator Influent |
| Newark 025A West | Newark | Peddie - access through parking, near railroad | Regulator Influent |
| Newark 025A Regulated | Newark | Peddie - access through parking, near railroad | Regulator Effluent |
| North Bergen 004A | North Bergen | 73rd and Hudson County 693 | Outfall |
| North Bergen 004B | North Bergen | Near 74th and Hudson County in grassy lot | Outfall |
| North Bergen 007A | North Bergen | 53rd and Tonnelle Ave in Concrete Plant driveway | Outfall |
| North Bergen 011A | North Bergen | 1101 Tonnelle Ave | Outfall |
| Paterson 006A East | Paterson | Montgomery and River St | Regulator Influent |
| Paterson 006A West | Paterson | Montgomery and River St | Regulator Influent |
| Paterson 006A Regulated | Paterson | Montgomery and River St | Regulator Effluent |
| Paterson_INT | Paterson | McLean Boulevard at Cemetary entrance | Interceptor |

Missing Data Period for Each Flow Meter







Dry Weather Flow Analysis






Hydrograph



Paterson Interceptor




















Rainfall Data Analysis






Candidate Storm Events for Calibration

| Rain Start | Rain End | Duration (hr) | Depth (in) | Max Intensity (in/hr) | Average Intensity (in/hr) |
|---------------|---------------|---------------|------------|-----------------------|---------------------------|
| 7/25/16 16:05 | 7/25/16 18:50 | 2.75 | 1.81 | 1.68 | 0.66 |
| 5/29/16 23:50 | 5/30/16 5:20 | 5.50 | 1.6 | 1.09 | 0.29 |
| 7/29/16 0:20 | 7/29/16 8:35 | 8.25 | 0.85 | 0.42 | 0.10 |
| 5/2/16 22:40 | 5/3/16 9:50 | 11.17 | 0.7 | 0.17 | 0.06 |
| 7/31/16 8:35 | 7/31/16 22:35 | 14.00 | 0.69 | 0.49 | 0.05 |
| 7/4/16 19:20 | 7/5/16 2:50 | 7.50 | 0.63 | 0.23 | 0.08 |
| 5/6/16 2:30 | 5/6/16 12:25 | 9.92 | 0.6 | 0.19 | 0.06 |
| 7/16/16 14:50 | 7/16/16 15:35 | 0.75 | 0.56 | 0.75 | 0.75 |
| 6/8/16 11:25 | 6/8/16 14:10 | 2.75 | 0.49 | 0.3 | 0.18 |
| 7/9/16 21:30 | 7/9/16 22:05 | 0.58 | 0.48 | 0.82 | 0.82 |
| 4/4/16 7:45 | 4/4/16 17:00 | 9.25 | 0.43 | 0.12 | 0.05 |



Discussion





PVSC – Long Term Control Plan Modeling Evaluation Group – Session 3

Hydrologic and Hydraulic Model Update and Calibration

**Greeley and Hansen LLC
September 15, 2017**

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

Agenda

- **Background: PVSC Sewer System**
- **PVSC Hydrologic and Hydraulic (H&H) Model Snapshot**
- **H&H Model Update**
- **H&H Model Calibration and Validation**
- **Summary & Next Step**

Background

3

Sewer Systems

- **Passaic Valley Sewerage Commission**
 - 48 municipalities
 - 8 CSO municipalities (0.9 million residents)
 - 1.5 million residents
 - 147 mi² service area
 - 22 mile interceptor sewer
 - 330 mgd WPCF


- **NBMUA Woodcliff WWTP**
 - 2 CSO municipalities
 - 3 mgd Woodcliff WWTP
 - 477 acres (368 acres in North Bergen)




PVSC Service Area


Legend

- PVSC Service Area
- CSO Communities
- Separated Communities
- PVSC WPCF (Water Pollution Control Facility)
- PVSC Interceptor / Sewer
- CSO Outfall



PVSC WPCF Schematic





CSO Communities

| Municipality | WWTP | Population | Area (mi ²) | Sewerage (miles) | CSOs |
|--------------|-------|----------------|-------------------------|------------------|------------|
| Bayonne | PVSC | 63,000 | 5.8 | 94 | 30 |
| East Newark | | 2,400 | 0.1 | 2 | 1 |
| Harrison | | 13,600 | 1.3 | 18 | 7 |
| Jersey City | | 247,600 | 14.8 | 230 | 21 |
| Kearny | | 40,700 | 6.5 | 52 | 5 |
| Newark | | 277,100 | 22.3 | 579 | 18 |
| North Bergen | | 52,600 | 4.5 | 59 | 7 |
| Paterson | | 146,200 | 8.7 | 164 | 23 |
| Guttenberg | NBMUA | 11,200 | 0.2 | 5 | 1 |
| North Bergen | | 8,200 | 0.7 | 8 | 1 |
| Total | | 862,600 | 84 | 1,211 | 114 |


Current H&H Model Snapshots

9

Entire PVSC H&H Model

- Subcatchment: 732
- Nodes (2735)
 - Manhole: 2621
 - Outfall: 103
 - Storage: 11
- Link (2873)
 - Conduit: 2567
 - Flap Valve: 82
 - Orifice: 33
 - Pump: 14
 - Sluice: 74 (30 variable)
 - Weir: 103


Entire PVSC H&H Model



10

Paterson Model

- Subcatchment: 67
- Nodes (585)
 - Manhole: 562
 - Outfall: 23
 - Storage: 0
- Link (657)
 - Conduit: 503
 - Flap Valve: 82
 - Orifice: 14
 - Pump: 0
 - Sluice: 16 (2 variable)
 - Weir: 42




Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

Newark Model

Newark Model

- Subcatchment: 310
- Nodes (758)
 - Manhole: 738
 - Outfall: 18
 - Storage: 2
- Link (819)
 - Conduit: 746
 - Flap Valve: 17
 - Orifice: 3
 - Pump: 3
 - Sluice: 27 (17 variable)
 - Weir: 23




Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

East Newark Model


- Subcatchment: 1
- Nodes (22)
 - Manhole: 21
 - Outfall: 1
 - Storage: 20
- Link (22)
 - Conduit: 19
 - Flap Valve: 1
 - Orifice: 1
 - Pump: 0
 - Sluice: 0
 - Weir: 1



Kearny Model


Kearny Model

- Subcatchment: 16
- Nodes (97)
 - Manhole: 91
 - Outfall: 5
 - Storage: 1
- Link (97)
 - Conduit: 78
 - Flap Valve: 5
 - Orifice: 7
 - Pump: 1
 - Sluice: 1
 - Weir: 5



Harrison Model

- Subcatchment: 16
- Nodes (117)
 - Manhole: 110
 - Outfall: 7
 - Storage: 0
- Link (118)
 - Conduit: 97
 - Flap Valve: 7
 - Orifice: 7
 - Pump: 0
 - Sluice: 0
 - Weir: 7




Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

North Bergen Model

North Bergen Model

- Subcatchment: 41
- Nodes (178)
 - Manhole: 166
 - Outfall: 9
 - Storage: 3
- Link (199)
 - Conduit: 183
 - Flap Valve: 0
 - Orifice: 0
 - Pump: 3
 - Sluice: 5
 - Weir: 8




Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

Jersey City Model

- Subcatchment: 5
- Nodes (34)
 - Manhole: 29
 - Outfall: 5
 - Storage: 0
- Link (36)
 - Conduit: 24
 - Flap Valve: 5
 - Orifice: 0
 - Pump: 2
 - Sluice: 5
 - Weir: 0




Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

Bayonne Model

- Subcatchment: 41
- Nodes (685)
 - Manhole: 651
 - Outfall: 29
 - Storage: 5
- Link (712)
 - Conduit: 648
 - Flap Valve: 27
 - Orifice: 0
 - Pump: 5
 - Sluice: 20 (11 variable)
 - Weir: 12

Bayonne Model




Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

Woodcliff WWTP Model

- Subcatchment: 5
- Nodes (38)
 - Manhole: 35
 - Outfall: 2
 - Storage: 1
- Link (39)
 - Conduit: 37
 - Flap Valve: 0
 - Orifice: 0
 - Pump: 0
 - Sluice: 1
 - Weir: 1



Legend

- CSOs
- ★ Permanent Meter
- ★ Temporary Meter
- Sewers in Model

Model Update


Existing Models

PVSC WPCF System

- PVSC Interceptor Model (InfoWorks CS)
- Bayonne Model (InfoWorks CS)
- North Bergen Model (2 PCSWMM model)
- Jersey City Model (XPSWMM model)

NBMUA Woodcliff WWTP System

- North Bergen Model (1 PCSWMM model)
- Guttenberg Model (1 PCSWMM model)



Legend


- PVSC CSO Area
- PVSC Service Area
- PVSC Municipalities
- Waterbody
- PVSC WPCF

Existing H&H Models

- PCSWMM
- InfoWorks (PVSC model)
- InfoWorks (Bayonne model)
- XPSWMM (Jersey City Model)
- Modeled Sewer Network

North Bergen Models

- North Bergen
 - Najarian Associates
 - 3 PCSWMM Models
 - LTCP Team has model
 - Converted to EPA SWMM for CSO Alert System



Bayonne Models

- Bayonne
 - HDR
 - InfoWorks CS
 - LTCP Team has model
 - Used for CSO Alert System




Jersey City Models

- Jersey City
 - ARCADIS
 - XPSWMM
 - LTCP Team does not have model
 - Model results provided by ARCADIS for CSO Alert System



PVSC Main Interceptor Model


- **Large, Complex System**
 - Main interceptor
 - Seven branch interceptors
 - Combined and separate sewers
 - Regulators
 - RTC
 - Pump stations
 - River crossings
 - Treatment plant



A Snapshot of Integrated Model...

Entire PVSC H&H Model

- 48 PVSC communities
- 8 CSO communities
 - ✓ Paterson
 - ✓ Newark
 - ✓ East Newark
 - ✓ Harrison
 - ✓ Kearny
 - (Above 5 discharge to interceptor by gravity to WPCF)*
 - ✓ Bayonne
 - ✓ Jersey City
 - ✓ North Bergen
 - (Above 3 discharge to Hudson County Forcemain to WPCF)*
- 2 NBMUA Woodcliff WWTP CSO communities
 - ✓ North Bergen
 - ✓ Guttenberg



Model Integration

Recreate North Bergen Model from PCSWMM



NB Delineation


Paper Copy

GIS Shapefile




Digitize model subcatchment based on paper copy


Sewer Network



30" North Bergen Force Main To Jersey City Interceptor

Model Integration/North Bergen Model






Model Integration

Bayonne Model

- With unique IDs starting with “BA-”
- Bayonne force main Connected to Hudson County Force Main
- 11 RTC rules appended to the integrated model
- Datum updated to PVSC datum



Model Integration

Jersey City Model


- Model was created with coarse estimates to allow connection of the North Bergen and Bayonne models to the PVSC model

Max pump rate based on data

Jersey City East: Peak 54 MGD
Jersey City West: Peak 48 MGD

Flows in Hudson County Force Main

- Jersey City East: Peak 54 MGD
- Jersey City West: Peak 48 MGD
- Bayonne: Peak 15 MGD
- Total Maximum: 117 MGD



Model Integration

Force Mains

- Hudson County Force Main was extended to the PVSC WPCF based on drawings
- South Kearny PS 30" force main was created and tied into the Hudson County Force Main




South Kearny Pump Station Service Area

June 2018 (Revised 03/28/19)
Page 458 of 796

- Kearny Meadowlands District
- South Kearny District
- Both Separated

South Kearny Pump Station

- Capacity: 17.5 MGD
- DWF: 1.6 MGD



Regulator Update

Regulator Modification

June 2018 (Revised 03/28/19)

Page 459 of 796

| Regulator | Overflow Weir | | | | Regulating Sluice Gate / Orifice | | | | | |
|-------------------|---------------|-------|----------------|-------|----------------------------------|---------------|---------------|----------------|-------|--------|
| | Drawing | | Original Model | | Drawing | | | Original Model | | |
| | Crest | Width | Crest | Width | Invert | Width | Height | Invert | Width | Height |
| P_015A | 152.9 | 2.5 | 152.9 | 2.5 | 151.87 | 1.25 | | 151.87 | 1.25 | |
| P-001A | 146.9 | 3.83 | 146.9 | 3.83 | 143.94 | 3 | 1 | 143.94 | 2.25 | |
| P-003A | 139.5 | 4 | 139.5 | 4 | 137.4 | 1.25 | | 137.4 | 1.25 | |
| P-005A | 133.4 | 5 | 136.71 | 5 | 131.7 | 0.833 | 1.667 | 131.7 | 1.25 | |
| P-006A | 134.2 | 8.0 | 135.25 | 8 | 129.53 | 2 | | 129.53 | 2 | |
| P-007A | 133.8 | 6 | 133.8 | 5 | 130.1 | 1.83 | 3 | 130.1 | 1.25 | |
| P-010A | 135.4 | 4 | 135.4 | 4 | 133.44 | 1.67 | 0.83 | 133.44 | 1.25 | |
| P-010A | 133.85 | 4 | 135.21 | 3 | | | | | | |
| P-016A (modified) | 138.8 | 8 | 140.94 | 8.5 | 136.25 | 2.5 | | 136.25 | 2.5 | |
| P-017A | 135.7 | 4.5 | 135.69 | 3.67 | 132.6 | 1 | | 132.6 | 1 | |
| P-032A | 135.2 | 4 | 135.2 | 4 | | | | | | |
| P-022A | 132.6 | 4.5 | 132.6 | 4.5 | 130.63 | 2 | | 130.63 | 2 | |
| P-021A | 132.7 | 4.5 | 132.7 | 4.5 | 130.75 | 1 | | 130.75 | 1 | |
| P-013A | 133.4 | 4.83 | 133.4 | 4.83 | 131.7 | 1.67 | 0.83 | 131.7 | 1.25 | |
| P-014A | 140.9 | 4.5 | 140.9 | 3 | 137.76 | 1.67 | 0.83 | 137.76 | 1.25 | |
| P-023A | 129.8 | 4.5 | 130.56 | 5 | 127.4 | Not available | Not available | 127.4 | 1.25 | |
| P-024A | 130.3 | 4.5 | 130.3 | 5 | 128.2 | 1.67 | 0.83 | 128.2 | 1.25 | |
| P-025A | 128.9 | 8.58 | 129.87 | 8.58 | 127.07 | 3 | 1 | 127.07 | 2 | |
| P-026A | 129.2 | 5.5 | 128.92 | 5.5 | 126.95 | 1.67 | 0.83 | 126.95 | 1.66 | 0.83 |
| P-027A | 131.1 | 7.11 | 131.1 | 4.0 | 129.6 | 3.5 | 1.167 | 129.6 | 3.5 | 2.0 |
| | | | | | 129.6 | 3.5 | 1.167 | 129.6 | 3.5 | 0.0 |

Regulator Modification

| Regulator | Overflow Weir | | | | Regulating Sluice Gate / Orifice | | | | | |
|------------------------------------|---------------|-------|----------------|-------|----------------------------------|-------|--------|----------------|-------|--------|
| | Drawing | | Original Model | | Drawing | | | Original Model | | |
| | Crest | Width | Crest | Width | Invert | Width | Height | Invert | Width | Height |
| N-002A (modified, Verona) | 110.43 | 41 | 103 | 6 | 102.65 | 2.5 | 2.5 | 99.33 | 2 | 2 |
| N-004A/005A (modified, Herbert PL) | 114.34 | 41 | 105.55 | 6.667 | 107.06 | 2 | 2 | 103.6 | 1.5 | 1.5 |
| N-008A | 103.5 | 6 | 103.5 | 6 | 100.7 | 1.5 | 1.5 | 100.7 | 1.5 | 1.5 |
| N-009A | 103.24 | 4 | 103.24 | 4 | 102.4 | 1.66 | 0.83 | 102.4 | 1.66 | 0.83 |
| N-010A | 105.12 | 8.42 | 105.12 | 8.42 | 101.24 | 6 | 3 | 101.24 | 6 | 3 |
| | 105.12 | 8.42 | 105.12 | 8.42 | 101.24 | 6 | 3 | 101.24 | 6 | 3 |
| | 105.12 | 8.42 | 105.12 | 8.42 | | | | | | |
| N-014A (modified, Rector) | 102.56 | 5.5 | 103.66 | 5.5 | 99.97 | 1.5 | 1.5 | 101.07 | 1.5 | 1.5 |
| N-014A (modified, Saybrook) | 102.33 | 7 | 103.43 | 7 | 99.02 | 2 | 2 | 100.12 | 2 | 2 |
| N-015A (modified) | 98.67 | 14 | 98.67 | 14 | 95.67 | 3.5 | 2.5 | 95.67 | 3.5 | 2.5 |
| N-016A | 97.62 | 7 | 97.62 | 4.5 | 96 | 1.5 | 1.5 | 96 | 1.33 | 1.33 |
| N-017A | 97.8 | 8 | 97.8 | 7 | 95.2 | 1.5 | 1.5 | 95.35 | 1.33 | 1.33 |
| N-018A | 100.26 | 4 | 100.26 | 4 | 99 | 2 | 2 | 99 | 2 | 2 |
| N-022A | 98.93 | 6 | 98.93 | 6 | | | | | | |
| N-027A/029A | 102 | 4.5 | 102 | 4.5 | 96.4 | 4 | 2.33 | 96.4 | 4 | 2.33 |
| N-025A | 98.6+ | 6 | 98.6 | 8 | 93 | 4 | 2.33 | 93 | 4 | 2.33 |
| | 98.6+ | 8 | 98.6 | 8 | | | | | | |
| | 105.85 | 5 | 98.6 | 8 | | | | | | |
| | 105.85 | 5 | 98.6 | 8 | | | | | | |
| N-030A | 102.32 | 10 | 102.32 | 10 | 99.04 | 4 | 3 | 99.04 | 4 | 3 |
| N-023A | 98.54 | 7 | 98.54 | 7 | | | | | | |


Regulator Modification

| Regulator | Overflow Weir | | | | Regulating Sluice Gate / Orifice | | | | | |
|-----------|---------------|-------|----------------|-------|----------------------------------|-------|--------|----------------|-------|--------|
| | Drawing | | Original Model | | Drawing | | | Original Model | | |
| | Crest | Width | Crest | Width | Invert | Width | Height | Invert | Width | Height |
| K-001A | 120.85 | 4.5 | 120.27 | 1.5 | 119.07 | 1 | | 119 | 1 | |
| K-004A | 107.9 | 1.5 | 108 | 1.5 | 106.9 | 1 | | 107 | 1 | |
| K-006A | 99.9 | 5 | 100.9 | 10 | 98.7 | 1.5 | | 98.2 | 1.5 | |
| | 100.1 | 5 | | | | | | | | |
| K-007A | 103 | 9 | 103 | 9 | 100.2 | 3 | 1 | 100.2 | 3 | 1 |
| K-010A | 102.5 | 4 | 102.5 | 4.5 | 98.84 | 1 | 1 | 100.45 | 1 | |
| | | | | | | | | | | |
| E-001A | 101.6 | 4 | 101.6 | 4 | 99.2 | 1.25 | | 99.2 | 1.25 | |
| | | | | | | | | | | |
| H-001A | 101.2 | 4 | 101.2 | 4 | 99.8 | 1.25 | | 99.8 | 1 | |
| H-002A | 102.2 | 4 | 102.2 | 4 | 101 | 1 | | 101.2 | 1 | |
| H-003A | 103.9 | 4 | 103.9 | 4 | 101.4 | 1.25 | | 101.4 | 1.25 | |
| H-004A | 102.2 | 4 | 102.2 | 3.5 | 100.58 | 1 | | 100.58 | 1 | |
| H-005A | 100.8 | 3.5 | 100.8 | 3.5 | 99.1 | 1 | | 99.1 | 1 | |
| H-006A | 99.9 | 4 | 99.9 | 4 | 97.9 | 1 | | 97.9 | 1 | |
| H-007A | 102.4 | 4.5 | 102.4 | 4.5 | 101.2 | 1 | | 101.2 | 1 | |


Paterson Update

Original Paterson Delineation

June 2018 (Revised 03/28/19)
Page 461 of 796




Updated Paterson Delineation





Paterson Internal Regulator

June 2018 (Revised 03/28/19)
Page 462 of 796



Updated Paterson Delineation









Separated Service Area

45

Separated Service Area Added to the Model

Legend


-  PVSC Service Area
-  CSO Communities
-  Separated Communities
-  PVSC WPCF (Water Pollution Control Facility)
-  PVSC Interceptor / Sewer
-  CSO Outfall
-  Added Separated Communities



Wet Weather Operating Rules


Wet Weather SOP

Flow < 350 MGD



Wet Weather SOP


350 MGD ≤ Flow < 400 MGD



Note: During 10/7/15 to 7/7/16, CSOs were put in use at plant flow 400 MGD.


Wet Weather SOP

Flow ≥ 400 MGD




Wet Weather SOP

Flow ≥ 400 MGD, & Storage Full



Wet Weather SOP

Flow Drops to 350 MGD



Bayonne Real Time Control Rule Update


एक फुट = 0.3048 मीटर
 एक मीटर = 3.28 फुट

| Original RTC Closing Table | | |
|----------------------------|----------|--------|
| | Input ft | Output |
| Rule 1 | 0 | 0.625 |
| Rule 2 | 0.751 | 0.313 |
| Rule 3 | 1.499 | 0 |



| Updated RTC Closing Table | | |
|---------------------------|----------|--------|
| | Input ft | Output |
| Rule 1 | 0 | 0.190 |
| Rule 2 | 0.751 | 0.095 |
| Rule 3 | 1.499 | 0 |

Comparison of Original and Updated Sluice Gate Opening




PVSC H&H Model Calibration and Validation

Temporary Flow Meter

June 2018 (Revised 03/28/19)
Page 468 of 796

21 Flow Meters


- 13 outfall pipe
- 5 regulator influent
- 2 regulator effluent
- 1 interceptor



PVSC Permanent Flow Meters


Over 70 Flow Meters, 55 was analyzed for DWF and model calibration

- PVSC Interceptor: 6
- Pump Station: 6
- Combined area: 5
- Separated Area: 38




Flow Meter Diagram
Dry Weather Flow
(MGD)


June 2018 (Revised 03/28/19)
 Page 469 of 796




Rainfall Stations



| Rain Gauge Summary | | | |
|--------------------|---------------|---------------------------|----------------------------------|
| Source | RG ID | Data Time Interval (Min.) | Total Rainfall (5/20/16-8/05/16) |
| NJ Weather | Hawthorne | 5 | 6.97 |
| NJ Weather | Lyndhurst | 5 | 5.39 |
| NJ Weather | jersey City | 5 | 7.04 |
| CWOP | West Paterson | 30 | 10.4 |
| CWOP | Passaic | 15 | 8.46 |
| CWOP | Cedar Grove | 10-50 | 8.98 |
| CWOP | West Orange | 10 | 11.72 |
| NWS ASOS | Caldwell | 1 | 6.84 |
| NWS ASOS | New York | 1 | 11.23 |
| NWS ASOS | Newark | 1 | 8.47 |





Candidate Storm Events for Calibration

Rainfall Based on Newark

| Rain Start | Rain End | Duration (hr) | Depth (in) | Max Intensity (in/hr) | Average Intensity (in/hr) |
|---------------|---------------|---------------|-------------|-----------------------|---------------------------|
| 7/25/16 16:05 | 7/25/16 18:50 | 2.75 | 1.81 | 1.68 | 0.66 |
| 5/29/16 23:50 | 5/30/16 5:20 | 5.50 | 1.6 | 1.09 | 0.29 |
| 7/29/16 0:20 | 7/29/16 8:35 | 8.25 | 0.85 | 0.42 | 0.10 |
| 5/2/16 22:40 | 5/3/16 9:50 | 11.17 | 0.7 | 0.17 | 0.06 |
| 7/31/16 8:35 | 7/31/16 22:35 | 14.00 | 0.69 | 0.49 | 0.05 |
| 7/4/16 19:20 | 7/5/16 2:50 | 7.50 | 0.63 | 0.23 | 0.08 |
| 5/6/16 2:30 | 5/6/16 12:25 | 9.92 | 0.6 | 0.19 | 0.06 |
| 7/16/16 14:50 | 7/16/16 15:35 | 0.75 | 0.56 | 0.75 | 0.75 |
| 6/8/16 11:25 | 6/8/16 14:10 | 2.75 | 0.49 | 0.3 | 0.18 |
| 7/9/16 21:30 | 7/9/16 22:05 | 0.58 | 0.48 | 0.82 | 0.82 |
| 4/4/16 7:45 | 4/4/16 17:00 | 9.25 | 0.43 | 0.12 | 0.05 |

Model Calibration and Validation Goals





- Visual match
- +/- 20% volume and
- +25%/-15% peak

Major Interceptor

Calibration Results – Main Interceptor



Paterson Main Line

June 2018 (Revised 03/28/19)
Page 472 of 796



Calibration Results – Main Interceptor


Paterson Main Line: Goodness-of-Fit



Calibration Results – Main Interceptor


Passaic Chamber

June 2018 (Revised 03/28/19)
Page 473 of 796




Calibration Results – Main Interceptor

Passaic Chamber: Goodness-of-Fit




Calibration Results – Main Interceptor Second River Crossing

June 2018 (Revised 03/28/19)
Page 474 of 796




Calibration Results – Main Interceptor Second River Crossing: Goodness-of-Fit



Calibration Results – Main Interceptor


June 2018 (Revised 03/28/19)
Page 475 of 796

PVSC WPCF








Calibration Results – Main Interceptor

PVSC WPCF: Goodness-of-Fit



Separated Area




Calibration Results – Separated Area *Totowa PS*



Calibration Results – Separated Area






June 2018 (Revised 03/28/19)
Page 477 of 796

Totowa PS: Goodness-of-Fit



Calibration Results – Separated Area




Hope Ave



Calibration Results – Separated Area






June 2018 (Revised 03/28/19)
Page 478 of 796

Hope Ave: Goodness-of-Fit



Calibration Results – Separated Area




Nutley Golf Club



Calibration Results – Separated Area






June 2018 (Revised 03/28/19)
Page 479 of 796

Nutley Golf Club: Goodness-of-Fit



Calibration Results – Separated Area


Union Outlet



Calibration Results – Separated Area


June 2018 (Revised 03/28/19)
Page 480 of 796

Union Outlet





79

Total Volume (Mgal)



Peak Flow (15-min, MGD)








Combined Area

Calibration Results – Combined Area




June 2018 (Revised 03/28/19)
Page 481 of 796

Paterson 6A Influent



Calibration Results – Combined Area





Paterson 6A Influent



Calibration Results – Combined Area



June 2018 (Revised 03/28/19)
Page 482 of 796

Johnston Ave.



Calibration Results – Combined Area






Johnston Ave.



Calibration Results – Combined Area




June 2018 (Revised 03/28/19)
Page 483 of 796

South 4th St.



Calibration Results – Combined Area


South 4th St.



Calibration Results – Combined Area





June 2018 (Revised 03/28/19)
Page 484 of 796

NB Central PS.




NB Central PS

87





Calibration Results – Combined Area

NB Central PS.




NB Central PS

88







CSO Meters

Calibration Results – CSO Overflow *NE_15A*





90



Calibration Results – CSO Overflow






June 2018 (Revised 03/28/19)
Page 486 of 796

NE_15A



Calibration Results – CSO Overflow


KE_07A



Calibration Results – CSO Overflow

June 2018 (Revised 03/28/19)
Page 487 of 796


KE_07A




KE_07A

93

Total Volume (Mgal)




Peak Flow (15-min, MGD)







Calibration Results – CSO Overflow

NB_04A



NB_04A



94



Calibration Results – CSO Overflow





June 2018 (Revised 03/28/19)
Page 488 of 796

NB_04A



Calibration Results – CSO Overflow


GU_01A





Calibration Results – CSO Overflow

GU_01A

June 2018 (Revised 03/28/19)
Page 489 of 796




97



Total Overflow Volume

NE_04&05, NE_09&10, NE_14A, NE_15A, KE_07A,
BA_08A, BA_10A, NB_11A, NB_07A, NB_04A, NB_04B, GU_01A

Total Overflow Volume from Sampling Locations



Summary & Next Step

99

Summary

- **The updated PVSC H&H model includes**
 - 48 municipalities served by the PVSC WPCF
 - 2 municipalities served by the NBMUA Woodcliff WWTP
 - Dry weather flow based on 2016 flow monitoring data
 - Wet weather flow simulated as runoff from the combined areas and RDII from the separated areas
 - Current PVSC WPCF wet weather operating rules
- **The model is calibrated and validated to 2016 flow monitoring data**

100

Next Step

- Finalize model
- Address comments received
- Generate CSO flows for WQ model
- Distribute model to CSO permittees

The End

Water Quality Modeling Update

Model Evaluation Group – Session 3

Rich Isleib, HDR

September 15, 2017



CONSULTING ENGINEERS

**CDM
Smith**

HDR

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.


Agenda

- Receiving Water Data Summary
- Source Loading Approach
 - Stormwater
 - CSO
 - Rivers
- Model Calibration
- Next Steps

Receiving Water Sampling Locations





INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.




NJ Pathogen Criteria

- Primary Contact Recreation:
 - Enterococci levels shall not exceed a geometric mean of **35/100 ml**, or a single sample maximum of **104/100 ml**. (SE1 and SC)
 - Hackensack R. (upper), Hudson R. (north of Harlem R.), Raritan R., Raritan Bay
 - E. coli levels shall not exceed a geometric mean of **126/100 ml** or a single sample maximum of **235/100 ml**. (All FW2)
 - Elizabeth R., Passaic R., Raritan R.
- Secondary Contact Recreation:
 - Fecal coliform levels shall not exceed a geometric mean of **770/100 ml**. (SE2)
 - Arthur Kill (lower), Hackensack R. (mid), Hudson R., Passaic R. (mid), Rahway R.
 - Fecal coliform levels shall not exceed a geometric mean of **1500/100ml**. (SE3)
 - Arthur Kill (upper), Elizabeth R., Hackensack R. (lower), Kill Van Kull, Newark Bay, Passaic R. (lower)







INTERAGENCY ADVISORY, CONSOLIDATIVE AND/OR DECLERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



INTERAGENCY ADVISORY, CONSOLIDATIVE AND/OR DECLERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECLASSIFIED MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.




INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECLASSIFIED MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Passaic River & Tributaries, Passaic River, B6, (SE3)


June 2018 (Revised 03/28/19)
Page 496 of 796



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.




Hackensack River & Tributaries, Hackensack River, 13 (SF 1)




INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.






INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECLASSIFIED MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECLASSIFIED MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Newark Bay & Tributaries, Newark Bay, 17, (SE3)


June 2018 (Revised 03/28/19)
Page 498 of 796



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.




Newark Bay & Tributaries, Arthur Kill, 21, (SE3)



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.






INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DECISIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Hudson River: Upper Bay, Hudson River, 31, (SE2)




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DECISIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Hudson River, Upper Bay, Hudson River, 33, (SE2)


June 2018 (Revised 03/28/19)
Page 500 of 796



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.




Hudson River, Upper Bay, Kill Van Kull, B12, (SE3)




INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.





INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



INTERAGENCY ADVISORY, CONFIDENTIAL AND/OR DECORATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A. 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.