





PVSC – Long Term Control Plan Modeling Evaluation Group – Session 4

Hydrologic and Hydraulic Model Overview

Greeley and Hansen LLC December 5, 2018

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS

Agenda

- Overview of PVSC H&H Model
 - Model Service Area and Network
 - Wet Weather Operating Rules
- H&H Model Calibration & Validation
- H&H Model Application






PVSC H&H Model Overview

3

Sewer Systems

- Passaic Valley Sewerage Commission
 - 48 municipalities
 - 8 CSO municipalities (0.9 million residents)
 - 1.5 million residents
 - 147 mi² service area
 - 22 mile interceptor sewer
 - 330 mgd WPCF
- NBMUA Woodcliff WWTP
 - 2 CSO municipalities
 - 3 mgd Woodcliff WWTP
 - 477 acres (368 acres in North Bergen)





CSO Communities

Municipality	VA/VA/TD	Donulation	Area	Sewerage	CCO-
Municipality	WWTP	Population	(mi²)	(miles)	CSOs
Bayonne		63,000	5.8	94	30
East Newark	PVSC WRRF	2,400	0.1	2	1
Harrison		13,600	1.3	18	7
Jersey City		247,600	14.8	230	21
Kearny		40,700	6.5	52	5
Newark		277,100	22.3	579	18
North Bergen		52,600	4.5	59	7
Paterson		146,200	8.7	164	23
Guttenberg	NBMUA	11,200	0.2	5	1
North Bergen	Woodcliff	8,200	0.7	8	1
Total		862,600	84	1,211	114



5

Entire PVSC H&H Model

Subcatchment: 1121

Nodes (4216)


Manhole: 4081Outfall: 123Storage: 12


Link (4413)


Conduit: 4039Flap Valve: 101Orifice: 42Pump: 16


Sluice: 95 (34 variable)


Weir: 120














North Bergen Model

Subcatchment: 41

Nodes (178)

Manhole: 166

Outfall: 9

Storage: 3

Link (199)

Conduit: 183

Flap Valve: 0


Orifice: 0


Pump: 3


- - - -


Sluice: 5

Weir: 8













Wet Weather Operating Rules

Wet Weather SOP

Flow < 350 MGD




Wet Weather SOP 350 MGD ≤ Flow < 400 MGD



Note: During 10/7/15 to 7/7/16, CSOs were put in use at plant flow 400 MGD.




Wet Weather SOP




Wet Weather SOP

Flow ≥ 400 MGD, & Storage Full



Wet Weather SOP Flow Drops to 350 MGD






PVSC H&H Model Calibration and Validation

Temporary Flow Meters (April to August 2016)

21 Flow Meters

- 13 outfall pipe
- 5 regulator influent
- 2 regulator effluent
- 1 interceptor



PVSC Permanent Flow Meters


Over 70 Flow Meters, 55 was analyzed for DWF and model calibration


- PVSC Interceptor: 6

- Pump Station: 6


- Combined area: 5

- Separated Area: 38





Rainfall Station Assignment



Candidate Storm Events for Calibration

Rainfall Based on Newark

Rain Start	Rain End	Duration (hr)	Depth (in)	Max Intensity (in/hr)	Average Intensity (in/hr)	
7/25/16 16:05	7/25/16 18:50	2.75	1.81	1.68	0.66	
5/29/16 23:50	5/30/16 5:20	5.50	1.6	1.09	0.29	
7/29/16 0:20	7/29/16 8:35	8.25	0.85	0.42	0.10	
5/2/16 22:40	5/3/16 9:50	11.17	0.7	0.17	0.06	
7/31/16 8:35	7/31/16 22:35	14.00	0.69	0.49	0.05	
7/4/16 19:20	7/5/16 2:50	7.50	0.63	0.23	0.08	
5/6/16 2:30	5/6/16 12:25	9.92	0.6	0.19	0.06	
7/16/16 14:50	7/16/16 15:35	0.75	0.56	0.75	0.75	
6/8/16 11:25	6/8/16 14:10	2.75	0.49	0.3	0.18	
7/9/16 21:30	7/9/16 22:05	0.58	0.48	0.82	0.82	
4/4/16 7:45	4/4/16 17:00	9.25	0.43	0.12	0.05	



Model Calibration and Validation Goals

Visual match

29


- +20/-10% volume and
- +25%/-15% peak






Major Interceptor


Calibration Results – Main Interceptor 380 of 476 Paterson Main Line



Calibration Results – Main Interceptor Paterson Main Line: Goodness-of-Fit










Calibration Results – Main Interceptor 381 of 476


Passaic Chamber



Calibration Results – Main Interceptor Passaic Chamber: Goodness-of-Fit









Calibration Results – Main Interceptos 382 of 476


Second River Crossing




Calibration Results – Main Interceptor Second River Crossing: Goodness-of-Fit










Calibration Results – Main Interceptor 383 of 476 PVSC WPCF



Calibration Results – Main Interceptor PVSC WPCF: Goodness-of-Fit











Separated Area


Calibration Results – Separated Area *Totowa PS*




Calibration Results – Separated Area 385 of 476 Totowa PS: Goodness-of-Fit




Calibration Results – Separated Area Hope Ave




Calibration Results – Separated Area 386 of 476 Hope Ave: Goodness-of-Fit




Calibration Results – Separated Area Nutley Golf Club




Calibration Results – Separated Area 387 of 476 Nutley Golf Club: Goodness-of-Fit



Calibration Results – Separated Area *Union Outlet*




Calibration Results – Separated Area 388 of 476 *Union Outlet*







Combined Area


Calibration Results – Combined Area 9 18 (Revised 04/09/19) Paterson 6A Influent



Calibration Results – Combined Area Paterson 6A Influent












Calibration Results – Combined Area ge 390 of 476 South 4th St.




Calibration Results – Combined Area South 4th **St.**










Calibration Results – Combined Area 991 of 476 NB Central PS.




Calibration Results – Combined Area NB Central PS.











Calibration Results – Woodcliff WWTP Page 392 of 476 Influent Flows






CSO Meters

NE_15A




Calibration Results – CSO Overflow

NE_15A




Calibration Results – CSO Overflow Page 394 of 476

KE_07A




Calibration Results – CSO Overflow

KE_07A





Calibration Results – CSO Overflow Page 395 of 476 NB_04A




Calibration Results – CSO Overflow

NB_04A












Calibration Results – CSO Overflow Page 396 of 476 GU_01A



Calibration Results – CSO Overflow *GU_01A*










Total Overflow Volume

NE_04&05, NE_09&10, NE_14A, NE_15A, KE_07A, BA_08A, BA_10A, NB_11A, NB_07A, NB_04A, NB_04B, GU_01A

Total Overflow Volume from Sampling Locations




GREELEY AND HANSEN

65

Summary

- The updated PVSC H&H model includes
 - 48 municipalities served by the PVSC WPCF
 - 2 municipalities served by the NBMUA Woodcliff WWTP
 - Dry weather flow based on 2016 flow monitoring data
 - Wet weather flow simulated as runoff from the combined areas and RDII from the separated areas
 - Current PVSC WPCF wet weather operating rules
- The model is calibrated and validated to 2016 flow monitoring data





PVSC H&H Model Application

67

PVSC H&H Model Application

- Typical Year Simulation
- CSO Control Alternative Simulation
- Generate CSO flows for WQ model



	000		Overflow		000	Overflow			000	Journal (Revised 04/09/19)			evised 04/09/19)
	CSO ID	Volume	# per	Duration	CSO	Volume	# per	Duration	CSO	Volume	# per	Duration	Page 399 of 476
		(MG)	Year	(Hour)	שו	(MG)	Year	(Hour)	עו	(MG)	Year	(Hour)	I ngo o s s s s s s s s s s s s s s s s s s
	PT001	24.9	38		EN001	16.6	37		NB003	171	51	286	l
	PT003	1.8	20	27					NB005	30.1	55	255	l
	PT005	6.5	27		HR001	1.3	30		NB006	0.0	0	0	
	PT006	76.6	38		HR002	2.8	34		NB007	6.6	32	98	
	PT007	42.8	37		HR003	13.6	33		NB008	15.1	30	82	
	PT010	9.7	26		HR005	18.8	36		NB009	25.6	45	175	l
	PT013	11.4	29		HR006	6.7	30		NB010	1.2	25	41	
	PT014	0.1	5		HR007	13.3	49		NB011	5.1	37	121	l
	PT015	0.5	18	11					NB014	0.5	7	6	
	PT016	12.3	30	55									
	PT017	8.7	33		KE001	3.9	33	54	BA001	373.3	71	533	
	PT021	5.0	30		KE004	12.3	58	177	BA002	8.7	9	14	
	PT022	17.4	33		KE006	118.8	63		BA003	11.2	34	108	
	PT023	3.0	17		KE007	86.0	36	165	BA004	0.0	3	1	
	PT024	8.3	31		KE010	26.0	54	144	BA006	16.0	37	138	
	PT025	87.9	56	120	115000		40		BA007	72.1	37	125	
	PT026	0.5	15		NE002	91.5	46	268	BA008	10.0	34	88	l
	PT027	41.0	46		NE003	0.0	0	0	BA009	4.2	33	58	l
	PT028	10.0	28		NE004	1.4	23	29	BA010	17.3	52	178	
	PT029	92.4	48		NE005	21.2	43 52	249	BA011	5.9	34	71	l
	PT030	4.5	4	-	NE008	93.3		327	BA012	14.0	57	142	
	PT031 PT032	9.5 30.2	27		NE009 NE010	163.7 163.7	42 42	210 210	BA013	0.8	33 43	35 127	
	1032	30.2	32		NE010 NE014	180.1	42 52	387	BA014 BA015	12.7 46.6	43 54	231	
					NE014 NE015	74.7	43		BA015	6.5	54 48	130	
PVSC H&H M	ode	l Typi	cal Y		NE015	54.7	43	252	BA017	54.2	62	350	l
					NE016	107.4	51	281	BA018	14.6	58	232	
CSO Overflow	v Vo	lume,			NE017	75.5	53	326	BA019	38.8	35	112	
	•					45.7	69	262	BA019	10.1	33	65	
Frequency, & Duration					NE022 NE023	16.8	35	108	BA020	62.9	54	212	
					NE025	58.2	16	30	BA021	0.0	0	0	
					NE025	16.6	17	25	BA024	0.0	3	2	
					NE020	11.3	17	39	BA024	1.3	9	4	
					NE030	10.4	19	21	BA028	0.0	0	0	
					TYLU00	10.7	10	41	BA029	6.8	24	41	
									BA030	1.5	16	40	NOTE IN
									BA034	0.1	7	4	NSEN
69									DA027	0.1	0	0	



The End

Hydrodynamic Modeling

Northern NJ CSO Long-Term Control Plan

December 5, 2018 Nicholas Kim, HDR

Agenda

- Calibration Period: 2016 2017
- Model Calibration
 - Temperature
 - Salinity
 - Note: Tidal elevation and current calibration results were presented in March 2017 MEG

Model Input

- Tidal Forcing:
 - Mid-Atlantic Bight: Global Tidal Prediction Program and observed low frequency variation
- Freshwater Sources:
 - Rivers: USGS gages (28)
 - CSOs: NJ and NYC
 - Stormwater : CDM Smith landside model
 - STP
- Meteorological Forcing: North America Regional Reanalyses (NARR) Model: 30km resolution; 3-hourly
 - Winds
 - Air temperature
 - Barometric pressure
 - Relative humidity
 - Shortwave solar radiation







- CSO
- STP



GREELEYAND HANBEN CDM Smith


Available Calibration Data


- NJ Harbor Dischargers Group: 2003-2017 (T/S)*
- NJ LTCP WQ Sampling Program: 2016 2017 (T/S)
- NYC DEP Harbor Survey Program: 1980's 2017 (T/S)
- HRECOS in-situ monitoring data: T/S
- Meadowlands Environmental Research Institute (MERI):
 T/S (grab and moored): 2008 present
 - * At times, the quality of NJ Harbor Discharge Group salinity data are questionable.

Salinity Results

- Lower Passaic River
- Hackensack River
- Newark Bay
- Kill van Kull
- Arthur Kill
- Raritan Bay
- Hudson River/Upper Bay


GREELEYAND HANSEN CDM Smith








RUN31: /pine3/pvsc0030/HYDRO/PLOTS/TANDS/PASts.gdp DATE: 9:24.2018 TIME: 11:18:16

























1 \7





/pine3/pvsc0030/HYDRO/PLOTS/TANDS/HUDts.gdp DATE: 9:24/2018 TIME: 11:17:56



Temperature Results

- Newark Bay
- Hudson River





Summary of Hydrodynamic Model Calibration

- Model has been configured for 2016-2017 with comprehensive model input and compared with data from various sources
- Reasonable reproduction of hydrodynamics in the regions (i.e. water temperature, and salinity) during dry periods and wet events.
- Setup 2004 Projection Conditions

23 GREELEYAND HANBEN CDM FOR


Water Quality Modeling Update

Model Evaluation Group – Session 4

Rich Isleib, HDR

Docombor E 2019







Agenda

- Model Kinetics
- Model Inputs
 - Source Loading
 - Stormwater
 - CSO
 - Rivers
 - Other
 - Bacteria Ratios
 - Constants
- Model Calibration/Validation
 - Time Series
 - Annual
 - Events
 - Probability
- Baseline

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.

NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.

OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Pathogen Model Kinetics

$$N = N_0 \exp(-KBt)$$

$$K_B = [0.8 + 0.006(\%seawater)]1.07^{(T-20)}$$

+
$$\alpha I_0(t)/K_eH[1-exp(-K_eH)]$$

N = Bacteria concentration

 K_B = Bacteria loss rate

T = Temperature (°C)

 α = proportionality constant


 I_0 = Surface solar radiation

t = time

K_e = Extinction coefficient (/m)

H = Depth(m)

 V_s = Net settling rate (m/d)




Pathogen Sources


- Source Loading
 - Stormwater
 - CSO
 - Rivers
 - Other
 - Bacteria Ratios



Stormwater Flows

- Flows derived from an InfoWorks model
- Loads were based on constant concentrations






Landside Path 2018 (Revised 04/09/19) Page 414 of 476 Concentration Stations

- Stormwater 8 locations
 - Low Density Residential (4)
 - High Density Residential (2)
 - Commercial / Industrial (2)
- CSO 11 Locations/(18 Planned)
 - Paterson (2)
 - Newark (4)
 - Harrison (2)
 - Kearny (1)
 - Bayonne (2)

Stormwater Pathogen Concentrations




CSO Loading Calculations

- The Mass Balance approach was used to assign loading to the CSOs
- The hydraulic models provided flow and the sanitary/stormwater flow fractions.
- CSO concentrations were calculated using sanitary and stormwater concentrations.
- Estimated CSO concentrations were compared to CSO concentration data.

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

8 GREELEY AND HANSEN CDM Smith


PVSC WWTP Pathogen Influent Concentrations



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.




CSO Mass Balance Check




Smith | JX

GREELEY AND HANSEN CDM Smith

CSO Mass Balance Check




CSO Mass Balance Check




CSO Mass Balance Check

GREELEY AND HANSEN CDM Smith



CSO Mass Balance Check



INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



River Loads

- Dry-weather
 - "Monte Carlo"
 - **Data Interpolation**
 - Data Average
- Wet-weather
 - **MLE**
 - Concentration vs. Flow

River Boundaries, Stations used for Loading Calculations										
		2004			2016			2017		
Waterbody	Data Station	Data EC	Data FC	Data EN	Data EC	Data FC	Data EN	Data EC	Data FC	Data EN
Hudson River	31	N	Υ	Υ	N	Υ	Υ	N	Υ	Υ
Hackensack River	13	N	Υ	Υ	Υ	Υ	Υ	Υ	Υ	Υ
Passaic River	1	N	Υ	Υ	Υ	Υ	Υ	Υ	Υ	Υ
Saddle River	6	N	Υ	Υ	Υ	Υ	Υ	Υ	Υ	Υ
Raritan River	25	N	Υ	Υ	Υ	Υ	Υ	Υ	Υ	Υ

Dry-weather Loads

- Clear need for dry-weather sources based on water quality data
- Assumed sanitary flow concentrations
- 150 gal/day-person

Waterbody	Equivalent People				
Passaic River	405				
Hackensack River	945				
Newark Bay	765				
Elizabeth River	105				
Kill van Kull	300				
Arthur Kill	360				
Hudson River	405				
Upper Bay	1,380				

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.


NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.

OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.


16 GREELEY AND HANSEN CDM Smith


Dry-weather Loads – Passaic River







Dry-weather Loads – Newark Bay





Dry-weather Loads – Hudson River





Other Loads

- **WWTP**
 - Fecal coliform = 200 cfu/100mL
 - E. Coli = 100 cfu/100mL
 - Enterococci = 100cfu/100mL
- Base flow from stormwater model
 - Fecal Coliform = 10 cfu/100mL
 - E. Coli = 5 cfu/100mL
 - Enterococci = 1 cfu/100mL
- **Hudson River**
 - Artificial load created near study area so that upstream loads did not have to be estimated


Pathogen Loading Ratios

Source	FC:ENT Ratio
Sanitary	5.9
Stormwater	0.4
CSO	0.4-4.6
Hudson River	2.7
Hackensack River	2.7
Passaic River	0.5
Raritan River	0.5

24 GREELEY AND HANSEN CDM F)

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Calibration Constants and Parameters



Calibration Constants and Parameters

Constant	F. Coliform & E. Coli	Enterococci		
Base Mortality Rate	0.2/day	0.68/day		
Temperature Coefficient	1.07	1.07		
Seawater Die-off Rate	0.01875/day	0.01875/day		
Solar Radiation Die-off Rate	0.003/ly-day	0.00824/ly-day		

26 GREELEY AND HANSEN CDM Smith

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS. NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Calibration Rates






Fig. 1 - Patterns found in data on E. coli inactivation in waters. Blaustein et al., 2013

Receiving Water Sampling Locations




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J. S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

















ILS.

GREELEY AND HANSEN CDM Smith

NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

NJ Pathogen Criteria

- Primary Contact Recreation:
 - Enterococci levels shall not exceed a geometric mean of 35/100 ml, or a single sample maximum of 104/100 ml. (SE1 and SC)
 - Hackensack R. (upper), Hudson R. (north of Harlem R.), Raritan R., Raritan Bay
 - E. coli levels shall not exceed a geometric mean of **126/100 ml** or a single sample maximum of **235/100 ml**. (All FW2)
 - Elizabeth R., Passaic R., Raritan R.
- Secondary Contact Recreation:
 - Fecal coliform levels shall not exceed a geometric mean of 770/100 ml. (SE2)
 - Arthur Kill (lower), Hackensack R. (mid), Hudson R., Passaic R. (mid), Rahway R.
 - Fecal coliform levels shall not exceed a geometric mean of 1500/100ml. (SE3)
 - Arthur Kill (upper), Elizabeth R., Hackensack R. (lower), Kill Van Kull, Newark Bay, Passaic R. (lower)

NJ Pathogen Criteria


The Department shall **utilize a geometric mean to assess compliance** with the bacterial quality indicators at N.J.A.C.7:9B-1.14(d)1ii-iii. The geometric mean shall be calculated using a minimum of five samples collected over a thirty-day period. The **single sample maximum shall be used for beach notification** in accordance with N.J.A.C. 8:26 and to identify where additional ambient water quality sampling is needed to calculate a geometric mean.

GREELEY AND HANSEN CDM. Smith

INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.

NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.

OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.



Assessment of Model's Ability to Calculate Attainment

- Passaic River GM Criterion Mid-depth
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?

Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
B24	FW2	126	Υ	Υ	Y	Υ
2	FW2	126	Υ	Υ	-	-
3	FW2	126	Υ	Υ	Y	Υ
B22	FW2	126	Υ	Υ	-	-
4	FW2	126	Υ	Υ	Y	Υ
5	FW2	126	Υ	Υ	Y	Υ
7	FW2-SE2	126	Υ	Υ	Y	Υ
8	FW2-SE2	126	Υ	Υ	Υ	Υ

38 GREELEY AND HANSEN CDM Smith


Assessment of Model's Ability to Calculate Attainment


- Passaic River SSM Criterion Mid-depth
- Percent of Time Data and Model Exceed Criterion (Using imaginary 30-day period)


Station	Class	Criterion	2016 Data	2016 Model	diff	2017 Data	2017 Model	diff
B24	FW2	235	33.1	47.8	14.7	73.8	59.6	14.2
2	FW2	235	46.5	59.0	12.5	NA	NA	
3	FW2	235	70.4	37.7	32.7	67.8	56.1	11.7
B22	FW2	235	53.0	38.0	15.0	NA	NA	
4	FW2	235	50.6	60.7	10.1	61.9	42.1	19.8
5	FW2	235	44.0	49.7	5.7	46.8	30.5	16.3
7	FW2-SE2	235	80.5	75.0	5.5	88.1	55.1	33.0
8	FW2-SE2	235	77.1	79.2	2.1	91.9	62.5	29.4


Model Calibration













Assessment of Model's Ability to Calculate Attainment

- Passaic River GM Criterion Mid-depth
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?

Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
7	FW2-SE2	770	Υ	N (49)	N	N
8	FW2-SE2	770	N	Υ	Υ	Υ
10	SE3	1500	N	N	Υ	N (49)
11	SE3	1500	N	N	-	-
В6	SE3	1500	N	N	Υ	Υ
12	SE3	1500	-	-	-	-









47 GREELEY AND HANSEN CDM Smith


INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.
NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.
OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.


Model Calibration


GREELEY AND HANSEN CDM Smith














Model Calibration

Hackensack River & Tributaries









Model Calibration








58 GREELEY AND HANSEN CDM Smith

OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

SE2

Hackensack River & Tributaries Hackensack River

Station: 14



Fecal Coliform (cfu/100mL) E. Coli (cfu/100mL) 10⁶ 10 10⁵ 10 10 Event #1 10³ 10³ June 6-8, 2016 10 10 10¹ 10 10 10 10⁶ 10 10 10⁵ 10⁴ 10 Event #3 Jan 24-26, 2017 10³ 10³ 10² 10² 10 10 10 10 2 2 10 10⁶ 10⁵ 10⁵ 10⁴ 10⁴ Event #4 10 10 April 26-28, 2017 10² 10² 10 10 10 10 Days since beginning of event Model Result Surface Layer Model Result Mid-depth Layer Model Result Bottom Layer Surface Data Mid-depth/Bottom Data

Run: KEBS4, Rivers = Monte Carlo / Wet Weather MLE KCL=0.00300, KCBC=0.2

NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

.......RIALS.

60 GREELEY AND HANSEN CDM Smith

NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.


Assessment of Model's Ability to Calculate Attainment


- Hackensack River GM Criterion Mid-depth
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?


Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
13	SE1	35	N	N	N	N
B1	SE1	35	Υ	Υ	Υ	Υ
B2	SE1	35	Υ	Υ	Υ	Υ
B11	SE2	770	N	N	-	-
В3	SE2	770	N	N	=	-
B4	SE2	770	N	N	-	-
14	SE2	770	-	-	N	N
В7	SE2	770	N	N	-	-
15	SE2	770	N	N	N	N
16	SE3	1500	-	-	-	-


62 GREELEY AND HANSEN CDM Smith













Newark Bay & Tributaries 2016 / 2017







Assessment of Model's Ability to Calculate Attainment


- Newark Bay GM Criterion Mid-depth
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?


Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
17	SE3	1500	N	N	N	N
B10	SE3	1500	N	N	-	-
18	SE3	1500	N	N	N	N
B17	SE3	1500	-	-	-	-
19	SE3	1500	N	N	N	N

70 GREELEY AND HANSEN CDM Smith










73 GREELEY AND HANSEN CDM Smith



Assessment of Model's Ability to Calculate Attainment

- Elizabeth River GM Criterion Mid-depth
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?

Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
B16	FW2	126	Υ	Υ	-	-
B14	FW2	126	Υ	Υ	-	-
B13	SE3	1500	Υ	N	-	-
20	SE3	1500	N	N	Υ	Υ

Assessment of Model's Ability to Calculate Attainment


- Elizabeth River SSM Criterion Mid-depth
- Percent of Time Data and Model Exceed Criterion (Using imaginary 30-day period)


Station	Class	Criterion	2016 Data	2016 Model	diff
B16	FW2	235	91.1	80.8	10.3
B14	FW2	235	86.6	70.7	15.9

76 GREELEY AND HANSEN CDM Smith

Model Calibration













82 GREELEY AND HANSEN CDM Smith











Assessment of Model's Ability to Calculate Attainment

- Arthur Kill– GM Criterion Surface
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?

Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
21	SE3	1500	N	N	N	N
23	SE3	1500	N	N	N	N
24	SE3	1500	N	N	N	N
B15	SE2	770	N	N	N	N

Assessment of Model's Ability to Calculate Attainment


- Raritan Bay GM Criterion Surface
- Do Data and Model Exceed Criterion (Using imaginary 30-day period)?


Station	Class	Criterion	2016 Data	2016 Model	2017 Data	2017 Model
28	Shellfish	35	N	N	N	N
29	Shellfish	35	N	N	N	N
30	Shellfish	35	N	N	N	N

88 GREELEY AND HANSEN CDM Smith


Model Calibration














NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ. OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.


92 GREELEY AND HANSEN CDM Smith


HUDSON RIVER SE2 Station: 32 Caliform cfu/100mL 10 10 Fecal 0.00.00 10 Enterococci cfu/100mL 10 10 10 10 10 cfu/100mL 10 Coli 10 Probability Model at Surface Model at Mid-Depth Model at Bottom Model Results during data sampling hours only











Calibration/Validation Conclusions

- The hydrodynamic model successfully reproduces the observed temperature and salinity within the area of interest during the calibration/validation periods.
- The receiving water model generally reproduces the observed fecal coliform, enterococci and E. coli concentrations within the project area during the calibration/validation periods.
- The receiving water model, as developed, will be a useful tool for comparing water quality improvements associated with CSO control alternatives.
- The model can be used to assess attainment of water quality criteria, but is more suited to assess relative attainment of alternatives than absolute attainment.

Projection Runs

- Baseline
- Gap Analysis (100% CSO Removal)
- Component Analysis
 - NYC Sources
 - NJ CSOs
 - NJ Non-CSOs
 - Upstream/Downstream Boundary Conditions
 - Dry-Weather Sources
- CSO Control Alternatives
 - Permittee Related (3)
 - Area-Wide
 - Final Selected Plan




INTERAGENCY ADVISORY, CONSULTATIVE AND/OR DELIBERATIVE MATERIALS.

NOT SUBJECT TO DISCLOSURE UNDER N.J.S.A 47:1A-1 ET SEQ.

OR THE COMMON LAW RIGHT TO INSPECT PUBLIC RECORDS.

Baseline Conditions

- 2004 Meteorological Conditions
- 2015 Infrastructure
- River Concentrations at Existing Conditions
- Dry-weather loading as is



APPENDIX C

Subcatchment Characteristics

Appendix B:

1. Combined Subcatchment Characteristics (Baseline Model)

Subcatchment ID	Total area (acre)	Width (ft)	% Imperv.	Effective % Imperv.	Slope (%)	Manning's N _pervious	Manning's N _impervious	Depression Storage_ pervious (in)	Depression Storage_ impervious (in)	% of Impervious without Depression Storage	initial	limiting	Horton decay (1/hour)
GU_C1R1C2	33.868	248.3	87.1%	43.6%	0.5	0.05	0.02	0.1	0.05	25%	5	2	2
GU_C3	5.28	81.4	89.1%	44.6%	0.5	0.05	0.02	0.1	0.05	25%	5	2	2
GU_R2	51.426	319	86.4%	43.2%	0.5	0.05	0.02	0.1	0.05	25%	5	2	2
GU_R3	20.439	183.4	80.8%	40.4%	0.5	0.05	0.02	0.1	0.05	25%	5	2	2
NB_1C_1	122.797	537.8	72.8%	36.4%	3	0.05	0.02	0.1	0.05	25%	5	2	2
NB_1C_2	18.315	171.7	52.4%	22.2%	3	0.05	0.02	0.1	0.05	25%	5	2	2

2. RTK Values for the Separate Subcatchments

Subcatchment ID	Total area (acre)	R1	Т1	K1	R2	Т2	K2	R3	Т3	К3
NB_RiverRoad	39.2	0.001	1.000	2.000	0.001	2.000	2.000	0.001	3.000	2.000
GU_C4	13.4	0.001	1.000	2.000	0.001	2.000	2.000	0.001	3.000	2.000

APPENDIX D

NJDEP Comment Letter Dated October 11, 2018

Email from NJDEP to PVSC Dated December 06, 2018 Granting 45 day Extension



State of New Jersey

PHIL MURPHY
Governor

SHEILA OLIVER

Lt. Governor

DEPARTMENT OF ENVIRONMENTAL PROTECTION Mail Code – 401-02B

Water Pollution Management Element Bureau of Surface Water Permitting P.O. Box 420 – 401 E State St Trenton, NJ 08625-0420

Phone: (609) 292-4860 / Fax: (609) 984-7938

CATHERINE R. McCABE

Commissioner

October 11, 2018

Frank Pestana, Executive Director North Bergen Municipal Utilities Authority 6200 Tonnelle Avenue North Bergen, NJ 07047 Alberto Cabrera, Town Clerk Town of Guttenberg 6808 Park Avenue Guttenberg, NJ 07093

Re: Technical Comments on "Service Area System Characterization Report"

North Bergen Municipal Utilities Authority, NJPDES Permit No. NJ0029084

Town of Guttenberg, NJPDES Permit No. NJ0108880

Dear Permittees:

Thank you for your submission dated June 2018 as submitted cooperatively by both parties above. The New Jersey Department of Environmental Protection (the Department or NJDEP) acknowledges that North Bergen Municipal Utilities Authority (NBMUA) and the Town of Guttenberg have committed to a single, coordinated Long Term Control Plan. This report contains the appropriate certification statements as indicated in the Department's letter dated July 10, 2018.

NBMUA Woodcliff STP and the Town of Guttenberg submitted a work plan for the System Characterization Report on December 18, 2015 for which the Department provided comments on February 22, 2016. A revised work plan submission was dated March 22, 2016 and was approved by the Department on April 11, 2016.

This letter serves to provide technical comments on your submission.

Overall Objectives of the Sewer System Characterization

The required information for the Sewer System Characterization is included in the NJPDES CSO permit at Combined Sewer Management (CSM) Part IV.G.1. In order to provide a backdrop to some of the technical issues identified in this letter, the Department would like to note the objectives of modeling in relation to the Sewer System Characterization as contained in EPA's Guidance for Long-Term Control Plans (EPA 832-B-95-002). Specifically, once the model is calibrated and verified, the primary objectives of Combined Sewer System (CSS) modeling applications include:

- To predict overflow occurrence, volume, and, in some cases, quality for rain events other than those which occurred during the monitoring phase. These can include a storm event of large magnitude (long recurrence period) or numerous storm events over an extended period of time.
- To predict the performance of portions of the CSS that have not been extensively monitored.

- To develop CSO statistics, such as annual number of overflows and percent of combined sewerage captured as described in the CSO Control Policy.
- To optimize CSS performance as part of Nine Minimum Control (NMC) implementation. In particular, modeling can assist in locating storage opportunities and hydraulic bottlenecks and demonstrate that system storage and flow to the POTW are maximized.
- To evaluate and optimize control alternatives, from simple controls described under the NMC to more complex controls proposed in a municipality's LTCP. An example of a simple control would be to raise weir heights to increase in-line storage. The model can be used to evaluate the resulting reductions in CSO volume and frequency.

NJDEP Technical Review

In light of the above objectives, the Department's comments are as follows:

General Comments

Comment 1: Section I.3, Page 86-88, Subcatchment Area. How was it determined that the number of subcatchments was sufficient to represent the service area for both North Bergen and Guttenberg? Please provide a table with all sub-catchment input parameters for the modeled areas for <u>each</u> subcatchment. The table should include the following parameters: Surface Area, Basin Width, Percent Impervious and Directly Connected Impervious Area (Effective Impervious), Land Slope, Manning's Roughness Coefficients, Infiltration Coefficients and Depression Storage.

Comment 2: Table I-9, Page 98. The table does not provide the duration of overflows. The main objective of running the H&H model is to quantify volume, frequency, and duration of discharge, please refer to the permit requirement at Part IV.G.1.d.iii. Also, prior to the table it is stated that the duration for each discharge can be found in the monthly discharge monitoring reports (DMRs). This statement is confusing and should be deleted since these results are for the typical year which predated any DMR data.

Comment 3: CSO overflow volume is estimated for the typical year 2004, with an average rainfall depth of 48.37 inches, which is significantly less than the previously estimated CSO volume in historic studies for the typical year 1988 with a significantly less rainfall depth. Please provide clarification on how and why there is such a discrepancy in the estimated CSO volume. It is suggested that you re-run the model using the 1988 rainfall with the updated model, provide the results, and provide a comparison analysis.

Comment 4: Part IV.G.1.b of the permit requires a thorough review of the entire collection system that conveys flows to the Woodcliff STP, including areas of sewage overflows. Therefore, the report shall include a discussion of areas that are prone to flooding based on observed and reported incidents, including dates of occurrence, type of storm events that caused the flooding, and antecedent conditions, if known.

Comment 5: Please provide a pie chart depicting the total runoff generated from the NBMUA/Guttenberg combined sewer area and assumed water loss, i.e., water budget. For example, please provide estimated quantities of the total runoff, volume diverted to the combined sewer, direct runoff to nearby receiving waterbodies, evaporation, infiltration, etc.

Specific Comments

Comment 6: Section C.1, Page 29, Wastewater Treatment Facilities. Regarding the re-rating of the treatment plant, while the Department has issued a NJPDES permit modification to authorize the higher flow of 3.46 MGD, please clarify the timing of any plant re-rating. This has a bearing on the Evaluation of Alternatives as due on July 1, 2019.

Comment 7: Table E-2, Page 40. The report cited that a dry weather flow analysis was performed on the Woodcliff STP plant influent flow. Please clarify how the values in Table E-2 were determined and provide the data that was utilized to populate the table. For example, do these values represent an average? In addition, please clarify why there was insufficient information to differentiate the diurnal pattern between weekends and weekdays, given that the STP has an influent flow meter. Finally, please describe how the diurnal patterns were modeled.

Comment 8: Section E.4, Page 41, WWF Analysis. While the methodology used to quantify the wet weather flow is acceptable, the report does not provide a sufficient detailed analysis of the wet weather flow at all monitoring stations. Please include in the appendix all monitoring stations where wet weather flow analyses were conducted.

Comment 9: Table E-3, Page 42. Table E-3 outlines the rainfall events used in the model calibration/validation. First, specify the location of the rain gauge(s) of these rainfall events. Also, please clarify how these rainfall events compare to rainfall captured at other stations within the system.

Comment 10: Table E-3, Page 42. Table E-3 lists the rainfall events selected for model calibration/validation. Please describe the selection process. Please provide the data in tabular format that was utilized to populate Table E-3.

Comment 11: Table E-3, Page 42. Additional justification is needed for selecting the July 31, 2016 rainfall event. This event has the longest duration, 14 hours. Also, both rainfall depth and average intensity are extremely low compared to other shorter events. It is recommended that the July 29, 2016 rainfall event be used as the long duration event and add one of the events listed in Table E-4 for short duration, i.e., July 16, 2016 or July 9, 2016.

Comment 12: Section E.7, Page 42, Rainfall Monitoring Locations and Analysis. This section references that the "New York rain gauge" rainfall data as obtained from NWS ASOS was used as the source for the rainfall analysis. Please specify which New York rain gauge was used.

Comment 13: Section G.3.2, Page 57, Sewer System Quality Sampling Locations. The report states that:

"The original Quality Assurance Project Plan (QAPP) targeted two CSO locations in the Guttenberg and North Bergen service area and eight stormwater locations that were distributed throughout the PVSC region by municipality and land use. The CSO locations can be seen in **Figure G-1**. The goal of the sampling protocol was to obtain three-wet weather events of sufficient depth, intensity, and duration for valid model calibration at each targeted location. This was the case for all eight stormwater locations; however, only one of the two CSO locations was sampled (location 001A), with the other not sampled at all due to access or other logistical issues (location 004A)."

Please discuss or reference other sections of the report as to how the lack of such data has been addressed and the model was successfully calibrated and validated.

Comment 14: Section G.3.5, Page 59, System Characterization and Landside Modeling QAPP Goals. Please ensure that the listed objectives of the system characterization and modeling agree with these objectives outlined in the Work Plan. The report should be structured to address the objectives of the Work Plan.

Comment 15: Section G.4, Page 59, Sewer System Quality Results. Under Sewer System Quality Results the report states:

"CSO sampling teams were deployed to CSO sampling location 001A on 7/13/2017 and 8/7/2017 for precipitation events, but no overflows occurred. However, the sampling teams followed the sampling protocols and collected one pre-overflow sample during each event. The results are presented in **Table G-3**. The data represent sanitary flow but may be partially diluted by stormwater."

Please provide justification as to how the data is representative of the sanitary conditions.

Comment 16: Section I.1.1, Page 75, Existing NBMUA Woodcliff Model. Section I.1.1 contains a description of the existing NBMUA Woodcliff Model and the existing Guttenberg model. The discussion in this section focuses on the received models. Please provide either a similar discussion and model input screen for the updated models or clarify that this discussion pertains to the updated models.

Comment 17: Figure I-7, Page 81, Woodcliff STP Model. Only 45 of the 618 manholes were included in the model. Please explain the reasons for not including most of the manholes in the service area in the model and justify the rationale of the ones selected.

Comment 18: Table I-4, Page 87, Impervious and Effective Impervious Area. The information in this table should be broken down by subcatchment. Also, the percent effective imperviousness for both North Bergen and Guttenberg are low considering the urban setting of the service area; please provide further discussion and justification. Also, please provide the land use information for Guttenberg and North Bergen, including the percentage of each type.

Comment 19: Table I-5, Page 87. Please provide additional details as to how the subcatchment unit width was derived.

Comment 20: Section I.3.2, Page 88, Manning's "n" Roughness Coefficients. The report states that initial values were set to 0.02 for impervious surfaces and 0.05 for pervious surfaces. Please provide the final values used after successful model calibration. Please provide the final values used after successful model calibration and a comparison to the range of acceptable literature values.

Comment 21: Section I.3.2, Page 88, Soil Infiltration. It is unclear what soil infiltration value was chosen. Please provide such.

Comment 22: Section I.3.7, Page 89, Rainfall Derived Infiltration and Inflow (RDII). Please provide the RTK values as broken down by subcatchment.

Comment 23: Section I.5.2, Page 92, WWF Calibration. The report states that the acceptable range for simulated wet weather flow volume is within the range of -20% to +20% and the peak flow is within -15% to +25%. Please justify your selection of this range.

Comment 24: Table I-8, Page 93. Please provide all model calibration and validation results for all selected rainfall events, including an analysis of the results. Also, provide a full explanation of any calibration result that is not within the acceptable range.

Comment 25: Figure I-13, Page 95. Please provide enlarged versions of these figures. In addition, please provide the data in tabular format that was utilized to generate these figures.

Comment 26: Section I.6.2, Page 98, Percent Capture. This section should be omitted from this report as it is more applicable in the Development and Evaluation of Alternatives Report, which is to be submitted on July 1, 2019.

Comment 27: Appendix A, Combined Sewer Overflow and Stormwater Sampling Results. Please provide the data in excel format as well.

Please incorporate these changes to the report and submit a revised version to the Department no later than 60 days from the date of this letter.

Thank you for your continued cooperation.

Sincerely,

Joseph Mannick, CSO Team Leader

Bureau of Surface Water Permitting

C: Marzooq Alebus, Bureau of Surface Water Permitting Teresa Guloy, Bureau of Surface Water Permitting Susan Rosenwinkel, Bureau of Surface Water Permitting Changi Wu, Bureau of NonPoint Pollution Control

Finizio, Marlene

From: Kobesky, Dwayne < Dwayne.Kobesky@dep.nj.gov>

Sent: Thursday, December 06, 2018 2:59 PM

To: McKenna, Bridget; Hope, Michael; Rosenwinkel, Susan; Mannick, Joe; Kempel, Nancy Cc: Eley, Marques; Sheldon S. Lipke (slipke@SJLConsultants.com); mwitt; Finizio, Marlene;

Fang, Yuan; Gibby, Eloise; Dupuis, Timothy J.; David Ksyniak (ksyniakda@cdmsmith.com)

Subject: RE: [EXTERNAL] RE: [EXTERNAL] Technical Comments on the Service Area System

Characterization Report

Hi Bridget,

In response to your request for an extension of time, the Department is granting you your request of a 45 day extension to resubmit the System Characterization Reports for the PVSC District and the North Bergen MUA/Guttenberg District Reports to address the comments received from the MEG.

Please let me know if you have any questions.

Dwayne

From: McKenna, Bridget < BMcKenna@PVSC.COM>

Sent: Thursday, December 6, 2018 8:14 AM

To: Kobesky, Dwayne <Dwayne.Kobesky@dep.nj.gov>; Hope, Michael <mhope@greeley-hansen.com>; Rosenwinkel, Susan <Susan.Rosenwinkel@dep.nj.gov>; Mannick, Joe <Joe.Mannick@dep.nj.gov>; Kempel, Nancy <Nancy.Kempel@dep.nj.gov>

Cc: Eley, Marques <MEley@PVSC.COM>; Sheldon S. Lipke (slipke@SJLConsultants.com) <slipke@SJLConsultants.com>; mwitt <mwitt@chasanlaw.com>; Finizio, Marlene <mfinizio@greeley-hansen.com>; Fang, Yuan <yfang@greeley-hansen.com>; Gibby, Eloise <egibby@greeley-hansen.com>; Dupuis, Timothy J. <dupuistj@cdmsmith.com>; David Ksyniakda@cdmsmith.com) <ksyniakda@cdmsmith.com>

Subject: RE: [EXTERNAL] RE: [EXTERNAL] Technical Comments on the Service Area System Characterization Report

Good morning,

PVSC held its 4th MEG meeting yesterday. As a result of comments received from the MEG members, PVSC is respectfully requesting a 45 day extension to resubmit the System Characterization Reports for the PVSC District and the North Bergen MUA/Guttenberg District Reports to address the comments received yesterday.

Should you have any questions regarding this request or require additional information please call or email me. Thanks very much,

Bridget

Bridget M. McKenna | Chief Operating Officer

Passaic Valley Sewerage Commission | 600 Wilson Avenue | Newark, New Jersey 07105 (P) 973-817-5976 | (F) 973-817-5709 | email: bmckenna@pvsc.com

From: Kobesky, Dwayne [mailto:Dwayne.Kobesky@dep.nj.gov]

Sent: Wednesday, December 05, 2018 9:15 AM

June 2018 (Revised 04/09/19)

To: Hope, Michael < mhope@greeley-hansen.com; Rosenwinkel, Susan < Susan.Rosenwinkel@dep.nj.gov; Mannick, Joe < Joe.Mannick@dep.nj.gov >; Kempel, Nancy < Na

Cc: McKenna, Bridget < BMcKenna@PVSC.COM>; Eley, Marques < MEley@PVSC.COM>; Sheldon S. Lipke (slipke@SJLConsultants.com) < slipke@SJLConsultants.com>; mwitt < mwitt@chasanlaw.com>; Finizio, Marlene < mfinizio@greeley-hansen.com>; Fang, Yuan < yfang@greeley-hansen.com>; Gibby, Eloise < egibby@greeley-hansen.com>; Dupuis, Timothy J. < dupuistj@cdmsmith.com>; David Ksyniak (ksyniakda@cdmsmith.com) < ksyniakda@cdmsmith.com>

Subject: [EXTERNAL] RE: [EXTERNAL] Technical Comments on the Service Area System Characterization Report

Hi Mike,

Thank you. Receipt confirmed.

Dwayne

From: Hope, Michael < mhope@greeley-hansen.com >

Sent: Tuesday, December 4, 2018 5:09 PM

To: Rosenwinkel, Susan <<u>Susan.Rosenwinkel@dep.nj.gov</u>>; Kobesky, Dwayne <<u>Dwayne.Kobesky@dep.nj.gov</u>>; Mannick, Joe <<u>Joe.Mannick@dep.nj.gov</u>>; Kempel, Nancy <<u>Nancy.Kempel@dep.nj.gov</u>>; DEP NJCSOProgram NJCSOProgram@dep.nj.gov

Cc: McKenna, Bridget <<u>BMcKenna@PVSC.COM</u>>; Eley, Marques <<u>MEley@PVSC.COM</u>>; Sheldon S. Lipke (<u>slipke@SJLConsultants.com</u>>; mwitt <<u>mwitt@chasanlaw.com</u>>; Finizio, Marlene <<u>mfinizio@greeley-hansen.com</u>>; Fang, Yuan <<u>yfang@greeley-hansen.com</u>>; Gibby, Eloise <<u>egibby@greeley-hansen.com</u>>; Dupuis, Timothy J. <<u>dupuistj@cdmsmith.com</u>>; David Ksyniak (<u>ksyniakda@cdmsmith.com</u>) <ksyniakda@cdmsmith.com>

Subject: RE: [EXTERNAL] Technical Comments on the Service Area System Characterization Report

Good afternoon.

We are in receipt of the New Jersey Department of Environmental Protection's (NJDEP's) letter, dated October 9, 2018, which transmitted technical comments on the Service Area System Characterization (Report) for the Passaic Valley Sewerage Commission (PVSC) and the Permittees within the PVSC Sewer District. Comment No. 1 and Comment No. 28 have requested the combined sewer overflow and stormwater sampling data to be provided in Microsoft Excel format.

Attached and in response to these comments, on behalf of PVSC and the Permittees within the PVSC Sewer District, please find the requested combined sewer overflow and stormwater data in Microsoft Excel format.

Please note that the revised Report in order to address the remaining NJDEP's comments as transmitted in the above referenced letter will be sent under a separate email.

Thank you,



Michael J. Hope, P.E. Managing Director 1700 Market Street, Suite 2130 Philadelphia, Pennsylvania 19103 P: 215.553.7917 greeley-hansen.com



From: Kobesky, Dwayne [mailto:Dwayne.Kobesky@dep.nj.gov]

Sent: Tuesday, October 09, 2018 2:52 PM

To: McKenna, Bridget <<u>BMcKenna@PVSC.COM</u>>; <u>boroughofeastnewark@verizon.net</u>; Newark - Adebowale, Andrea <<u>Adebowalea@ci.newark.nj.us</u>>; 'fmargron@patersonnj.gov' <<u>fmargron@patersonnj.gov</u>>; 'tboyle@baynj.org' <<u>tboyle@baynj.org</u>>; <u>rrussomanno@townofharrison.com</u>; 'Smith, Robert J.' <<u>rsmith@kearnynj.org</u>>; <u>Fpnbmua@aol.com></u>

Cc: Rosenwinkel, Susan < Susan.Rosenwinkel@dep.nj.gov >; Alebus, Marzooq < Marzooq.Alebus@dep.nj.gov >; Guloy, Teresa < Teresa.Guloy@dep.nj.gov >; Mannick, Joe < Joe.Mannick@dep.nj.gov >; Ebersberger, Timothy < timothy.ebersberger@dep.nj.gov >

Subject: [EXTERNAL] Technical Comments on the Service Area System Characterization Report

Good Afternoon,

Please find the attached Technical Comments on the Service Area System Characterization Report.

Thank you,

Dwayne Kobesky

New Jersey Department of Environmental Protection
Division of Water Quality
Bureau of Surface Water Permitting
401 East State Street, P.O. Box 420
Mail Code 401-02B
Trenton, NJ 08625-0420
(609) 292-4860
Dwayne.Kobesky@dep.nj.gov

APPENDIX E

NJDEP Comment Letter Dated February 27, 2019

Email from NJDEP to PVSC Dated March 29, 2019 Granting 10 day Extension



State of New Jersey

PHIL MURPHY DEPARTMENT OF ENVIRONMENTAL PROTECTION

Governor Mail Code – 401-02B

Water Pollution Management Element Bureau of Surface Water Permitting P.O. Box 420 – 401 E State St

Trenton, NJ 08625-0420 Phone: (609) 292-4860 / Fax: (609) 984-7938 CATHERINE R. McCABE

Commissioner

February 27, 2019

Frank Pestana, Executive Director North Bergen Municipal Utilities Authority 6200 Tonnelle Avenue North Bergen, NJ 07047

SHEILA OLIVER

Lt. Governor

Alberto Cabrera, Town Clerk Town of Guttenberg 6808 Park Avenue Guttenberg, NJ 07093

Re: Review of Revised "Service Area System Characterization Report"

North Bergen Municipal Utilities Authority, NJPDES Permit No. NJ0029084

Town of Guttenberg, NJPDES Permit No. NJ0108715

Dear Permittees:

Thank you for your submission dated January 24, 2019 which contains a revised version of the "Service Area System Characterization Report" as well as a "Summary of Changes" document. The original submission was dated June 2018 and was in response to Part IV.D.3.b.ii of the above referenced NJPDES permit. The New Jersey Department of Environmental Protection (the Department or NJDEP) provided technical comments on your original submission on October 11, 2018 where this revised submission is in response to those comments. The Department acknowledges that both the original and revised submissions were made in a timely manner. This letter is written to provide a determination on your most recent submission.

The Department has conducted a technical review of your revised report and has the following remaining technical comments. Any comments that pertain to the October 11, 2018 document are identified as "Former NJDEP Comment" with the relevant number.

Comment 1: Section D.1.6, Areas Prone to Flooding and Sewer System Backups. As stated in Former NJDEP Comment 4, Part IV.G.1.b of the permit requires a thorough review of the entire collection system that conveys flows to the Woodcliff STP, including areas of sewage overflows. Therefore, the report shall include a discussion of areas that are prone to flooding based on observed and reported incidents, including dates of occurrence, type of storm events that caused the flooding, and antecedent conditions, if known. In response to this comment you provided information for the Town of Guttenberg stating that the "...Borough of Guttenberg does not have records indicating areas prone to flooding or sewer system backups."

The Department is aware of at least three incidences of sewer overflows in Guttenberg. As reported to the NJDEP Hotline on August 11, September 25 and December 21 of 2018 and January 24 and February 4 of 2019, an overflow occurred at a manhole in the Galaxy Towers parking lot at 7200 River Road due to periods of intense rain. Please verify with the Town of Guttenberg as to whether or not these incidents occurred and also confirm with them if they have any known areas or recordkeeping for

flooding incidents. In addition, note that special attention should be paid to any flooding issues when the Development and Evaluation of Alternatives report is prepared as due on July 1, 2019.

Comment 2: Section E.7, Rainfall Event Analysis; Section E.8, Wet Weather Event Selection for Model Calibration and Validation; and Section I.5.2, Wet Weather Flow Calibration/Validation. In the Department's October 11, 2018 letter, the selection of the July 31, 2016 rainfall event was questioned with a suggestion that the July 29, 2016 rainfall event be considered. It is unclear if the July 31, 2016 rainfall event was replaced with the July 30, 2016 rainfall event as indicated in "Table E-4: Top 10 Rainfall Events (Volume Based), 5/20/16-8/10/16"; "Table E-5: Calibration and Validation Rainfall Events" as well as in "Table I-9: Wet Weather Events for Model Calibration and Validation" of the revised report. Please clarify. (Former NJDEP Comment 11).

In addition, please provide justification for only using dates that had data from all 8 rain gauge locations. The geographic region discussed in this report is localized compared to the more regional report containing the other PVSC communities. Please discuss if rainfall variation (specifically for the NBMUA and Guttenberg service areas) is a contributing factor for the decision to want data from all 8 gauges compared to the primary gauge at Newark Airport and the closest gauge (NY Central Park). As noted in Former Comment 11 these two gauges cover both the July 9th and 16th storms which are short duration storms which are under represented in the analysis.

Comment 3: Section I.2.3, Model Evaluation Group. The Department is aware that this subject "Service Area System Characterization Report" is one of the reports that is being reviewed by the Model Evaluation Group and acknowledges that there is a new section in the revised report (Section I.2.3) describing this review. In addition, Appendix B contains summaries and meeting minutes as well as an e-mail from the Model Evaluation Group dated March 6, 2016 regarding Session 1 as held on February 5, 2016. Please provide additional information as to whether or not any other input or formal concurrence or approval has transpired with the Model Evaluation Group regarding Session 2 (March 17, 2017), Session 3 (September 15, 2017), Session 4 (December 5, 2018), or regarding the final "Service Area System Characterization Report."

Comment 4: Section I.3.3, Trunk sewer and Main Interceptor. On page 100 it is stated that "Manning's "n" values in the model are in the range of 0.010 to 0.014." It is further stated on page 100 that the "Manning's "n" may be changed during calibration to account for minor loss or additional sediment depositions in the pipe." Yet Manning's N values were included in Appendix B of the revised report as a standard value of 0.05 for pervious surfaces and 0.02 for impervious surfaces. Please confirm if there were any adjustments to the Manning's values as part of the calibration/validation process. (Former NJDEP Comment 20)

Comment 5: Section I.6.2, Percent Capture. Table I-11 of the revised report is unchanged from the July 2018 report and includes a representation of Percent Capture. This section states that "Wet weather capture was calculated for the CSO communities contributing flows to the NBMUA Woodcliff STP." This table depicts percent capture for the 2004 Typical Year and shows 89% capture for the Woodcliff STP.

As described in the October 11, 2018 letter, the Department objected to inclusion of this information in the July 2018 submission (Former NJDEP Comment 26) based on the rationale that it is more appropriate for the Development and Evaluation of Alternatives Report, which is to be submitted on July 1, 2019. However, because this table is included in the revised report without change the Department is hereby expressing its objections. The Department acknowledges that percent capture is a component of the National CSO Control Policy where this section is referenced within the Presumption Approach as follows:

"ii. The elimination or the capture for treatment of no less than 85% by volume of the combined sewage collected in the CSS during precipitation events on a system-wide annual average basis."

Similar language is included in the NJPDES permit at Part IV.G.4.f.ii also as one of the criteria for the Presumption Approach:

"ii. The elimination or the capture for treatment of no less than 85% by volume of the combined sewage collected in the CSS during precipitation events on a hydraulically connected system-wide annual average basis."

While an equation was not provided within Section I.6.2 of the revised report, it appears that the resultant calculations may include separately sewered portions of the municipalities that send flow to the Woodcliff STP in the overall average. Please note the above permit language specifically references the "CSS"; therefore, any percent capture calculation that includes separately sewered communities is in direct conflict with the NJPDES permit and National CSO Control Policy.

Comment 6: Please provide a pie chart depicting the total runoff generated for 2004 from the combined sewer areas and assumed water loss, i.e., water budget (Former Comment 5). To provide further detail on an acceptable option, this chart can be generated for the total runoff generated from the modeled combined sewer area using data exported from the existing conditions hydraulic model simulation for the 2004 representative year precipitation record. The volume of precipitation falling upon the overall combined sewer area can be partitioned into 3 broad components, which is consistent with data available through the modeling software. The total annual surface runoff volume calculated to enter the modeled collection system can be divided into a treated runoff volume and an overflow runoff volume, while the balance of the water budget outflows (i.e. losses), such as evaporation, interception, infiltration, and direct runoff to water bodies, can be classified as overall water losses. In summary, a simple pie chart showing the approximate percentage of treated runoff volume, overflow runoff volume, and water losses within the combined sewer areas would suffice.

Please incorporate these changes to the report and submit a revised version to the Department no later than 30 days from the date of this letter.

Thank you for your continued cooperation.

Sincerely,

Joseph Mannick, CSO Team Leader

Bureau of Surface Water Permitting

C: Marzooq Alebus, Bureau of Surface Water Permitting Stephen Seeberger, Bureau of Surface Water Permitting Teresa Guloy, Bureau of Surface Water Permitting Susan Rosenwinkel, Bureau of Surface Water Permitting Adam Sarafan, Bureau of Surface Water Permitting Chang I Wu, Bureau of Nonpoint Pollution Control

Finizio, Marlene

Subject: FW: Review of Revised CSO System Characterization Report for North Bergen and

Guttenberg

Attachments: NBMUA Revised Report 2 27 19.pdf

From: Rosenwinkel, Susan [mailto:Susan.Rosenwinkel@dep.nj.gov]

Sent: Friday, March 29, 2019 12:15 PM

To: Hope, Michael < mhope@greeley-hansen.com>

Subject: Review of Revised CSO System Characterization Report for North Bergen and Guttenberg

I understand this information was never forwarded. Pursuant to our discussion please provide a response to this letter by Monday, April 8.

Thanks,

Susan Rosenwinkel

Bureau Chief NJDEP-Division of Water Quality Bureau of Surface Water Permitting 401 E. State St, P.O. Box 420 Mail Code 401-02B Trenton, NJ 08625-0420

Tel: (609) 292-4860

Susan.rosenwinkel@dep.nj.gov

From: Mannick, Joe

Sent: Wednesday, February 27, 2019 11:00 AM

To: Frank Pestana < FPestana@nbmua.com>; 'townclerk@myguttenberg.com' < townclerk@myguttenberg.com>

Cc: Rosenwinkel, Susan < <u>Susan.Rosenwinkel@dep.nj.gov</u>>; Alebus, Marzooq < <u>Marzooq.Alebus@dep.nj.gov</u>>; Seeberger,

Stephen <Stephen.Seeberger@dep.nj.gov>; Sarafan, Adam <Adam.Sarafan@dep.nj.gov>; Wu, Chang I.

<Chang.I.Wu@dep.nj.gov>; Guloy, Teresa <Teresa.Guloy@dep.nj.gov>

Subject: Review of Revised CSO System Characterization Report for North Bergen and Guttenberg

Good Morning,

Please find the attached review of revised CSO system characterization report letter.

Joe Mannick, CSO Program Coordinator New Jersey Department of Environmental Protection Division of Water Quality Bureau of Surface Water Permitting

Ph: 609.292.4860